

DAYYER, Iran, Islamic Republic of

WMO: 408720

Lat: 27.833N

Lon: 51.933E

Elev: 4

StdP: 101.28

Time Zone: 3.50 (IRN)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.0	(c) 12.6	(d) -6.2	(e) 2.2	(f) 18.5	(g) -3.4	(h) 2.8	(i) 18.9	(j) 12.5	(k) 14.4	(l) 11.0	(m) 18.4	(n) 5.6	(o) 310	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.2	(c) 44.1	(d) 22.6	(e) 42.1	(f) 22.8	(g) 40.4	(h) 23.1	(i) 32.0	(j) 36.3	(k) 31.5	(l) 35.9	(m) 31.0	(n) 35.6	(o) 6.2	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
31.0	28.9	35.7	30.4	27.9	35.4	29.9	27.1	35.1	111.6	36.4	108.5	35.9	106.2	35.7	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.3	9.0	7.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	4.0	32.7	2.0	0.7	2.6	33.2	1.4	33.7	0.3	34.1	-1.2	34.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	18.3	18.8	22.6	27.0	32.6	34.2	35.0	34.6	33.2	30.0	24.7	20.4
	DBStd	6.67	2.24	2.50	2.51	2.85	3.37	3.26	2.33	1.38	1.82	2.30	2.79	2.13
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	56	28	21	2	0	0	0	0	0	0	0	0	5
	CDD10.0	6447	257	246	389	511	701	726	774	764	697	618	442	322
	CDD18.3	3462	27	34	133	261	442	476	516	506	447	360	192	69
	CDH23.3	49867	40	75	771	2729	6734	7708	8663	8604	7390	5144	1721	287
	CDH26.7	31664	1	5	154	1115	4301	5311	6183	6124	4993	2867	583	27
(14) Wind	WSAvg	3.3	3.9	3.8	3.5	3.2	3.7	3.9	3.0	2.6	2.9	2.8	3.2	3.4
(15) Precipitation	PrecAvg	229	84	21	20	4	0	0	0	0	0	2	28	69
	PrecMax	500	278	63	81	15	1	0	3	0	1	22	90	254
	PrecMin	95	9	0	0	0	0	0	0	0	0	0	0	3
	PrecStd	105	73	19	24	4	0	0	1	0	0	6	34	85
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	27.5	33.2	38.4	45.1	47.1	46.5	42.6	42.6	40.9	33.8	28.7
		MCWB	16.8	16.5	16.6	20.8	22.2	23.0	24.1	26.2	22.2	21.3	20.1	19.8
	2%	DB	24.4	25.2	30.0	35.8	42.7	44.3	43.6	40.2	39.6	38.0	31.9	27.3
		MCWB	18.3	17.6	17.9	20.5	21.3	22.1	23.8	28.0	23.2	22.3	20.8	19.0
	5%	DB	23.6	24.1	28.2	33.8	40.6	42.0	40.8	38.5	37.7	35.8	30.9	26.1
		MCWB	18.1	17.7	18.2	20.1	21.1	22.3	24.0	28.7	25.9	23.9	21.3	18.6
	10%	DB	22.8	23.1	26.9	31.9	38.8	39.9	38.5	37.4	36.7	34.5	29.9	25.0
		MCWB	17.3	17.1	17.9	20.2	21.2	22.6	25.9	29.7	27.9	24.9	21.1	17.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	20.7	23.0	25.8	28.8	31.2	32.2	33.0	31.9	30.0	25.6	22.7
		MCDB	24.0	23.9	27.2	29.7	32.1	34.7	36.1	37.2	36.4	34.2	30.0	27.0
	2%	WB	20.2	19.9	21.8	24.9	27.9	30.3	31.7	32.3	31.1	28.8	24.5	21.1
		MCDB	23.6	23.4	25.9	29.5	32.0	33.9	35.8	36.6	35.7	33.7	29.6	25.7
	5%	WB	19.4	19.2	21.1	23.9	27.1	29.7	31.2	31.7	30.5	28.0	23.3	19.8
		MCDB	22.9	22.8	25.2	28.9	32.0	33.5	35.5	36.3	35.4	33.2	29.1	24.9
	10%	WB	18.3	18.3	20.5	23.0	26.3	29.2	30.8	31.3	30.0	27.1	22.0	18.7
		MCDB	22.0	22.1	24.8	28.8	31.7	33.3	35.2	36.0	35.1	32.7	28.2	23.7
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	7.6	7.8	7.9	8.3	7.8	6.2	5.7	7.2	8.5	8.4	8.4
		MCDBR	8.0	8.0	9.4	10.4	11.6	11.6	10.4	7.8	8.7	10.2	9.0	9.1
		MCWBR	5.6	5.8	6.4	5.9	5.5	5.9	6.8	7.0	6.8	7.0	5.8	5.9
	5% WB	MCDBR	6.9	6.5	7.2	7.6	7.6	7.0	5.3	5.7	6.3	7.9	7.7	8.2
		MCWBR	6.2	5.9	7.0	6.7	7.6	6.8	5.7	5.5	6.1	6.8	6.6	6.3
(40) Clear-Sky Solar Irradiance	taub		0.467	0.527	0.591	0.656	0.641	0.621	0.707	0.674	0.580	0.525	0.480	0.454
	taud		1.987	1.842	1.694	1.609	1.627	1.681	1.574	1.647	1.780	1.881	1.988	2.030
	Ebn at Noon		750	737	718	688	700	710	650	667	717	728	731	742
	Edh at Noon		155	193	237	266	261	246	273	252	214	183	153	142
(44) All-Sky Solar Radiation	RadAvg		3.80	4.59	5.75	6.58	7.77	8.28	7.75	7.29	6.64	5.52	4.08	3.58
	RadStd		0.28	0.36	0.47	0.44	0.21	0.13	0.17	0.16	0.14	0.18	0.29	0.32

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page