

BANDAR ABBASS INTL, Iran, Islamic Republic ofWMO: **408750**Lat: **27.2154N**Lon: **56.3732E**Elev: **10**StdP: **101.20**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	10.8	-10.0	1.6	20.9	-5.3	2.4	19.1	9.9	20.1	8.5	20.0	1.9	0	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	42.0	24.4	40.2	25.6	39.0	26.1	31.2	35.6	30.7	35.1	30.5	34.9	4.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
30.2	27.5	34.2	29.9	27.1	34.1	29.2	26.0	33.9	107.4	36.1	104.7	34.9	103.0	35.2	35.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.7	6.9	DB	6.2	45.2	1.3	1.1	5.3	46.0	4.5	46.6	3.8	47.2	2.9	48.0	(4)
(5)			WB	2.5	32.2	1.9	0.7	1.1	32.7	0.0	33.1	-1.1	33.5	-2.5	34.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	17.7	19.7	22.6	27.0	31.2	33.7	34.5	33.9	32.3	29.4	24.0	19.6
	DBStd	6.22	2.25	2.31	2.17	2.20	1.68	1.52	1.19	1.26	1.19	1.75	2.44	2.32
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	65	38	12	1	0	0	0	0	0	0	0	0	14
	CDD10.0	6265	239	271	392	510	657	709	759	740	668	601	421	297
	CDD18.3	3288	19	49	134	260	399	459	501	482	418	343	171	53
	CDH23.3	47211	95	254	1042	3075	6057	7538	8265	7830	6459	4555	1615	425
CDH26.7	28941	2	30	278	1460	3704	5142	5785	5351	4081	2481	572	55	
Wind	WSAvg	3.4	2.8	3.2	3.4	3.6	3.6	3.7	3.9	3.8	3.5	3.1	3.1	2.9
Precipitation	PrecAvg	164	47	31	36	5	0	1	3	0	1	5	8	27
	PrecMax	384	147	182	170	75	1	11	46	2	7	66	50	173
	PrecMin	33	2	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	91	42	41	52	14	0	2	10	1	1	14	11	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	29.2	33.2	38.0	42.1	44.1	43.9	43.1	41.0	39.0	34.0	30.0
		MCWB	16.5	18.7	20.2	21.4	23.3	24.0	23.1	24.5	23.0	21.2	18.8	16.6
	2%	DB	25.2	27.2	31.0	36.0	39.5	42.0	41.1	40.9	39.0	36.9	32.1	28.1
		MCWB	17.8	18.9	19.7	21.8	23.6	24.3	25.6	25.9	23.8	22.3	21.0	17.1
	5%	DB	24.2	25.9	29.2	34.2	38.1	40.1	39.2	38.9	37.4	35.6	31.0	27.0
		MCWB	17.3	18.6	19.9	22.1	24.2	25.8	27.9	28.0	26.4	24.3	21.8	17.9
	10%	DB	23.3	24.9	28.0	33.0	36.9	38.8	38.0	37.2	36.1	34.2	29.9	25.9
		MCWB	16.7	18.4	20.1	22.4	24.4	26.4	28.6	29.2	27.7	25.3	21.5	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	22.1	23.7	26.4	29.2	31.1	31.8	32.0	30.7	29.6	27.8	22.7
		MCDB	24.2	25.6	28.5	31.4	34.4	36.0	36.3	36.1	35.2	34.0	30.4	26.3
	2%	WB	20.3	21.1	22.7	25.4	28.3	30.5	31.2	31.2	30.3	28.8	25.5	21.4
		MCDB	23.7	24.8	27.3	30.8	33.5	35.1	35.6	35.5	34.7	33.2	29.4	25.2
	5%	WB	19.4	20.5	22.1	24.7	27.6	29.9	30.8	30.7	29.7	28.1	24.4	20.5
		MCDB	22.9	24.2	26.7	30.3	32.9	34.5	35.2	35.0	34.1	32.5	28.7	24.3
	10%	WB	18.4	19.7	21.4	24.0	27.0	29.4	30.5	30.4	29.3	27.4	23.5	19.4
		MCDB	21.9	23.5	25.9	29.8	32.5	34.4	35.0	34.7	33.8	32.0	27.8	23.6
Mean Daily Temperature Range	5% DB	MDBR	10.9	10.1	9.9	10.7	11.0	9.6	7.0	6.9	8.3	10.4	11.3	12.2
		MCDBR	11.5	10.9	12.2	13.2	13.3	13.1	10.4	10.8	11.3	12.3	12.0	13.1
		MCWBR	6.6	5.8	5.7	5.6	5.6	6.2	5.6	5.6	5.9	6.3	6.3	7.0
	5% WB	MCDBR	9.3	8.9	9.9	10.7	10.5	8.5	6.7	7.0	7.8	8.9	9.2	10.4
		MCWBR	6.0	5.4	5.4	5.3	5.0	4.6	3.7	3.8	4.2	4.9	5.5	6.4
Clear-Sky Solar Irradiance	taub	0.422	0.487	0.543	0.576	0.582	0.638	0.716	0.678	0.597	0.509	0.434	0.409	
	taud	2.146	1.964	1.825	1.777	1.773	1.700	1.599	1.667	1.785	1.943	2.134	2.189	
	Ebn at Noon	806	778	760	749	743	699	645	665	706	747	786	801	
	Edh at Noon	132	172	208	225	226	242	267	248	214	173	133	122	
All-Sky Solar Radiation	RadAvg	3.90	4.63	5.75	6.78	7.62	7.76	7.20	6.88	6.26	5.42	4.29	3.73	
	RadStd	0.25	0.37	0.39	0.32	0.16	0.19	0.20	0.23	0.13	0.11	0.14	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	-1.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page