

KAHNUJ, Iran, Islamic Republic of

WMO: 408770

Lat: 27.9939N

Lon: 57.7129E

Elev: 1542

StdP: 13.90

Time Zone: 3.50 (IRN)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.7	42.9	12.4	10.9	56.3	16.5	13.4	54.7	28.7	69.6	26.8	68.7	1.2	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	114.5	70.3	112.9	70.3	111.2	70.1	80.4	101.7	79.1	99.8	78.0	97.9	10.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	139.4	91.8	73.7	132.8	91.5	72.3	126.7	92.0	45.7	101.8	44.3	100.2	43.1	98.4	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.6	27.0	23.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	28.3	82.5	3.6	2.3	25.7	84.2	23.6	85.6	21.6	86.9	19.0	88.6	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	59.1	62.0	71.8	82.0	92.7	99.0	99.8	97.8	92.9	84.1	70.0	60.7
	DBStd	15.83	5.30	7.09	5.71	5.56	4.41	3.18	2.86	3.38	3.24	4.67	6.69	6.03
	HDD50	11	2	6	0	0	0	0	0	0	0	0	0	3
	HDD65	517	195	125	10	0	0	0	0	0	0	0	29	158
	CDD50	11364	284	343	675	961	1324	1471	1545	1481	1288	1057	600	335
	CDD65	6394	12	42	220	511	859	1021	1080	1016	838	592	178	25
	CDH74	99900	42	309	2139	6495	13710	17711	18725	17357	13505	7950	1699	258
	CDH80	68939	0	76	831	3605	9421	13395	14261	12894	9284	4570	566	36
(14) Wind	WSAvg	11.0	8.1	9.5	11.4	12.3	13.2	14.0	15.0	13.5	11.9	10.0	7.1	6.6
(15) Precipitation	PrecAvg	6.3	1.9	1.6	1.1	0.2	0.1	0.1	0.1	0.2	0.0	0.1	0.2	1.0
	PrecMax	15.4	5.9	5.6	5.6	2.1	0.6	0.6	0.7	0.7	0.5	1.0	1.8	9.1
	PrecMin	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	1.5	1.5	1.5	0.4	0.1	0.2	0.2	0.2	0.1	0.2	0.4	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.1	87.2	95.4	103.9	113.5	116.6	116.3	114.8	111.4	105.4	91.3	84.0
		MCWB	58.2	61.4	64.4	66.7	69.4	72.5	69.9	71.3	69.1	67.0	61.9	60.4
	2%	DB	75.1	82.3	91.9	101.3	110.4	114.5	114.5	112.8	108.8	102.0	88.8	79.4
		MCWB	57.8	60.3	63.0	66.1	69.2	70.3	70.0	70.2	68.4	67.1	62.3	58.0
	5%	DB	72.5	77.4	88.4	98.3	107.7	112.8	112.6	111.2	106.9	99.2	86.2	76.7
		MCWB	56.8	57.9	61.3	65.3	68.8	70.2	70.7	70.3	68.3	66.4	62.7	57.2
	10%	DB	70.1	74.2	85.0	94.9	105.2	110.8	110.5	109.1	104.5	96.5	83.0	73.7
		MCWB	55.9	56.8	60.1	64.6	68.5	69.6	71.2	70.4	68.8	65.8	61.1	56.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.8	65.7	68.8	71.9	82.5	81.2	81.5	82.2	79.4	76.5	69.7	64.2
		MCDB	70.8	76.9	87.9	95.1	105.0	105.8	103.2	104.1	94.0	92.7	81.8	74.0
	2%	WB	61.3	62.7	66.1	69.3	76.3	79.2	80.2	79.6	77.8	74.7	68.0	62.3
		MCDB	69.8	73.4	81.4	89.8	98.5	103.4	101.3	99.7	94.0	88.1	79.0	73.6
	5%	WB	60.1	60.9	64.5	67.7	72.4	77.2	79.1	78.4	76.4	72.7	66.3	60.7
		MCDB	68.5	71.1	79.3	89.2	98.1	99.8	100.3	97.4	92.8	85.7	77.3	71.2
	10%	WB	58.5	59.6	62.9	66.5	70.2	75.2	78.1	77.3	75.2	70.9	64.4	58.8
		MCDB	66.9	69.9	77.1	88.6	97.3	97.3	98.9	95.5	91.4	85.8	77.1	69.0
(35) Mean Daily Temperature Range	5% DB	MDBR	21.2	20.3	22.1	22.7	24.1	24.2	21.9	22.8	24.3	24.5	23.6	25.3
		MCDBR	23.2	23.5	26.9	25.8	26.4	25.6	24.0	24.5	26.4	26.1	24.0	27.0
		MCWBR	11.0	9.4	8.8	8.0	7.5	6.8	6.9	6.6	7.4	8.4	9.3	12.3
	5% WB	MCDBR	16.7	18.2	21.7	23.3	25.3	24.1	20.6	21.3	21.1	21.8	18.7	20.3
		MCWBR	8.9	8.9	8.6	8.6	10.3	8.5	7.8	7.1	7.3	8.1	8.4	10.1
(40) Clear-Sky Solar Irradiance	taub		0.384	0.447	0.501	0.545	0.566	0.613	0.652	0.622	0.555	0.485	0.403	0.372
	taud		2.221	2.027	1.874	1.799	1.765	1.697	1.655	1.705	1.808	1.938	2.166	2.260
	Ebn at Noon		268	258	252	245	239	227	218	223	233	242	258	266
	Edh at Noon		38	51	62	69	72	77	80	75	66	55	40	36
(44) All-Sky Solar Radiation	RadAvg		1234	1454	1813	2135	2377	2456	2329	2235	2010	1729	1373	1191
	RadStd		86	112	126	102	91	85	63	83	46	45	49	69

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page