

KAHNUJ, Iran, Islamic Republic of

WMO: 408770

Lat: 27.9939N

Lon: 57.7129E

Elev: 470

StdP: 95.80

Time Zone: 3.50 (IRN)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.3	6.1	-10.9	1.6	13.5	-8.6	1.9	12.6	12.8	20.9	12.0	20.4	0.5	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	45.8	21.3	44.9	21.3	44.0	21.2	26.9	38.7	26.2	37.7	25.6	36.6	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.9	33.2	23.2	19.0	33.1	22.4	18.1	33.3	88.3	38.8	85.1	37.9	82.3	36.9	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.1	10.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-2.0	28.1	2.0	1.3	-3.5	29.0	-4.6	29.8	-5.8	30.5	-7.2	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	15.1	16.7	22.1	27.8	33.7	37.2	37.7	36.5	33.9	28.9	21.1	15.9		
	DBStd	8.79	2.94	3.94	3.17	3.09	2.45	1.77	1.59	1.88	1.80	2.59	3.71	3.35		
	HDD10.0	6	1	3	0	0	0	0	0	0	0	0	0	2		
	HDD18.3	287	108	69	6	0	0	0	0	0	0	0	16	88		
	CDD10.0	6313	158	191	375	534	736	817	858	823	716	587	333	186		
	CDD18.3	3552	7	23	122	284	477	567	600	564	466	329	99	14		
	CDH23.3	55500	23	172	1188	3608	7617	9839	10403	9643	7503	4417	944	143		
	CDH26.7	38299	0	42	462	2003	5234	7442	7923	7163	5158	2539	314	20		
(14) Wind	WSAvg	4.9	3.6	4.2	5.1	5.5	5.9	6.3	6.7	6.0	5.3	4.5	3.2	3.0		
(15) Precipitation	PrecAvg	161	47	40	29	5	2	2	2	5	1	2	6	26		
	PrecMax	390	151	142	143	53	14	14	17	17	12	26	46	232		
	PrecMin	7	1	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	93	37	39	38	11	3	4	5	5	2	6	10	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.6	30.7	35.2	40.0	45.3	47.0	46.8	46.0	44.1	40.8	32.9	28.9		
		MCWB	14.6	16.4	18.0	19.3	20.8	22.5	21.0	21.8	20.6	19.4	16.6	15.8		
	2%	DB	23.9	27.9	33.3	38.5	43.5	45.8	45.8	44.9	42.7	38.9	31.6	26.3		
		MCWB	14.3	15.7	17.2	18.9	20.7	21.3	21.1	21.2	20.2	19.5	16.8	14.5		
	5%	DB	22.5	25.2	31.3	36.8	42.1	44.9	44.8	44.0	41.6	37.4	30.1	24.8		
		MCWB	13.8	14.4	16.3	18.5	20.5	21.2	21.5	21.3	20.2	19.1	17.0	14.0		
	10%	DB	21.2	23.4	29.4	34.9	40.7	43.8	43.6	42.8	40.3	35.9	28.3	23.2		
		MCWB	13.3	13.8	15.6	18.1	20.3	20.9	21.8	21.3	20.4	18.8	16.2	13.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	18.7	20.4	22.2	28.1	27.3	27.5	27.9	26.3	24.7	20.9	17.9		
		MCDB	21.6	25.0	31.1	35.1	40.5	41.0	39.5	40.1	34.4	33.7	27.6	23.3		
	2%	WB	16.3	17.1	19.0	20.7	24.6	26.2	26.8	26.5	25.4	23.7	20.0	16.8		
		MCDB	21.0	23.0	27.4	32.1	37.0	39.7	38.5	37.6	34.4	31.2	26.1	23.1		
	5%	WB	15.6	16.1	18.1	19.8	22.5	25.1	26.2	25.8	24.7	22.6	19.0	16.0		
		MCDB	20.3	21.7	26.3	31.8	36.7	37.7	37.9	36.3	33.8	29.8	25.2	21.8		
	10%	WB	14.7	15.3	17.2	19.1	21.2	24.0	25.6	25.2	24.0	21.6	18.0	14.9		
		MCDB	19.4	21.0	25.0	31.5	36.3	36.3	37.2	35.3	33.0	29.9	25.1	20.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.3	12.3	12.6	13.4	13.5	12.2	12.7	13.5	13.6	13.1	14.1		
		MCDBR	12.9	13.0	15.0	14.3	14.7	14.2	13.3	13.6	14.7	14.5	13.3	15.0		
		MCWBR	6.1	5.2	4.9	4.4	4.2	3.8	3.8	3.7	4.1	4.7	5.1	6.9		
	5% WB	MCDBR	9.3	10.1	12.1	12.9	14.1	13.4	11.5	11.8	11.7	12.1	10.4	11.3		
		MCWBR	5.0	5.0	4.8	4.8	5.7	4.7	4.4	4.0	4.1	4.5	4.7	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.384	0.447	0.501	0.545	0.566	0.613	0.652	0.622	0.555	0.485	0.403	0.372		
	taud		2.221	2.027	1.874	1.799	1.765	1.697	1.655	1.705	1.808	1.938	2.166	2.260		
	Ebn at Noon		844	814	793	772	755	716	687	703	736	764	814	838		
	Edh at Noon		121	160	197	219	227	242	252	238	208	172	127	112		
(44) All-Sky Solar Radiation	RadAvg		3.89	4.58	5.71	6.73	7.49	7.74	7.34	7.05	6.33	5.45	4.33	3.75		
	RadStd		0.27	0.35	0.40	0.32	0.29	0.27	0.20	0.26	0.14	0.14	0.16	0.22		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page