

SARAVAN, Iran, Islamic Republic ofWMO: **408780**Lat: **27.3898N**Lon: **62.3184E**Elev: **1195**StdP: **87.77**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	1.7	-24.6	0.5	11.5	-21.3	0.6	10.6	10.4	16.5	9.1	13.7	3.0	320	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	40.7	17.4	39.8	17.2	38.8	16.8	22.3	30.5	21.7	30.2	21.0	30.4	4.2	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	17.1	27.7	18.9	15.9	28.4	17.5	14.5	29.0	72.5	30.1	70.2	30.0	67.2	30.2	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.5	-3.4	42.4	1.4	1.1	-4.4	43.2	-5.2	43.8	-5.9	44.4	-6.9	45.2		
(5)			-7.4	23.4	1.1	0.8	-8.2	24.0	-8.8	24.4	-9.5	24.9	-10.2	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.6	10.7	13.3	18.5	24.1	28.9	32.1	33.0	31.3	27.8	23.0	16.4	11.6
	DBStd	8.38	3.31	4.16	3.30	3.06	2.38	2.10	1.51	1.57	2.05	2.60	3.48	3.18
	HDD10.0	69	32	16	0	0	0	0	0	0	0	0	2	21
	HDD18.3	707	236	146	38	3	0	0	0	0	0	1	75	209
	CDD10.0	4672	54	108	265	423	586	663	713	660	533	402	194	70
	CDD18.3	2269	0	5	45	176	328	413	454	402	283	146	18	0
	CDH23.3	32902	3	69	513	2015	4674	6558	7184	6073	3858	1689	247	19
	CDH26.7	19593	0	8	137	901	2760	4302	4763	3818	2182	688	33	1
Wind	WSAvg	3.2	3.1	3.5	3.2	3.3	3.3	3.7	3.3	3.1	3.0	2.8	2.9	3.3
Precipitation	PrecAvg	109	18	18	20	8	6	7	6	5	1	5	5	10
	PrecMax	282	91	71	60	48	23	118	45	58	8	37	45	69
	PrecMin	14	0	0	0	0	2	0	0	0	0	0	0	0
	PrecStd	58	20	20	18	12	5	23	13	12	2	9	11	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	27.8	32.0	36.4	40.2	42.2	41.8	40.5	37.9	35.1	29.3	25.9
		MCWB	10.1	12.5	13.1	15.1	16.6	17.6	18.1	17.2	15.7	14.7	12.1	10.6
	2%	DB	21.7	25.6	29.8	34.5	38.5	40.9	40.7	39.2	36.9	33.6	27.6	23.1
		MCWB	10.0	11.8	12.9	14.6	16.2	17.1	17.8	16.5	15.3	14.5	12.1	9.8
	5%	DB	20.1	23.3	28.1	33.1	37.2	39.9	39.8	38.2	35.9	32.0	26.2	21.2
		MCWB	9.2	11.0	12.3	14.3	15.9	17.1	17.6	16.3	14.9	14.1	11.8	9.3
	10%	DB	18.4	21.2	26.2	31.5	36.1	38.6	38.8	37.3	34.8	30.4	24.6	19.5
		MCWB	8.5	10.0	11.6	13.9	15.6	16.6	17.3	16.0	14.5	13.4	11.4	8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	13.8	15.8	16.7	19.5	22.8	23.1	22.9	20.3	18.7	15.8	12.6
		MCDB	18.5	23.0	25.4	29.1	29.8	30.9	31.6	30.4	28.8	26.7	22.6	18.9
	2%	WB	11.6	13.0	14.7	16.0	18.1	21.7	22.5	22.0	18.9	17.1	14.8	11.5
		MCDB	18.1	21.0	24.4	28.7	31.0	30.1	31.0	29.1	28.3	27.1	21.9	18.9
	5%	WB	10.7	12.2	13.9	15.5	17.3	20.8	22.0	21.1	17.8	15.8	13.7	10.5
		MCDB	17.1	20.2	23.6	28.9	32.1	30.6	30.5	29.5	28.9	26.4	22.1	18.9
	10%	WB	9.9	11.3	13.0	14.8	16.7	19.7	21.4	19.9	16.4	14.8	12.6	9.5
		MCDB	16.5	19.2	22.1	28.8	32.5	31.6	30.7	30.3	27.5	22.2	18.2	15.2
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.8	12.8	12.5	12.7	12.4	12.1	12.5	14.0	14.0	13.7	14.3
		MCDBR	16.2	15.5	15.5	14.6	14.2	14.0	13.2	13.3	14.8	15.2	15.9	17.6
		MCWBR	8.3	7.0	5.7	5.3	4.8	4.7	4.6	4.8	5.5	6.3	7.3	8.9
	5% WB	MCDBR	11.9	11.7	12.2	12.4	13.2	12.6	12.3	12.3	14.1	13.2	12.2	14.5
	MCWBR	6.7	5.4	4.9	4.6	4.4	4.8	4.3	4.3	5.3	5.1	5.2	7.5	
Clear-Sky Solar Irradiance	taub	0.323	0.370	0.422	0.482	0.520	0.520	0.554	0.494	0.425	0.396	0.338	0.310	
	taud	2.398	2.234	2.047	1.917	1.834	1.838	1.785	1.903	2.048	2.127	2.338	2.427	
	Ebn at Noon	922	898	867	825	791	786	759	803	853	856	895	922	
	Edh at Noon	102	130	166	195	212	210	221	195	164	142	107	95	
All-Sky Solar Radiation	RadAvg	4.18	4.92	6.03	6.95	7.44	7.76	7.38	7.22	6.68	5.67	4.66	4.05	
	RadStd	0.26	0.33	0.30	0.32	0.23	0.31	0.26	0.24	0.15	0.13	0.13	0.21	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page