

KISH INTL, Iran, Islamic Republic ofWMO: **408820**Lat: **26.5316N**Lon: **53.9603E**Elev: **30**StdP: **100.97**Time Zone: **3.50 (IRN)**Period: **03-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.8	15.8	1.0	4.1	19.8	3.8	5.0	21.0	12.3	18.3	11.2	18.5	3.4	300	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	39.8	25.7	38.4	26.8	37.8	27.3	31.5	34.7	31.0	34.4	30.6	34.1	4.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.0	29.0	33.3	30.2	27.6	32.9	30.0	27.3	32.7	109.1	34.4	106.3	34.5	104.0	33.8	34.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.7	9.7	8.3	13.2	42.4	1.6	1.2	12.0	43.3	11.0	44.0	10.1	44.7	8.9	45.6	
			DB												
			WB	7.7	32.5	1.5	0.8	6.6	33.0	5.7	33.5	4.9	34.0	3.7	34.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	19.6	20.4	23.0	26.9	30.7	32.6	34.2	34.5	32.9	30.4	26.0	21.8
	DBStd	5.55	1.78	1.94	1.92	2.23	1.86	1.50	1.17	0.94	1.04	1.34	2.16	1.90
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	13	8	3	0	0	0	0	0	0	0	0	0	1
	CDD10.0	6487	297	292	402	506	642	677	749	758	688	633	479	364
	CDD18.3	3459	47	62	143	256	383	427	491	500	438	375	229	107
	CDH23.3	44939	55	147	680	2428	5156	6387	7866	8081	6744	5072	1985	338
CDH26.7	26436	1	12	120	926	2800	3993	5386	5601	4344	2647	582	23	
Wind	WSAvg	3.8	3.8	4.2	4.7	4.6	4.4	4.0	3.7	3.5	3.3	3.2	3.3	3.4
Precipitation	PrecAvg	199	46	32	36	8	2	2	4	3	2	3	19	42
	PrecMax	487	139	163	143	34	8	11	43	10	7	15	96	196
	PrecMin	68	7	1	0	0	0	0	0	0	0	0	0	1
	PrecStd	95	34	34	40	8	2	2	8	2	1	4	23	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	28.1	31.1	36.0	39.9	40.9	41.1	41.1	38.9	37.1	32.8	28.2
		MCWB	19.7	18.2	19.1	21.0	21.9	23.4	24.9	25.1	25.0	24.6	22.3	20.0
	2%	DB	24.8	26.2	29.2	34.1	37.8	38.9	39.2	39.1	37.8	35.4	31.8	27.1
		MCWB	18.7	18.8	19.6	20.8	22.5	25.6	26.9	27.4	26.7	25.7	22.4	19.7
	5%	DB	23.9	25.0	28.0	32.8	36.1	37.2	38.2	38.1	36.9	34.8	30.9	26.1
		MCWB	18.1	18.6	20.0	21.3	23.5	26.5	27.9	28.2	27.9	25.9	22.6	18.9
	10%	DB	23.0	24.0	26.8	31.1	35.0	36.2	37.2	37.2	36.0	33.9	29.9	25.1
		MCWB	17.3	18.0	19.8	21.6	24.0	26.8	28.4	28.8	28.5	26.0	22.3	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.7	23.4	25.9	28.9	30.8	31.7	32.2	32.5	30.8	25.8	23.2
		MCDB	24.0	24.4	27.3	29.8	32.6	35.1	35.5	35.3	34.9	33.0	30.0	26.3
	2%	WB	20.2	20.7	22.4	24.7	28.0	30.1	31.1	31.5	31.2	29.1	25.0	21.9
		MCDB	23.0	23.6	25.9	29.1	31.5	33.7	34.7	34.7	34.3	32.6	29.3	25.1
	5%	WB	19.4	20.1	21.7	23.9	27.3	29.6	30.7	31.1	30.5	28.3	24.3	20.9
		MCDB	22.4	22.9	25.0	28.5	31.0	33.2	34.2	34.4	33.9	31.8	28.5	24.3
	10%	WB	18.6	19.4	21.1	23.2	26.6	29.1	30.4	30.7	29.9	27.6	23.6	20.2
		MCDB	21.8	22.4	24.3	27.7	30.7	32.8	33.9	34.1	33.3	31.4	28.0	23.3
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.2	6.9	7.9	8.9	8.2	6.9	6.5	6.6	7.0	6.3	6.0
		MCDBR	6.5	7.2	8.5	9.9	10.5	9.4	8.3	7.6	7.6	7.8	6.9	6.8
		MCWBR	3.7	4.0	4.2	4.5	4.9	4.9	4.8	4.4	4.1	4.0	3.5	3.6
	5% WB	MCDBR	6.0	6.5	7.3	8.5	8.9	8.2	7.0	6.5	6.5	6.9	6.5	6.2
		MCWBR	4.1	4.1	4.1	4.5	4.5	4.2	3.9	3.6	3.7	3.8	3.4	3.8
Clear-Sky Solar Irradiance	taub	0.434	0.498	0.557	0.598	0.584	0.609	0.701	0.668	0.582	0.503	0.447	0.429	
	taud	2.138	1.957	1.813	1.757	1.781	1.766	1.640	1.713	1.841	1.991	2.139	2.158	
	Ebn at Noon	798	772	751	733	743	719	655	674	721	757	777	782	
	Edh at Noon	135	174	212	230	224	226	226	256	237	203	166	134	127
All-Sky Solar Radiation	RadAvg	4.01	4.85	5.87	6.86	7.85	8.06	7.60	7.08	6.52	5.59	4.34	3.77	
	RadStd	0.28	0.39	0.47	0.43	0.20	0.15	0.18	0.14	0.09	0.10	0.21	0.31	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)		+0.90	+1.31	N/A	+0.55	N/A	N/A	N/A	-5	+346

Nomenclature: See separate page