

BANDAR LENGEH INTL, Iran, Islamic Republic of

WMO: 408830

Lat: 26.5283N

Lon: 54.8286E

Elev: 75

StdP: 14.66

Time Zone: 3.50 (IRN)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 55.4	(c) 57.4	(d) 24.6	(e) 18.7	(f) 65.1	(g) 31.4	(h) 25.8	(i) 67.6	(j) 21.6	(k) 69.0	(l) 20.0	(m) 69.0	(n) 6.7	(o) 350	(p) 0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	103.4	79.4	101.6	80.8	100.2	81.9	88.8	95.5	87.9	95.2	87.2	94.8	10.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
87.4	200.1	93.2	86.2	192.3	93.2	85.6	188.2	93.2	54.6	96.2	53.4	94.7	52.5	94.6	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 21.1	(b) 18.8	(c) 16.9	(e) 51.5	(f) 108.9	(g) 2.5	(h) 2.6	(i) 49.7	(j) 110.7	(k) 48.3	(l) 112.2	(m) 46.9	(n) 113.7	(o) 45.1	(p) 115.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	66.0	67.9	73.1	80.6	87.4	91.3	94.8	94.6	91.4	85.8	76.6	69.5
	DBStd	10.75	3.38	4.02	3.71	4.51	3.58	3.14	1.99	1.62	2.10	2.61	3.98	3.17
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	46	29	13	0	0	0	0	0	0	0	0	0	4
	CDD50	11552	496	502	715	917	1161	1238	1388	1383	1243	1108	797	604
	CDD65	6122	60	95	250	467	696	788	923	918	793	643	347	142
	CDH74	84170	120	307	1436	4989	9922	12358	15237	15128	12478	8752	2887	556
	CDH80	50875	1	27	232	1958	5606	8043	10773	10664	8160	4548	828	35
(14) Wind	WSAvg	8.5	7.7	8.6	9.2	9.3	9.3	8.8	8.9	9.5	8.3	7.5	7.7	7.3
(15) Precipitation	PrecAvg	5.0	1.5	0.7	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.4	1.1
	PrecMax	15.3	6.8	6.5	5.9	0.7	0.1	0.1	1.1	1.2	0.1	0.2	2.0	7.2
	PrecMin	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.2	1.5	1.3	1.5	0.2	0.0	0.0	0.2	0.2	0.0	0.0	0.5	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	83.0	88.0	98.3	104.2	105.9	106.0	104.4	102.0	97.1	89.9	82.7
		MCWB	65.5	67.1	67.8	70.8	69.6	75.8	77.9	80.3	79.4	77.6	72.2	65.9
	2%	DB	76.9	80.0	84.5	93.4	99.0	102.2	102.6	102.3	100.1	95.1	88.1	80.7
		MCWB	65.4	66.3	68.8	70.3	73.2	78.1	81.5	82.5	80.6	78.7	72.7	66.2
	5%	DB	75.3	77.3	82.5	91.1	96.8	100.0	100.8	100.6	98.4	93.5	86.4	78.9
		MCWB	64.1	65.6	68.9	70.1	73.9	79.1	83.0	83.3	82.1	79.6	72.5	65.3
	10%	DB	73.6	75.4	80.5	88.2	94.8	97.7	100.0	99.0	96.8	92.8	84.6	77.1
		MCWB	62.8	65.1	68.2	71.2	74.8	80.2	83.5	84.1	83.0	79.5	71.9	64.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	71.7	75.3	79.9	86.3	88.2	90.0	90.2	88.5	86.1	78.5	73.8
		MCDB	75.6	77.7	82.2	85.9	90.8	93.4	95.9	95.3	95.9	92.3	85.7	77.6
	2%	WB	68.2	69.9	73.2	77.7	84.2	87.2	88.9	88.8	87.3	84.3	77.0	71.2
		MCDB	74.2	75.9	79.9	85.2	89.7	93.4	95.8	95.7	94.5	91.6	84.9	76.5
	5%	WB	66.8	68.4	72.0	76.2	82.7	86.1	87.9	87.9	86.6	83.1	75.6	69.2
		MCDB	72.9	74.9	78.6	84.6	88.8	93.2	95.5	95.4	94.0	90.7	83.8	75.0
	10%	WB	65.3	67.0	70.8	74.9	81.4	84.9	87.1	87.1	85.5	81.6	74.0	67.4
		MCDB	71.6	73.7	77.4	83.7	88.4	92.5	95.1	95.2	93.3	89.8	82.5	73.9
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	14.1	14.3	14.8	14.9	13.3	11.3	10.7	12.1	14.2	14.4	14.8
		MCDBR	15.1	14.9	16.0	17.2	17.7	16.4	12.7	12.2	13.3	14.5	14.8	15.9
		MCWBR	9.9	9.5	11.2	12.3	13.1	12.9	10.3	9.8	9.7	10.4	10.1	10.8
	5% WB	MCDBR	14.0	13.7	13.7	14.4	13.9	13.4	10.9	10.6	11.7	13.3	13.7	13.8
		MCWBR	10.0	9.6	10.4	12.3	10.8	11.0	9.1	8.6	8.2	10.6	9.6	10.5
(40) Clear-Sky Solar Irradiance	taub		0.427	0.492	0.549	0.584	0.577	0.616	0.705	0.668	0.585	0.503	0.439	0.420
	taud		2.149	1.963	1.820	1.773	1.789	1.744	1.625	1.695	1.822	1.976	2.145	2.176
	Ebn at Noon		255	247	240	236	237	226	207	214	228	240	249	252
	Edh at Noon		42	55	67	72	70	73	82	76	66	53	42	40
(44) All-Sky Solar Radiation	RadAvg		1272	1525	1847	2152	2460	2505	2374	2201	2031	1752	1376	1198
(45)	RadStd		79	118	138	120	56	46	56	47	27	27	55	86

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.86	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	+288	+270

Nomenclature: See separate page