

BANDAR LENGEH INTL, Iran, Islamic Republic of

WMO: 408830

Lat: 26.5283N

Lon: 54.8286E

Elev: 23

StdP: 101.05

Time Zone: 3.50 (IRN)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	14.1	-4.1	2.7	18.4	-0.3	3.7	19.8	9.6	20.5	8.9	20.6	3.0	350	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	39.7	26.3	38.7	27.1	37.9	27.7	31.5	35.3	31.1	35.1	30.7	34.9	4.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.8	28.6	34.0	30.1	27.5	34.0	29.8	26.9	34.0	109.2	35.6	106.4	34.8	104.1	34.8	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.4	7.5	DB	10.8	42.7	1.4	1.4	9.8	43.7	9.0	44.6	8.3	45.4	7.3	46.4	
			WB	4.3	32.6	1.6	0.8	3.2	33.2	2.3	33.7	1.4	34.1	0.3	34.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	18.9	20.0	22.8	27.0	30.8	32.9	34.9	34.8	33.0	29.9	24.8	20.8
	DBStd	5.97	1.88	2.23	2.06	2.51	1.99	1.74	1.11	0.90	1.17	1.45	2.21	1.76
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	26	16	7	0	0	0	0	0	0	0	0	0	2
	CDD10.0	6418	276	279	397	509	645	688	771	768	691	616	443	336
	CDD18.3	3401	33	53	139	259	387	438	513	510	441	357	193	79
	CDH23.3	46761	67	171	798	2772	5512	6866	8465	8404	6932	4862	1604	309
CDH26.7	28264	1	15	129	1088	3114	4468	5985	5924	4533	2527	460	19	
Wind	WSAvg	3.8	3.4	3.8	4.1	4.2	4.1	3.9	4.0	4.2	3.7	3.3	3.5	3.3
Precipitation	PrecAvg	128	39	19	24	4	1	0	1	1	0	1	9	27
	PrecMax	388	172	164	150	19	2	3	27	30	3	6	52	183
	PrecMin	31	1	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	82	39	33	38	5	0	1	5	6	1	1	13	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	28.3	31.1	36.8	40.1	41.1	41.1	40.2	38.9	36.1	32.2	28.2
		MCWB	18.6	19.5	19.9	21.6	20.9	24.3	25.5	26.8	26.3	25.4	22.3	18.8
	2%	DB	25.0	26.7	29.2	34.1	37.2	39.0	39.2	39.1	37.8	35.1	31.2	27.1
		MCWB	18.6	19.0	20.4	21.3	22.9	25.6	27.5	28.0	27.0	26.0	22.6	19.0
	5%	DB	24.0	25.2	28.0	32.8	36.0	37.8	38.2	38.1	36.9	34.2	30.2	26.0
		MCWB	17.8	18.7	20.5	21.2	23.3	26.2	28.3	28.5	27.8	26.4	22.5	18.5
	10%	DB	23.1	24.1	26.9	31.2	34.9	36.5	37.8	37.2	36.0	33.8	29.2	25.1
		MCWB	17.1	18.4	20.1	21.8	23.8	26.8	28.6	28.9	28.3	26.4	22.2	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	22.0	24.1	26.6	30.2	31.2	32.2	32.3	31.4	30.0	25.8	23.2
		MCDB	24.2	25.4	27.9	29.9	32.7	34.1	35.5	35.2	35.5	33.5	29.8	25.3
	2%	WB	20.1	21.0	22.9	25.4	29.0	30.7	31.6	31.5	30.7	29.1	25.0	21.8
		MCDB	23.5	24.4	26.6	29.6	32.1	34.1	35.4	35.4	34.7	33.1	29.4	24.7
	5%	WB	19.3	20.2	22.2	24.6	28.2	30.1	31.0	31.0	30.3	28.4	24.2	20.7
		MCDB	22.7	23.9	25.9	29.2	31.5	34.0	35.3	35.2	34.5	32.6	28.8	23.9
	10%	WB	18.5	19.5	21.6	23.8	27.5	29.4	30.6	30.6	29.7	27.6	23.3	19.7
		MCDB	22.0	23.2	25.2	28.7	31.3	33.6	35.0	35.1	34.1	32.1	28.0	23.3
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.8	8.0	8.2	8.3	7.4	6.3	6.0	6.7	7.9	8.0	8.2
		MCDBR	8.4	8.3	8.9	9.6	9.9	9.1	7.1	6.8	7.4	8.1	8.2	8.9
		MCWBR	5.5	5.3	6.2	6.8	7.3	7.2	5.7	5.5	5.4	5.8	5.6	6.0
	5% WB	MCDBR	7.8	7.6	7.6	8.0	7.7	7.5	6.1	5.9	6.5	7.4	7.6	7.7
		MCWBR	5.6	5.3	5.8	6.8	6.0	6.1	5.1	4.8	4.6	5.9	5.3	5.8
Clear-Sky Solar Irradiance	taub	0.427	0.492	0.549	0.584	0.577	0.616	0.705	0.668	0.585	0.503	0.439	0.420	
	taud	2.149	1.963	1.820	1.773	1.789	1.744	1.625	1.695	1.822	1.976	2.145	2.176	
	Ebn at Noon	805	778	757	744	748	714	652	674	718	756	785	793	
	Edh at Noon	133	173	210	226	222	231	260	241	207	168	133	125	
All-Sky Solar Radiation	RadAvg	4.01	4.81	5.82	6.78	7.76	7.90	7.49	6.94	6.40	5.52	4.34	3.78	
	RadStd	0.25	0.37	0.44	0.38	0.17	0.15	0.18	0.15	0.09	0.09	0.17	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.48	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	+160	+150

Nomenclature: See separate page