

JASK, Iran, Islamic Republic ofWMO: **408930**Lat: **25.6375N**Lon: **57.7696E**Elev: **16**StdP: **14.69**Time Zone: **3.50 (IRN)**Period: **05-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.4	62.2	28.0	21.9	65.3	35.3	30.2	67.5	26.7	68.7	24.2	70.2	7.4	0	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.5	98.9	82.7	97.0	82.5	95.3	82.5	89.0	93.6	88.1	92.8	87.2	91.9	12.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
88.0	203.4	92.7	86.8	195.9	91.9	86.1	191.1	91.3	55.0	93.5	53.7	93.3	52.5	92.0	95.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.8	22.3	20.2	55.9	104.2	2.8	2.9	53.8	106.2	52.2	108.0	50.6	109.6	48.5	111.7		
			43.1	91.2	4.0	2.3	40.2	92.9	37.8	94.3	35.6	95.6	32.7	97.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	69.2	71.0	75.4	81.4	87.3	90.0	90.0	89.0	87.6	84.8	78.2	72.3	
	DBStd	8.04	3.11	3.52	3.03	3.23	3.07	3.09	2.44	2.67	2.17	2.66	2.91	3.01	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	13	7	5	0	0	0	0	0	0	0	0	0	1	
	CDD50	11461	595	589	789	941	1156	1201	1240	1207	1127	1079	846	691	
	CDD65	5997	137	173	324	491	691	751	775	742	677	614	396	226	
	CDH74	73833	202	408	1811	5242	9729	11471	11846	11087	9766	7967	3433	871	
	CDH80	38210	0	14	213	1692	5307	7160	7382	6623	5446	3615	721	37	
Wind	WSAvg	10.4	9.5	10.8	10.7	10.4	9.9	11.7	13.1	12.4	10.4	8.8	8.4	8.7	
Precipitation	PrecAvg	4.2	1.2	0.5	1.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.8	
	PrecMax	21.3	6.6	2.5	12.4	1.5	0.0	0.0	0.2	0.3	0.0	0.4	4.1	7.3	
	PrecMin	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	PrecStd	4.3	1.4	0.6	2.4	0.3	0.0	0.0	0.0	0.1	0.0	0.1	0.8	1.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.8	82.1	86.4	93.4	99.0	103.9	100.8	100.8	98.3	95.3	88.1	82.6	
		MCWB	69.5	71.5	72.1	74.9	77.7	79.6	84.6	85.0	79.9	81.2	74.4	69.1	
	2%	DB	77.2	79.1	84.2	90.6	96.5	98.9	97.7	98.3	95.2	93.2	86.3	80.8	
		MCWB	67.8	70.0	72.8	75.0	78.1	81.7	85.0	84.9	82.0	80.1	74.8	68.7	
	5%	DB	75.7	77.4	82.3	88.6	94.8	96.8	95.2	95.3	93.3	91.3	85.1	79.2	
		MCWB	66.9	69.3	71.9	75.1	78.7	81.3	86.0	85.5	83.4	80.3	74.3	68.2	
	10%	DB	75.1	76.6	80.6	86.8	93.0	95.0	93.4	93.2	91.6	89.6	84.0	78.4	
		MCWB	66.6	68.8	71.5	75.2	78.9	81.7	86.5	85.8	83.3	79.6	73.6	67.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	74.8	77.5	81.8	87.5	89.4	90.8	90.0	88.2	85.9	80.1	75.5
			MCDB	75.7	78.4	81.5	85.3	90.6	94.1	95.2	95.2	92.8	91.4	84.7	79.0
2%		WB	71.0	73.0	76.0	80.5	85.9	88.1	89.3	88.6	86.8	84.4	78.8	73.1	
		MCDB	75.2	77.0	79.9	84.6	89.7	92.7	93.6	93.9	91.5	89.9	83.6	77.8	
5%		WB	69.8	71.8	74.8	79.2	84.6	87.2	88.3	87.3	85.8	83.1	77.5	71.7	
		MCDB	74.5	76.0	78.9	83.6	88.9	91.8	92.8	92.7	90.4	88.3	83.1	77.2	
10%		WB	68.6	70.4	73.7	78.1	83.5	86.3	87.4	86.5	84.9	82.1	76.3	70.1	
		MCDB	73.8	74.8	78.2	83.3	88.1	91.0	91.9	91.5	89.6	87.1	82.2	76.3	
Mean Daily Temperature Range	5% DB	MDBR	10.7	9.7	9.6	9.7	9.9	7.5	5.0	5.5	6.7	9.1	10.5	11.5	
		MCDBR	10.8	10.3	11.0	11.8	12.1	11.2	8.1	9.5	10.0	10.9	10.7	11.8	
		MCWBR	8.4	8.1	9.2	8.5	9.1	10.0	7.1	8.3	9.0	10.4	8.7	9.1	
	5% WB	MCDBR	9.0	8.3	9.1	9.2	9.0	7.9	6.4	7.3	7.3	9.2	9.1	10.3	
		MCWBR	7.6	7.4	8.3	8.1	7.9	7.2	5.7	6.2	6.4	8.2	7.8	8.6	
Clear-Sky Solar Irradiance	taub	0.423	0.480	0.535	0.565	0.575	0.648	0.727	0.677	0.585	0.502	0.439	0.419		
	taud	2.197	2.021	1.878	1.831	1.814	1.711	1.612	1.700	1.837	1.990	2.164	2.197		
	Ebn at Noon	259	252	245	241	238	220	203	212	229	242	251	254		
	Edh at Noon	41	52	63	68	69	76	83	76	65	53	42	39		
All-Sky Solar Radiation	RadAvg	1335	1604	1932	2250	2462	2460	2281	2205	2047	1796	1459	1285		
	RadStd	88	108	122	98	43	83	76	73	43	33	41	61		