

JASK, Iran, Islamic Republic ofWMO: **408930**Lat: **25.6375N**Lon: **57.7696E**Elev: **5**StdP: **101.26**Time Zone: **3.50 (IRN)**Period: **05-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.2	16.8	-2.2	3.1	18.5	1.8	4.3	19.7	11.9	20.4	10.8	21.2	3.3	0	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	4.2	37.2	28.2	36.1	28.0	35.2	28.1	31.7	34.2	31.2	33.8	30.7	33.3	5.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
31.1	29.1	33.7	30.5	28.0	33.3	30.1	27.3	32.9	110.2	34.1	106.9	34.0	104.3	33.3	35.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	10.0	9.0	13.3	40.1	1.6	1.6	12.1	41.2	11.2	42.2	10.3	43.1	9.2	44.3		
(5)			6.2	32.9	2.2	1.3	4.6	33.8	3.2	34.6	2.0	35.3	0.4	36.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	20.7	21.7	24.1	27.4	30.7	32.2	31.6	30.9	29.3	25.7	22.4	(6)	
(7)		DBStd	4.47	1.73	1.96	1.68	1.80	1.70	1.71	1.35	1.48	1.21	1.48	1.62	1.67	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	7	4	3	0	0	0	0	0	0	0	0	0	1	(9)
(10)		CDD10.0	6367	331	327	438	523	642	667	689	671	626	599	470	384	(10)
(11)		CDD18.3	3332	76	96	180	273	384	417	431	412	376	341	220	126	(11)
(12)		CDH23.3	41018	112	227	1006	2912	5405	6373	6581	6159	5426	4426	1907	484	(12)
(13)		CDH26.7	21228	0	8	118	940	2948	3978	4101	3679	3026	2008	401	21	(13)
(14)	Wind	WSAvg	4.7	4.2	4.8	4.8	4.7	4.4	5.3	5.8	5.6	4.7	3.9	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	106	30	12	28	4	0	0	1	0	0	10	20	(15)	
(16)		PrecMax	540	168	64	314	38	0	0	5	8	0	9	103	186	(16)
(17)		PrecMin	17	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	109	36	16	61	8	0	0	1	2	0	2	21	42	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.8	30.2	34.1	37.2	40.0	38.2	36.8	35.2	31.2	28.1	(19)	
(20)			MCWB	20.8	21.9	22.3	23.8	25.4	26.5	29.2	29.4	26.6	27.4	23.5	20.6	(20)
(21)		2%	DB	25.1	26.2	29.0	32.6	35.9	37.2	36.5	36.8	35.1	34.0	30.1	27.1	(21)
(22)			MCWB	19.9	21.1	22.7	23.9	25.6	27.6	29.4	29.4	27.8	26.7	23.8	20.4	(22)
(23)		5%	DB	24.3	25.2	28.0	31.5	34.9	36.0	35.1	35.1	34.1	33.0	29.5	26.2	(23)
(24)			MCWB	19.4	20.7	22.2	24.0	26.0	27.4	30.0	29.7	28.5	26.8	23.5	20.1	(24)
(25)		10%	DB	24.0	24.8	27.0	30.4	33.9	35.0	34.1	34.0	33.1	32.0	28.9	25.8	(25)
(26)			MCWB	19.2	20.4	22.0	24.0	26.1	27.6	30.3	29.9	28.5	26.4	23.1	20.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	23.8	25.3	27.7	30.8	31.9	32.6	31.2	29.9	26.7	24.1	(27)	
(28)			MCDWB	24.3	25.8	27.5	29.6	32.5	34.5	35.1	35.1	33.8	33.0	29.3	26.1	(28)
(29)		2%	WB	21.7	22.8	24.4	26.9	29.9	31.2	31.8	31.4	30.5	29.1	26.0	22.8	(29)
(30)			MCDWB	24.0	25.0	26.6	29.2	32.0	33.7	34.2	34.4	33.1	32.2	28.7	25.4	(30)
(31)		5%	WB	21.0	22.1	23.8	26.2	29.2	30.7	31.3	30.7	29.9	28.4	25.3	22.0	(31)
(32)			MCDWB	23.6	24.5	26.1	28.7	31.6	33.2	33.8	33.7	32.5	31.3	28.4	25.1	(32)
(33)		10%	WB	20.4	21.3	23.2	25.6	28.6	30.2	30.8	30.3	29.4	27.8	24.6	21.2	(33)
(34)			MCDWB	23.2	23.8	25.7	28.5	31.2	32.8	33.3	33.1	32.0	30.6	27.9	24.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	5.4	5.3	5.4	5.5	4.2	2.8	3.1	3.7	5.0	5.8	6.4	(35)
(36)			MCDBR	6.0	5.7	6.1	6.5	6.7	6.2	4.5	5.3	5.6	6.1	5.9	6.6	(36)
(37)			MCWBR	4.6	4.5	5.1	4.7	5.0	5.6	3.9	4.6	5.0	5.8	4.9	5.0	(37)
(38)		5% WB	MCDWB	5.0	4.6	5.0	5.1	5.0	4.4	3.5	4.1	4.1	5.1	5.0	5.7	(38)
(39)			MCWBR	4.2	4.1	4.6	4.5	4.4	4.0	3.2	3.5	3.6	4.6	4.3	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.423	0.480	0.535	0.565	0.575	0.648	0.727	0.677	0.585	0.502	0.439	0.419	(40)	
(41)		taud	2.197	2.021	1.878	1.831	1.814	1.711	1.612	1.700	1.837	1.990	2.164	2.197	(41)	
(42)		Ebn at Noon	817	793	772	760	749	692	639	669	721	762	792	801	(42)	
(43)		Edh at Noon	128	164	199	214	217	239	263	241	205	167	132	124	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.21	5.06	6.09	7.09	7.76	7.76	7.19	6.95	6.45	5.66	4.60	4.05	(44)	
(45)		RadStd	0.28	0.34	0.39	0.31	0.14	0.26	0.24	0.23	0.14	0.10	0.13	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.26	+0.58	-1.15	N/A	-0.31	-0.27	N/A	N/A	N/A	N/A

Nomenclature: See separate page