

CHABAHAR, Iran, Islamic Republic of

WMO: 408980

Lat: 25.2807N

Lon: 60.6509E

Elev: 26

StdP: 14.68

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 52.0	(c) 55.4	(d) 11.0	(e) 9.6	(f) 67.0	(g) 20.4	(h) 15.3	(i) 68.5	(j) 24.5	(k) 74.7	(l) 21.2	(m) 73.8	(n) 2.0	(o) 50	(p) 0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.9	102.3	77.5	98.9	77.1	96.5	78.0	87.3	91.1	86.2	90.5	85.3	89.9	12.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
86.4	193.4	90.4	85.2	185.7	89.6	84.1	179.1	88.9	52.8	91.3	51.2	90.7	50.0	90.0	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 21.4	(b) 18.4	(c) 16.2	(d) DB	(e) 48.1	(f) 109.2	(g) 5.1	(h) 7.4	(i) 44.5	(j) 114.5	(k) 41.5	(l) 118.8	(m) 38.6	(n) 123.0	(o) 34.8	(p) 128.4	(q) 94.9
(a) 21.4	(b) 18.4	(c) 16.2	(d) WB	(e) 37.3	(f) 89.1	(g) 4.9	(h) 2.2	(i) 33.7	(j) 90.7	(k) 30.8	(l) 92.1	(m) 28.1	(n) 93.3	(o) 24.5	(p) 94.9	(q) 94.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.1	67.5	69.7	75.3	81.7	88.1	90.4	87.8	85.8	84.9	82.7	76.4	70.4
	DBStd	8.26	3.96	4.20	3.53	3.51	3.55	2.82	2.50	2.40	2.64	2.81	3.22	3.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	41	21	12	0	0	0	0	0	0	0	0	0	8
	CDD50	10988	543	550	783	952	1180	1211	1173	1109	1046	1015	792	634
	CDD65	5553	99	142	318	502	715	761	708	644	596	550	342	176
	CDH74	66168	361	600	2231	5557	10127	11210	9731	8268	7436	6566	3034	1047
(13) CDH80		31643	5	77	548	2218	5822	6899	5268	3824	3210	2786	863	123
(14) Wind	WSAvg	6.8	5.6	6.9	7.0	7.3	7.2	7.3	9.1	8.2	6.7	5.7	5.2	5.0
(15) Precipitation	PrecAvg	4.4	1.2	0.4	0.8	0.1	0.0	0.2	0.1	0.0	0.0	0.3	0.4	0.8
	PrecMax	18.8	6.3	4.4	4.4	0.9	0.0	6.1	1.5	0.5	0.1	5.7	3.7	4.6
	PrecMin	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	1.4	0.9	0.9	0.2	0.0	1.2	0.3	0.1	0.0	1.1	0.8	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.6	86.2	93.2	100.0	110.9	109.1	100.5	97.8	98.7	99.3	93.3	86.4
		MCWB	59.6	65.7	66.9	69.2	74.3	76.0	81.2	80.9	77.0	69.0	65.6	62.7
	2%	DB	78.7	82.2	88.7	95.4	103.6	102.2	96.5	93.6	94.9	95.0	89.5	82.8
		MCWB	64.7	65.0	67.5	70.2	75.6	80.9	82.0	81.1	78.3	71.4	68.1	62.6
	5%	DB	77.3	79.1	85.7	92.6	99.1	98.3	93.5	91.5	91.8	91.7	86.4	80.9
		MCWB	64.8	66.4	68.0	71.0	76.0	81.3	82.4	80.9	78.9	74.3	68.5	63.8
	10%	DB	76.1	77.2	82.4	89.5	95.9	95.2	91.4	89.5	89.3	89.0	84.4	79.2
		MCWB	64.5	66.6	69.6	72.7	76.6	82.5	82.5	81.1	79.5	77.3	69.7	64.6
	0.4%	WB	72.0	74.0	77.5	82.4	87.6	89.4	89.1	86.8	84.4	84.4	79.6	73.3
		MCDB	77.0	77.5	81.8	87.1	91.7	93.7	91.5	89.3	88.2	87.6	83.5	78.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	70.2	72.7	75.5	80.8	85.9	87.8	86.5	85.0	83.3	83.2	77.4	71.7
		MCDB	76.0	76.5	79.8	85.3	90.1	91.7	90.0	88.5	87.3	86.8	82.6	77.4
	5%	WB	69.0	71.5	74.4	79.4	84.4	86.7	85.1	83.5	82.4	82.2	76.1	70.0
		MCDB	75.1	75.9	79.0	84.6	89.0	91.2	89.2	87.9	87.1	86.2	81.9	76.3
	10%	WB	67.5	69.8	73.4	78.1	83.3	85.8	84.1	82.5	81.5	81.0	74.8	68.4
		MCDB	73.9	74.9	78.3	83.9	88.4	90.7	88.8	87.2	86.5	85.3	81.1	75.9
(35) Mean Daily Temperature Range	5% DB	MDBR	16.7	15.6	14.8	15.4	16.0	10.9	7.8	7.8	9.6	14.7	17.3	18.1
		MCDBR	17.6	18.4	22.1	23.1	24.2	19.0	12.2	11.5	15.9	21.9	21.6	21.1
		MCWBR	10.6	10.5	11.0	11.2	11.5	9.2	4.7	4.7	6.8	10.3	11.5	11.6
	5% WB	MCDBR	12.1	13.2	13.0	13.1	14.1	10.8	8.0	8.6	11.4	10.7	14.7	14.3
		MCWBR	8.2	8.7	8.4	9.0	8.7	6.8	4.5	4.6	5.8	7.3	9.1	9.4
(40) Clear-Sky Solar Irradiance	taub		0.410	0.460	0.516	0.561	0.603	0.682	0.752	0.687	0.595	0.508	0.434	0.413
	taud		2.213	2.060	1.904	1.827	1.762	1.646	1.562	1.664	1.801	1.957	2.151	2.190
	Ebn at Noon		264	259	250	242	231	212	198	210	226	240	253	257
	Edh at Noon		40	50	62	68	73	81	88	79	68	55	43	40
(44) All-Sky Solar Radiation	RadAvg		1384	1649	1991	2289	2449	2402	2189	2090	2030	1807	1498	1317
(45) RadStd			66	77	84	81	35	84	113	96	57	36	37	57

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page