

CHABAHAH, Iran, Islamic Republic of

WMO: 408980

Lat: 25.2807N

Lon: 60.6509E

Elev: 8

StdP: 101.23

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	13.0	-11.7	1.4	19.5	-6.4	2.2	20.3	10.9	23.7	9.5	23.2	0.9	50	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.1	39.1	25.3	37.1	25.1	35.8	25.6	30.7	32.9	30.1	32.5	29.6	32.1	5.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
30.2	27.6	32.4	29.6	26.5	32.0	29.0	25.6	31.6	105.0	33.0	101.3	32.6	98.5	32.2	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.6	8.2	7.2	9.0	42.9	2.8	4.1	6.9	45.8	5.3	48.2	3.7	50.6	1.6	53.5		
			2.9	31.7	2.7	1.2	1.0	32.6	-0.6	33.4	-2.2	34.1	-4.2	35.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	19.7	20.9	24.0	27.6	31.2	32.4	31.0	29.9	29.4	28.2	24.7	21.4
	DBStd	4.59	2.20	2.33	1.96	1.95	1.97	1.57	1.39	1.33	1.47	1.56	1.79	2.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	23	12	7	0	0	0	0	0	0	0	0	0	4
	CDD10.0	6104	302	306	435	529	656	673	652	616	581	564	440	352
	CDD18.3	3085	55	79	177	279	397	423	393	358	331	306	190	98
	CDH23.3	36760	201	333	1239	3087	5626	6228	5406	4593	4131	3648	1686	582
	CDH26.7	17579	3	43	304	1232	3234	3833	2927	2124	1783	1548	479	68
Wind	WSAvg	3.0	2.5	3.1	3.1	3.3	3.2	3.3	4.1	3.7	3.0	2.5	2.3	2.3
Precipitation	PrecAvg	112	30	10	20	2	0	6	2	1	0	7	11	20
	PrecMax	478	161	111	112	22	0	154	39	13	3	146	95	117
	PrecMin	10	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	95	35	23	24	5	0	30	8	3	0	27	21	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	30.1	34.0	37.8	43.8	42.8	38.1	36.6	37.0	37.4	34.1	30.2
		MCWB	15.3	18.7	19.4	20.7	23.5	24.4	27.3	27.2	25.0	20.6	18.7	17.1
	2%	DB	25.9	27.9	31.5	35.2	39.8	39.0	35.8	34.2	35.0	35.0	31.9	28.2
		MCWB	18.2	18.3	19.7	21.2	24.2	27.2	27.8	27.3	25.7	21.9	20.0	17.0
	5%	DB	25.1	26.2	29.8	33.7	37.3	36.8	34.2	33.0	33.2	33.1	30.2	27.1
		MCWB	18.2	19.1	20.0	21.7	24.4	27.4	28.0	27.2	26.0	23.5	20.3	17.7
	10%	DB	24.5	25.1	28.0	31.9	35.5	35.1	33.0	31.9	31.9	31.7	29.1	26.2
		MCWB	18.1	19.2	20.9	22.6	24.8	28.0	28.1	27.3	26.4	25.1	21.0	18.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	23.3	25.3	28.0	30.9	31.9	31.7	30.5	29.1	29.1	26.4	23.0
		MCDB	25.0	25.3	27.7	30.6	33.2	34.3	33.1	31.8	31.2	30.9	28.6	25.6
	2%	WB	21.2	22.6	24.2	27.1	30.0	31.0	30.3	29.5	28.5	28.4	25.2	22.1
		MCDB	24.4	24.7	26.5	29.6	32.3	33.2	32.2	31.4	30.7	30.4	28.1	25.2
	5%	WB	20.6	21.9	23.6	26.3	29.1	30.4	29.5	28.6	28.0	27.9	24.5	21.1
		MCDB	24.0	24.4	26.1	29.2	31.7	32.9	31.8	31.1	30.6	30.1	27.7	24.6
	10%	WB	19.7	21.0	23.0	25.6	28.5	29.9	28.9	28.1	27.5	27.2	23.8	20.2
		MCDB	23.3	23.8	25.7	28.8	31.3	32.6	31.5	30.7	30.3	29.6	27.3	24.4
Mean Daily Temperature Range	5% DB	MDBR	9.3	8.6	8.2	8.5	8.9	6.1	4.3	4.3	5.4	8.1	9.6	10.0
		MCDBR	9.8	10.2	12.3	12.8	13.5	10.6	6.8	6.4	8.8	12.2	12.0	11.7
		MCWBR	5.9	5.8	6.1	6.2	6.4	5.1	2.6	2.6	3.8	5.7	6.4	6.5
	5% WB	MCDBR	6.7	7.3	7.2	7.3	7.9	6.0	4.4	4.8	6.4	5.9	8.2	8.0
		MCWBR	4.5	4.8	4.7	5.0	4.8	3.8	2.5	2.6	3.2	4.0	5.1	5.2
Clear-Sky Solar Irradiance	taub	0.410	0.460	0.516	0.561	0.603	0.682	0.752	0.687	0.595	0.508	0.434	0.413	
	taud	2.213	2.060	1.904	1.827	1.762	1.646	1.562	1.664	1.801	1.957	2.151	2.190	
	Ebn at Noon	832	815	788	763	729	669	623	663	714	757	799	809	
	Edh at Noon	127	158	194	215	229	255	277	250	213	173	134	125	
All-Sky Solar Radiation	RadAvg	4.36	5.20	6.28	7.21	7.72	7.57	6.90	6.59	6.40	5.70	4.72	4.15	
	RadStd	0.21	0.24	0.27	0.25	0.11	0.26	0.36	0.30	0.18	0.12	0.12	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page