

MAZAR-I-SHARIF INTL, Afghanistan

WMO: 409110

Lat: 36.7055N

Lon: 67.2185E

Elev: 1284

StdP: 14.03

Time Zone: 4.50 (AFG)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	26.5	10.2	9.7	39.2	14.2	11.8	50.1	26.7	47.1	24.2	46.3	5.8	80	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	107.3	65.7	105.4	65.1	102.6	64.2	67.2	100.4	66.2	98.2	65.5	96.8	10.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.8	80.6	69.1	57.6	74.2	69.0	55.8	69.4	69.3	32.2	98.5	31.5	97.9	30.9	97.0	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	22.0	19.4	17.4	111.0	9.9	1.0	10.3	111.8	4.4	112.4	-1.1	112.9	-8.4	113.7
			16.8	69.3	9.2	1.2	10.2	70.1	4.8	70.8	-0.3	71.5	-7.0	72.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	42.7	44.3	56.3	66.9	80.1	89.1	93.8	89.8	80.6	66.6	51.8	43.6	(6)
	DBStd	19.72	6.49	9.84	8.30	7.89	5.51	4.78	4.06	4.91	5.61	7.93	8.69	7.61	(7)
	HDD50	768	237	197	38	2	0	0	0	0	0	2	72	220	(8)
	HDD65	2777	692	581	285	73	0	0	0	0	1	79	403	663	(9)
	CDD50	7072	11	36	234	509	932	1174	1358	1234	919	516	127	22	(10)
	CDD65	3602	0	0	16	129	467	724	893	769	470	127	7	0	(11)
	CDH74	54343	0	4	184	1206	6142	11763	15424	12417	6007	1124	72	0	(12)
	CDH80	33887	0	0	31	399	3205	7720	10987	8137	3036	355	17	0	(13)
(14) Wind	WSAvg	8.0	6.8	7.8	8.6	8.1	8.1	9.1	10.4	9.4	7.7	6.8	6.2	6.5	(14)
(15) Precipitation	PrecAvg	7.0	1.3	1.4	1.9	0.9	0.4	0.0	0.0	0.0	0.0	0.2	0.4	0.9	(15)
	PrecMax	9.5	2.6	3.2	5.6	2.2	1.6	0.1	0.0	0.0	0.3	1.0	2.2	4.2	(16)
	PrecMin	5.2	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
	PrecStd	1.1	0.7	0.7	1.1	0.6	0.4	0.0	0.0	0.0	0.1	0.3	0.5	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	73.1	84.2	93.5	102.4	107.8	109.8	107.6	101.8	93.0	82.5	66.5	(19)
		MCWB	48.4	54.8	59.1	60.7	63.4	64.7	66.5	66.7	63.2	58.2	55.8	50.1	(20)
	2%	DB	59.4	64.7	79.0	88.1	98.9	105.7	107.9	105.4	98.6	87.8	73.8	62.5	(21)
		MCWB	47.9	52.2	57.9	61.3	63.1	64.5	65.9	65.3	62.1	58.4	52.8	47.6	(22)
	5%	DB	56.9	61.0	75.1	84.3	96.5	103.6	106.0	102.6	95.4	84.1	69.4	58.9	(23)
		MCWB	46.5	50.7	57.0	60.1	62.5	64.0	65.4	64.2	61.2	57.3	52.1	47.7	(24)
	10%	DB	53.6	57.4	70.2	80.8	93.2	100.6	104.0	100.6	93.0	80.5	64.7	55.2	(25)
		MCWB	45.8	49.3	55.9	60.1	62.0	63.1	64.9	63.4	60.5	56.2	50.5	46.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	56.9	62.3	66.8	67.0	67.0	69.0	68.0	65.2	61.9	58.9	54.6	(27)
		MCDB	59.0	64.7	76.4	80.0	85.1	101.0	103.4	104.0	96.1	83.9	72.9	61.0	(28)
	2%	WB	50.0	54.3	60.2	65.0	65.7	66.0	67.5	66.4	63.6	60.1	56.6	50.8	(29)
		MCDB	55.7	62.2	72.8	78.4	86.7	99.6	104.3	101.1	94.2	81.2	67.8	58.4	(30)
	5%	WB	48.5	52.0	58.4	63.5	64.9	65.3	66.4	65.4	62.2	58.7	54.1	48.8	(31)
		MCDB	54.8	59.6	71.1	76.9	85.9	98.0	103.0	100.0	92.8	79.2	65.0	55.0	(32)
	10%	WB	46.4	49.9	56.9	62.1	63.9	64.4	65.5	64.2	61.0	57.3	51.8	47.0	(33)
		MCDB	52.5	56.6	68.8	75.5	85.2	96.1	101.7	98.8	90.8	77.7	63.2	53.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	15.1	17.9	18.6	21.4	19.7	17.9	17.8	20.0	19.3	16.8	15.1	(35)
		MCDBR	19.2	21.0	25.1	24.3	25.4	22.9	20.4	20.2	24.0	23.9	24.0	21.4	(36)
	5% WB	MCWBR	11.1	10.8	9.7	8.5	8.6	8.1	7.9	8.0	10.1	10.4	11.6	11.9	(37)
		MCWBR	16.4	17.5	22.1	19.9	21.4	19.9	18.0	18.1	21.5	20.3	20.0	17.5	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.379	0.434	0.490	0.507	0.506	0.509	0.494	0.469	0.440	0.465	0.439	0.386	(40)
		taud	2.112	1.968	1.858	1.861	1.882	1.864	1.896	1.958	1.993	1.899	1.954	2.086	(41)
	Ebn at Noon	Ebn at Noon	247	246	244	249	251	250	252	256	256	231	220	233	(42)
		Edh at Noon	38	49	60	63	63	64	62	57	52	52	44	36	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	722	965	1395	1804	2255	2537	2490	2275	1931	1391	890	669	(44)
	RadStd	RadStd	68	111	108	163	119	68	55	68	39	81	86	74	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	-0.97	-1.62	N/A	N/A	N/A	N/A

Nomenclature: See separate page