

FUJAIRAH INTL, United Arab Emirates

WMO: 411980

Lat: 25.112N

Lon: 56.324E

Elev: 46

StdP: 100.77

Time Zone: 4.00 (E04)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.8	16.8	-2.0	3.2	30.6	0.8	4.0	30.5	12.5	22.1	11.0	21.8	3.7	300	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.9	42.9	21.9	41.0	22.5	39.2	23.1	31.7	34.4	31.2	34.2	30.7	34.1	6.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.2	29.3	33.4	30.8	28.6	33.3	30.0	27.3	33.4	110.1	34.5	107.4	33.7	104.0	33.9	34.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.2	9.4	8.0	13.3	46.5	1.4	1.5	12.3	47.6	11.4	48.5	10.6	49.4	9.6	50.5
			8.0	32.3	1.3	1.0	7.0	33.0	6.3	33.6	5.5	34.1	4.6	34.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	21.0	22.0	24.7	29.5	34.0	35.2	34.4	33.4	32.4	30.5	26.3	22.7	(6)
(7)		DBStd	5.44	1.79	1.99	2.32	2.90	2.68	2.24	1.86	1.81	1.38	1.77	1.97	1.89	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	4	2	1	0	0	0	0	0	0	0	0	0	1	(9)
(10)		CDD10.0	6894	341	337	457	584	743	755	758	727	673	637	488	395	(10)
(11)		CDD18.3	3856	84	105	199	334	485	505	499	468	423	378	238	137	(11)
(12)		CDH23.3	52676	224	411	1494	4353	7803	8354	8064	7323	6360	5347	2278	664	(12)
(13)		CDH26.7	32105	14	53	400	2251	5331	5954	5584	4843	3960	2934	704	76	(13)
(14)	Wind	WSAvg	3.2	3.5	3.6	3.7	3.9	4.1	3.3	3.0	2.7	2.5	2.5	2.9	3.2	(14)
(15)	Precipitation	PrecAvg	121	18	23	28	8	2	1	4	1	2	6	8	17	(15)
(16)		PrecMax	447	96	82	148	48	19	6	61	3	8	57	60	246	(16)
(17)		PrecMin	39	0	5	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	95	24	15	38	11	4	1	11	1	2	11	13	48	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.4	30.2	35.2	40.0	44.2	45.9	44.0	42.3	40.2	38.2	33.9	30.0	(19)
(20)			MCWB	17.8	17.7	19.2	19.9	21.3	22.0	22.9	23.6	23.4	21.5	20.6	18.6	(20)
(21)		2%	DB	26.2	28.1	32.0	37.8	42.1	42.9	41.0	39.9	37.8	36.2	32.0	28.2	(21)
(22)			MCWB	18.5	18.5	18.2	19.8	21.0	22.2	24.4	24.6	24.6	23.0	22.1	19.4	(22)
(23)		5%	DB	25.2	26.8	30.1	36.0	40.2	40.9	38.9	37.9	36.2	35.0	31.0	27.2	(23)
(24)			MCWB	18.4	19.0	18.8	20.3	20.7	22.9	25.5	26.9	25.7	23.6	22.5	19.7	(24)
(25)		10%	DB	24.4	25.7	28.8	34.2	38.2	39.1	37.2	36.2	35.1	34.0	30.0	26.2	(25)
(26)			MCWB	18.1	19.1	19.3	20.6	21.2	23.6	27.6	28.4	26.8	24.5	22.6	19.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.5	23.6	25.7	27.5	30.6	32.4	32.7	32.1	32.0	29.4	26.2	23.7	(27)
(28)			MCD B	24.3	25.5	27.6	30.4	33.3	35.0	35.1	34.4	34.0	32.5	29.8	26.2	(28)
(29)		2%	WB	21.2	22.5	24.5	26.3	29.4	31.3	31.8	31.2	30.7	28.5	25.4	22.4	(29)
(30)			MCD B	24.3	25.1	27.0	30.3	33.5	34.6	34.4	34.3	33.3	32.2	29.7	25.9	(30)
(31)		5%	WB	20.4	21.7	23.4	25.4	28.6	30.6	31.3	30.7	29.9	27.7	24.4	21.6	(31)
(32)			MCD B	23.9	24.7	26.4	30.0	33.2	34.4	34.3	34.1	33.0	31.9	29.2	25.4	(32)
(33)		10%	WB	19.5	20.9	22.5	24.6	27.9	29.9	30.8	30.3	29.2	27.0	23.6	20.8	(33)
(34)			MCD B	23.4	24.2	25.9	29.7	32.6	34.2	34.1	33.9	32.7	31.6	28.6	24.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.9	7.3	8.0	8.2	6.9	5.0	5.0	5.7	6.7	6.8	7.0	(35)
(36)			MCDBR	7.4	8.2	9.2	10.0	10.4	10.3	8.3	8.0	7.9	8.2	7.4	7.5	(36)
(37)			MCWBR	4.6	5.6	6.7	7.3	8.2	9.0	7.8	7.0	6.8	7.8	5.5	4.6	(37)
(38)		5% WB	MCD BR	6.5	6.4	6.8	7.9	7.5	6.8	5.2	5.4	5.7	5.9	6.2	6.6	(38)
(39)			MCWBR	4.9	5.6	6.6	7.7	8.2	7.3	4.8	4.6	4.9	6.3	5.2	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.443	0.504	0.563	0.599	0.599	0.662	0.745	0.703	0.609	0.519	0.461	0.444	(40)	
(41)		taud	2.130	1.952	1.807	1.751	1.749	1.657	1.561	1.631	1.772	1.945	2.101	2.121	(41)	
(42)		Ebn at Noon	797	773	750	734	732	683	627	652	704	748	771	776	(42)	
(43)		Edh at Noon	138	177	215	232	232	252	277	258	219	175	141	135	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.10	4.86	5.77	6.60	7.36	7.44	6.87	6.56	6.14	5.42	4.41	3.88	(44)	
(45)		RadStd	0.28	0.36	0.40	0.43	0.19	0.20	0.20	0.21	0.20	0.11	0.12	0.12	0.24	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.47	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	+150	+149

Nomenclature: See separate page