

DIBBA, Oman

WMO: 412420

Lat: 25.6157N

Lon: 56.2473E

Elev: 10

StdP: 101.20

Time Zone: 4.00 (E04)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	14.2	0.6	3.9	28.1	3.0	4.7	28.2	9.8	20.9	8.4	22.2	0.9	220	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.6	41.9	23.2	40.2	23.6	38.8	24.2	31.8	35.0	31.2	34.3	30.7	34.0	4.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
31.1	29.1	34.0	30.6	28.2	33.7	30.0	27.2	33.4	110.7	35.1	107.4	34.4	104.6	33.9	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.5	6.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	7.6	31.3	1.7	1.3	6.3	32.2	5.4	33.0	4.4	33.7	3.2	34.7	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	20.0	21.0	24.0	28.3	33.1	34.5	34.3	33.3	32.0	29.5	25.0	21.6
	DBStd	5.64	1.83	2.21	2.17	2.57	2.47	1.98	1.52	1.53	1.32	1.87	2.00	2.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	12	6	4	0	0	0	0	0	0	0	0	0	1
	CDD10.0	6598	310	308	433	549	716	735	754	722	659	604	449	358
	CDD18.3	3568	58	79	174	299	458	485	496	464	409	346	199	102
	CDH23.3	49201	163	337	1394	3749	7298	7975	8029	7225	6077	4619	1804	529
	CDH26.7	29769	3	39	363	1855	4851	5575	5549	4745	3693	2466	582	47
(14) Wind	WSAvg	2.4	2.4	2.7	3.0	3.0	3.0	2.7	2.4	2.4	2.0	1.8	1.8	2.0
(15) Precipitation	PrecAvg	131	25	25	33	6	1	1	3	0	1	4	7	23
	PrecMax	316	98	120	151	29	3	5	37	2	12	48	60	167
	PrecMin	34	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	86	29	26	36	9	1	1	7	0	2	10	14	39
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	30.0	33.3	38.7	43.7	45.1	43.6	42.2	40.1	38.0	32.7	29.1
		MCWB	18.8	18.6	19.3	20.6	22.0	24.2	24.0	23.8	22.3	22.3	22.0	19.3
	2%	DB	25.9	27.7	31.0	36.1	40.7	41.9	40.5	39.7	37.9	36.0	31.5	27.9
		MCWB	19.1	18.6	18.9	20.5	20.8	23.0	25.3	25.7	24.1	23.6	22.7	20.1
	5%	DB	25.1	26.3	29.7	34.7	39.2	40.1	38.4	37.7	36.5	34.8	30.7	27.0
		MCWB	18.3	19.2	19.3	20.2	21.3	24.5	26.9	27.0	25.5	24.6	22.7	20.5
	10%	DB	24.2	25.3	28.7	33.3	37.8	38.5	37.1	36.3	35.2	33.9	29.9	26.1
		MCWB	17.6	18.9	19.8	20.4	21.8	25.3	28.3	28.4	26.9	25.1	22.4	19.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	22.8	25.4	26.9	30.6	32.4	32.7	31.9	31.0	29.6	25.9	23.9
		MCDB	25.1	25.4	27.6	31.4	34.1	35.7	35.9	35.3	33.9	33.1	29.9	26.8
	2%	WB	20.8	21.9	24.4	25.7	29.5	31.6	32.1	31.1	30.3	28.6	25.0	22.9
		MCDB	24.4	24.9	26.9	30.4	33.3	35.0	35.1	34.1	33.2	32.3	29.7	25.8
	5%	WB	19.8	21.1	23.2	24.7	28.5	31.1	31.5	30.6	29.7	27.8	24.2	21.8
		MCDB	23.8	24.4	26.5	29.8	32.8	34.5	34.5	33.8	32.7	31.8	29.2	25.0
	10%	WB	18.8	20.2	22.3	23.7	27.7	30.3	30.9	30.0	29.2	27.1	23.4	20.9
		MCDB	23.1	24.0	26.2	29.3	32.5	34.2	34.0	33.5	32.3	31.5	28.3	24.3
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.1	8.6	8.3	8.8	7.6	5.7	5.8	6.9	8.9	9.1	8.5
		MCDBR	8.8	9.2	10.0	9.9	10.8	10.5	8.7	9.2	9.6	9.6	9.5	8.9
		MCWBR	4.6	5.2	5.5	5.6	6.6	7.0	5.4	5.4	5.6	5.7	5.2	4.7
	5% WB	MCDBR	8.4	8.0	8.6	8.7	8.1	7.2	5.9	6.1	6.3	7.9	9.0	7.9
		MCWBR	5.1	5.3	6.4	6.1	6.8	5.8	2.9	3.4	3.5	4.9	5.6	4.6
(40) Clear-Sky Solar Irradiance	taub		0.478	0.552	0.617	0.649	0.647	0.711	0.796	0.755	0.662	0.569	0.495	0.475
	taud		2.014	1.830	1.689	1.648	1.651	1.573	1.486	1.547	1.667	1.824	1.995	2.019
	Ebn at Noon		756	727	705	697	697	650	596	618	663	702	732	738
	Edh at Noon		154	199	241	257	255	274	299	280	243	197	156	148
(44) All-Sky Solar Radiation	RadAvg		3.97	4.74	5.68	6.56	7.34	7.43	6.85	6.53	6.08	5.34	4.30	3.76
	RadStd		0.29	0.38	0.40	0.41	0.17	0.18	0.18	0.20	0.10	0.10	0.13	0.25

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		+0.40	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	+120	+116	

Nomenclature: See separate page