

IBRI, Oman

WMO: 412520

Lat: 23.1954N

Lon: 56.4295E

Elev: 327

StdP: 97.46

Time Zone: 4.00 (E04)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	12.8	-7.8	2.0	28.4	-5.7	2.4	28.6	10.9	21.5	10.1	22.8	2.9	310	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	46.0	20.9	45.1	21.0	44.1	21.1	25.5	36.1	24.9	36.4	24.4	36.2	5.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	18.2	30.7	21.8	17.1	30.9	21.0	16.3	31.1	80.5	36.5	77.9	36.2	75.9	36.4	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.2	8.0	DB	8.6	47.9	1.4	0.6	7.6	48.3	6.7	48.7	5.9	49.0	4.8	49.4	(4)
(5)			WB	5.4	26.8	1.4	1.1	4.4	27.6	3.5	28.3	2.7	28.9	1.7	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.8	19.9	22.0	26.0	30.3	34.9	37.0	37.9	36.8	34.7	31.1	25.5	21.5	(6)	
	DBStd	6.75	2.24	3.36	3.01	3.11	2.22	2.07	1.90	2.22	1.98	1.93	2.22	2.17	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	18	10	6	1	0	0	0	0	0	0	0	0	2	(9)	
	CDD10.0	7244	308	337	494	611	772	809	864	832	742	653	465	358	(10)	
	CDD18.3	4222	60	109	237	361	514	559	606	573	492	394	215	102	(11)	
	CDH23.3	65647	396	993	2797	5252	8644	9798	10803	9982	8268	5828	2164	722	(12)	
(13)	CDH26.7	44955	55	326	1377	3245	6214	7410	8324	7509	5886	3554	890	164	(13)	
(14)	Wind	WSAvg	3.6	3.4	4.0	3.9	4.1	4.0	4.1	3.8	3.4	3.2	2.9	2.8	3.3	(14)
(15) Precipitation	PrecAvg	122	16	19	25	14	5	3	7	6	4	4	6	12	(15)	
	PrecMax	285	44	78	156	75	15	15	48	19	18	22	32	58	(16)	
	PrecMin	48	1	1	0	0	0	0	1	1	0	0	0	1	(17)	
	PrecStd	47	11	16	31	18	4	4	9	4	3	5	8	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	33.8	37.4	41.0	46.1	47.1	47.1	46.1	44.4	40.7	34.9	32.5	(19)	
		MCWB	15.2	16.7	16.7	18.9	19.6	20.5	21.3	21.5	20.7	19.0	17.8	16.8	(20)	
	2%	DB	28.1	32.0	35.7	39.7	43.7	46.0	46.0	44.9	43.0	39.4	33.4	29.7	(21)	
		MCWB	15.3	16.5	16.5	18.5	19.7	20.3	21.4	21.8	20.7	18.9	17.9	15.8	(22)	
	5%	DB	26.8	30.4	34.3	38.5	42.4	44.9	45.0	43.9	41.9	38.2	32.4	28.4	(23)	
		MCWB	15.2	16.0	16.6	18.1	19.6	20.2	21.5	21.8	20.5	18.5	17.6	16.0	(24)	
	10%	DB	25.6	28.7	32.9	37.3	41.2	43.7	44.0	42.9	40.8	36.9	31.2	27.1	(25)	
		MCWB	14.8	15.7	16.4	17.7	19.4	20.3	21.5	21.8	20.5	18.3	17.3	15.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.2	20.3	21.4	22.7	24.5	26.0	26.9	26.3	24.9	23.5	21.2	19.7	(27)	
		MCDB	24.8	27.0	27.9	29.3	33.7	33.6	36.3	36.9	35.1	31.1	28.1	25.1	(28)	
	2%	WB	17.4	18.9	20.2	21.6	23.6	25.1	25.7	25.1	24.1	22.6	20.2	18.7	(29)	
		MCDB	24.4	26.8	27.6	29.0	33.8	35.2	36.6	37.4	34.7	30.3	28.2	24.9	(30)	
	5%	WB	16.5	18.0	19.3	20.7	22.6	24.4	25.0	24.6	23.6	21.7	19.5	17.9	(31)	
		MCDB	24.0	26.3	28.3	30.6	34.2	35.4	36.8	37.0	34.5	31.0	27.9	24.3	(32)	
	10%	WB	15.7	17.2	18.4	19.7	21.6	23.6	24.5	24.1	23.0	20.7	18.9	17.1	(33)	
		MCDB	23.5	26.1	28.2	32.6	35.4	35.8	36.7	36.6	34.2	31.8	27.4	24.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.9	12.7	12.1	12.4	13.2	12.1	12.1	12.3	11.6	10.7	11.2	(35)	
		MCDBR	12.4	12.2	13.4	12.4	13.4	14.0	13.0	12.4	12.7	12.4	11.3	12.7	(36)	
	5% WB	MCWBR	4.9	4.7	4.8	3.9	4.2	4.3	3.8	3.4	3.7	4.2	4.2	4.6	(37)	
		MCWBR	10.8	10.1	10.3	10.3	11.5	13.1	11.9	12.0	12.4	11.1	10.5	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.397	0.445	0.506	0.562	0.584	0.661	0.748	0.708	0.594	0.470	0.415	0.392	(40)	
		taud	2.179	2.015	1.847	1.752	1.708	1.587	1.487	1.546	1.721	1.977	2.144	2.190	(41)	
	Ebn at Noon		855	835	802	765	744	683	626	651	719	800	828	843	(42)	
		Edh at Noon	133	167	207	232	242	271	299	282	232	172	137	127	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.70	5.48	6.28	6.92	7.59	7.53	6.93	6.84	6.48	5.90	4.95	4.46	(44)	
	RadStd		0.21	0.24	0.34	0.41	0.19	0.25	0.26	0.17	0.13	0.15	0.10	0.18	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	+0.30	+0.52	N/A	N/A	+0.26	+0.29	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page