

SAIDU SHARIF, Pakistan

WMO: 415230

Lat: 34.733N

Lon: 72.350E

Elev: 951

StdP: 90.41

Time Zone: 5.00 (E05)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	1.8	-4.6	2.9	9.9	-3.3	3.2	8.5	2.8	10.9	2.1	9.9	0.0	N/A	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	37.1	22.4	35.8	22.8	34.5	22.9	26.4	33.1	25.8	32.3	25.2	31.5	0.4	N/A

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	22.1	30.8	24.1	21.3	30.1	23.5	20.6	29.5	89.0	33.5	86.2	32.2	83.5	31.6	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3.3	2.2	1.3	-0.1	40.2	0.5	2.0	-0.4	41.7	-0.7	42.9	-1.0	44.0	-1.4	45.5
			-1.5	27.5	1.1	0.7	-2.2	28.0	-2.9	28.4	-3.5	28.8	-4.3	29.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	8.2	10.2	15.0	19.7	24.8	28.2	28.4	27.2	25.0	20.4	14.0	9.8
	DBStd	7.68	2.04	2.87	3.59	3.12	2.82	2.45	1.93	1.85	1.97	2.94	1.96	2.09
	HDD10.0	127	63	29	4	0	0	0	0	0	0	0	1	30
	HDD18.3	1085	316	227	113	21	1	0	0	0	0	13	131	263
	CDD10.0	3515	6	34	158	290	458	546	571	534	449	323	120	25
	CDD18.3	1433	0	0	9	61	201	296	313	276	199	78	1	0
	CDH23.3	15804	0	3	110	581	2155	3609	3753	2991	1847	742	13	0
	CDH26.7	7398	0	0	13	173	1062	1993	1862	1330	734	231	1	0
Wind	WSAvg	0.2	0.1	0.1	0.1	0.2	0.3	0.3	0.2	0.1	0.1	0.1	0.0	0.0
Precipitation	PrecAvg	990	74	133	127	116	53	63	148	114	69	39	27	36
	PrecMax	1500	262	300	314	349	180	169	417	300	162	169	91	158
	PrecMin	640	0	9	0	0	4	0	36	34	13	0	0	0
	PrecStd	217	65	82	78	75	40	46	91	61	41	40	24	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.3	23.2	28.1	32.7	37.7	39.1	38.1	35.4	33.5	32.9	24.9	20.4
		MCWB	9.1	13.1	16.0	20.1	20.7	21.6	23.9	25.6	23.3	21.8	14.7	10.5
	2%	DB	16.5	20.1	26.1	30.2	35.6	37.6	36.3	34.2	32.5	30.8	23.0	18.6
		MCWB	8.7	11.0	15.2	18.2	20.4	22.2	24.7	25.0	22.7	19.9	13.6	9.9
	5%	DB	15.2	18.2	24.2	28.6	34.1	36.3	34.9	33.1	31.7	29.2	21.5	17.1
		MCWB	8.0	10.2	14.2	17.6	20.2	22.2	24.8	24.9	22.5	18.6	12.8	9.1
	10%	DB	13.7	16.4	22.3	26.8	32.4	35.0	33.7	32.2	30.7	27.5	20.0	15.7
		MCWB	7.4	9.5	13.6	16.9	19.7	22.0	24.6	24.6	22.1	17.8	12.1	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	13.8	17.2	20.6	22.6	26.5	27.1	27.1	25.2	22.9	15.7	11.7
		MCDB	15.6	21.7	25.3	30.6	32.8	34.5	34.0	33.3	31.7	30.3	22.7	17.6
	2%	WB	9.5	12.1	15.8	19.3	21.6	25.3	26.4	26.4	24.2	21.5	14.6	10.6
		MCDB	14.2	18.5	24.4	28.9	32.8	33.8	33.3	32.5	30.8	28.3	21.3	16.7
	5%	WB	8.8	10.9	14.9	18.2	20.9	24.3	25.9	25.7	23.6	20.1	13.7	9.8
		MCDB	13.2	16.8	23.2	27.2	32.1	33.0	32.7	31.6	29.9	26.5	19.8	16.0
	10%	WB	8.0	9.9	14.0	17.4	20.1	23.3	25.4	25.2	23.0	18.7	12.8	9.0
		MCDB	12.4	15.2	21.3	25.6	30.7	32.1	31.9	30.6	28.9	25.7	18.6	14.7
Mean Daily Temperature Range	5% DB	MDBR	10.4	10.2	10.8	11.8	13.3	12.9	9.9	9.6	11.3	13.5	12.3	12.2
		MCDBR	13.2	13.7	14.2	14.8	15.7	14.3	11.8	10.9	12.6	15.4	14.7	14.0
		MCWBR	6.7	6.4	6.0	6.1	5.5	5.1	4.6	4.5	5.3	6.1	6.8	6.8
	5% WB	MCDBR	11.2	12.1	13.4	13.8	14.9	12.1	9.6	9.4	10.7	13.7	12.8	12.7
		MCWBR	6.4	6.5	6.1	6.2	5.8	5.6	4.1	4.1	4.9	6.1	6.6	6.7
Clear-Sky Solar Irradiance	taub	0.380	0.432	0.449	0.458	0.469	0.536	0.621	0.601	0.507	0.448	0.416	0.377	
	taud	2.111	1.994	2.012	2.057	2.056	1.909	1.767	1.814	1.984	2.036	2.055	2.131	
	Ebn at Noon	793	791	817	832	826	769	701	706	755	764	743	769	
	Edh at Noon	123	155	165	166	168	194	223	209	168	146	129	114	
All-Sky Solar Radiation	RadAvg	2.83	3.32	4.65	5.97	7.08	7.42	6.66	6.07	5.64	4.68	3.35	2.73	
	RadStd	0.34	0.51	0.49	0.43	0.44	0.31	0.41	0.43	0.29	0.28	0.24	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page