

PESHAWAR, Pakistan

WMO: 415300

Lat: 34.017N

Lon: 71.583E

Elev: 1181

StdP: 14.08

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.8	(c) 40.1	(d) 26.5	(e) 21.4	(f) 54.8	(g) 29.8	(h) 24.9	(i) 50.8	(j) 18.6	(k) 60.5	(l) 13.8	(m) 56.1	(n) 1.2	(o) 230	(p) 0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 22.9	(c) 107.2	(d) 74.5	(e) 104.1	(f) 75.8	(g) 101.8	(h) 76.8	(i) 85.1	(j) 96.9	(k) 83.7	(l) 95.6	(m) 82.6	(n) 94.0	(o) 7.0	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.4	176.6	94.0	80.9	167.5	91.9	79.6	160.8	90.9	51.2	97.6	49.5	95.3	48.0	93.8	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.5	(b) 16.7	(c) 13.2	(e) 33.7	(f) 112.1	(g) 1.9	(h) 3.2	(i) 32.3	(j) 114.4	(k) 31.2	(l) 116.2	(m) 30.1	(n) 118.0	(o) 28.7	(p) 120.3		
			DB													
			WB													
				31.4	88.1	1.7	1.3	30.2	89.0	29.2	89.7	28.3	90.4	27.0	91.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	52.7	57.4	66.7	76.0	85.5	90.5	89.6	87.5	84.6	75.8	64.0	55.3
	DBStd	14.23	3.78	4.89	6.14	6.02	5.35	4.09	4.16	3.49	3.37	5.01	3.94	3.67
	HDD50	22	15	3	0	0	0	0	0	0	0	0	0	4
	HDD65	1022	381	216	55	3	0	0	0	0	0	0	66	301
	CDD50	8736	99	211	517	779	1100	1216	1227	1161	1037	801	420	168
	CDD65	4261	0	4	107	331	635	766	762	696	587	337	36	0
	CDH74	57928	5	73	1041	3599	8992	12140	11544	9758	7274	3140	341	21
	CDH80	33406	0	7	315	1740	5502	8021	7203	5532	3747	1304	35	0
(14) Wind	WSAvg	4.4	2.4	3.7	4.2	5.2	6.0	6.5	7.1	6.1	4.7	2.9	2.0	1.9
(15) Precipitation	PrecAvg	17.3	1.3	2.1	2.7	2.2	1.1	0.5	1.6	2.7	1.0	0.5	0.5	0.9
	PrecMax	30.4	5.9	9.3	8.8	7.4	4.7	3.1	6.4	11.0	4.4	3.7	2.5	5.7
	PrecMin	7.5	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.2	1.4	1.8	2.0	1.7	1.0	0.6	1.5	2.6	0.9	0.7	0.6	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.8	80.3	90.6	100.6	109.1	113.1	107.0	102.0	98.9	95.4	83.9	76.9
		MCWB	56.4	58.3	68.6	71.7	72.4	71.3	80.7	83.1	79.2	74.5	64.0	57.7
	2%	DB	70.0	75.9	86.4	96.9	105.7	108.2	103.9	99.4	96.9	92.9	80.4	73.1
		MCWB	54.2	57.5	65.6	70.1	72.0	74.3	81.1	82.5	78.8	73.8	62.7	55.6
	5%	DB	66.9	72.0	83.8	93.2	102.3	105.6	101.8	97.5	95.2	89.9	77.7	70.0
		MCWB	52.5	55.9	64.8	69.0	72.2	75.1	81.3	81.7	77.9	71.3	61.8	54.5
	10%	DB	64.1	68.8	80.3	89.6	98.9	102.4	98.8	95.4	93.5	87.5	75.3	67.5
		MCWB	51.4	55.0	63.1	68.0	71.9	75.6	81.0	81.1	77.2	69.9	61.1	53.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	62.6	71.3	75.3	78.7	84.7	87.1	86.7	83.5	79.1	68.0	60.1
		MCDB	69.1	75.0	83.8	92.2	99.8	99.9	99.8	97.0	94.6	91.1	76.8	71.9
	2%	WB	56.1	60.1	68.2	72.7	76.5	82.5	85.3	85.2	81.8	76.8	65.9	57.8
		MCDB	67.1	70.3	82.0	90.9	96.6	99.0	98.0	95.6	93.0	88.0	75.7	69.1
	5%	WB	54.1	58.3	66.2	71.0	75.1	80.7	83.9	83.8	80.5	74.4	64.2	56.0
		MCDB	64.0	68.3	79.9	88.9	95.1	96.0	96.7	94.1	91.6	85.5	74.6	67.0
	10%	WB	52.4	56.7	64.3	69.5	73.6	78.9	82.7	82.7	79.3	72.2	62.5	54.2
		MCDB	61.5	66.8	77.7	86.6	94.0	94.9	94.8	92.4	89.9	84.0	72.2	64.9
(35) Mean Daily Temperature Range	5% DB	MDBR	22.7	20.1	21.3	22.6	24.2	22.9	17.0	16.0	18.5	22.1	23.4	25.1
		MCDBR	27.9	26.7	26.3	27.6	28.5	27.9	20.7	17.9	19.8	22.9	26.7	29.4
		MCWBR	16.1	13.8	12.4	11.3	10.4	10.7	10.2	9.1	9.4	9.9	13.7	16.0
	5% WB	MCDBR	24.7	22.4	24.2	24.9	25.8	20.9	17.1	15.8	17.0	20.3	22.3	25.9
		MCWBR	15.3	12.5	12.5	11.3	11.1	11.5	10.3	9.5	9.5	9.6	12.4	15.2
(40) Clear-Sky Solar Irradiance	taub		0.452	0.512	0.539	0.560	0.586	0.675	0.776	0.747	0.643	0.593	0.532	0.458
	taud		1.934	1.837	1.813	1.812	1.777	1.627	1.506	1.555	1.693	1.708	1.789	1.921
	Ebn at Noon		226	226	234	237	233	212	190	192	205	200	198	214
	Edh at Noon		48	58	64	67	70	82	92	86	72	65	55	46
(44) All-Sky Solar Radiation	RadAvg		957	1112	1523	1951	2287	2364	2067	1889	1783	1501	1110	931
	RadStd		105	163	149	116	106	74	109	129	83	74	57	65

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+1.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page