

QUETTA INTL, Pakistan

WMO: 416600

Lat: 30.251N

Lon: 66.938E

Elev: 1600

StdP: 83.52

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-3.7	-13.6	1.4	2.8	-11.6	1.7	2.5	12.6	4.3	11.4	7.1	1.6	130	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	37.6	19.8	36.6	19.4	35.6	19.0	22.4	34.1	21.4	33.3	20.6	32.5	7.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.6	29.8	17.6	15.4	29.1	16.4	14.2	29.2	75.0	35.0	70.8	33.6	67.4	32.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.7	10.9	9.8	-7.9	39.2	2.5	0.4	-9.7	39.5	-11.2	39.8	-12.6	40.0	-14.4	40.3
			-9.3	24.2	2.2	2.3	-10.9	25.8	-12.2	27.1	-13.4	28.4	-15.0	30.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	5.2	7.6	13.4	18.7	23.6	27.7	29.8	27.9	23.4	17.4	10.8	6.3
	DBStd	9.03	3.46	4.16	3.72	3.33	2.68	2.20	1.43	1.66	2.65	3.22	3.40	3.31
	HDD10.0	401	151	88	12	0	0	0	0	0	0	0	30	119
	HDD18.3	1556	406	299	158	36	2	0	0	0	1	58	226	372
	CDD10.0	3213	4	22	117	261	422	531	612	554	401	231	54	6
	CDD18.3	1327	0	0	4	46	165	281	354	296	152	29	0	0
	CDH23.3	17098	0	2	63	576	2058	3769	4825	3621	1742	436	7	1
	CDH26.7	8813	0	0	7	167	958	2098	2769	1941	761	113	0	0
Wind	WSAvg	4.6	3.7	4.5	4.8	5.2	5.5	5.7	6.2	5.3	4.1	3.6	3.3	3.3
Precipitation	PrecAvg	230	45	44	49	30	7	2	11	4	3	4	7	24
	PrecMax	419	178	189	232	148	40	43	122	28	95	69	65	146
	PrecMin	62	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	85	39	39	44	36	10	6	22	7	15	13	12	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.4	22.7	27.5	32.0	36.0	38.3	38.9	37.8	34.5	31.2	24.3	19.8
		MCWB	8.6	10.2	15.0	16.0	17.6	19.0	20.9	20.4	17.8	15.4	12.4	8.9
	2%	DB	16.4	19.9	25.0	30.2	34.5	37.1	37.9	36.4	33.1	29.5	22.4	17.4
		MCWB	7.8	9.6	13.9	15.7	17.2	18.8	20.3	19.7	16.9	14.7	11.6	7.9
	5%	DB	14.4	17.5	23.2	28.7	33.2	36.1	37.0	35.2	32.1	27.9	20.7	15.6
		MCWB	6.6	8.7	12.9	15.2	17.0	18.5	19.9	19.1	16.5	14.0	10.6	6.8
	10%	DB	12.3	15.2	21.1	26.8	31.8	34.9	36.0	34.2	30.9	25.9	18.9	13.6
		MCWB	5.6	7.3	11.7	14.2	16.6	18.0	19.6	18.5	16.4	13.0	9.9	6.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	11.7	17.4	19.0	21.6	22.5	24.2	22.9	21.2	17.8	14.4	10.8
		MCDB	16.3	19.7	24.7	27.8	32.5	34.5	36.4	34.7	31.2	28.6	22.2	17.6
	2%	WB	8.3	10.4	15.1	17.4	19.7	21.3	22.9	21.7	19.6	15.9	12.6	8.8
		MCDB	14.7	18.2	23.4	27.5	31.4	33.0	34.8	33.3	30.0	26.9	19.8	15.3
	5%	WB	7.3	9.2	13.4	16.2	18.7	20.4	21.7	20.8	18.6	14.7	11.5	7.6
		MCDB	13.1	16.1	21.8	26.7	30.8	32.5	33.9	32.5	28.8	26.1	19.0	13.9
	10%	WB	6.2	8.1	12.2	15.1	17.5	19.5	20.8	19.9	17.6	13.7	10.4	6.4
		MCDB	11.5	14.6	20.2	25.3	29.6	32.1	33.2	31.7	27.6	24.6	17.8	12.5
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.5	12.2	13.7	14.5	13.9	12.8	13.0	15.1	15.7	14.3	13.0
		MCDBR	15.2	14.2	15.2	15.9	16.7	15.0	14.1	14.0	15.4	16.7	16.0	15.5
		MCWBR	8.8	7.1	7.9	7.0	6.6	5.1	4.7	4.9	5.7	6.5	8.1	8.5
	5% WB	MCDBR	13.1	13.0	14.5	15.0	16.0	13.7	13.4	13.4	14.4	16.5	14.6	13.4
		MCWBR	8.1	7.1	8.3	8.1	7.9	5.7	5.5	5.7	6.6	8.0	8.0	8.4
Clear-Sky Solar Irradiance	taub	0.333	0.401	0.449	0.507	0.505	0.531	0.645	0.582	0.431	0.371	0.349	0.313	
	taud	2.238	2.031	1.894	1.792	1.798	1.744	1.557	1.667	1.971	2.108	2.184	2.322	
	Ebn at Noon	887	848	832	798	800	776	689	729	838	868	859	894	
	Edh at Noon	115	155	191	219	219	230	277	246	174	141	120	100	
All-Sky Solar Radiation	RadAvg	3.73	4.37	5.77	6.82	7.73	8.11	7.43	7.06	6.67	5.70	4.39	3.72	
	RadStd	0.30	0.45	0.39	0.36	0.31	0.32	0.38	0.37	0.22	0.15	0.20	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page