

BAHAWALPUR, Pakistan

WMO: 417000

Lat: 29.400N

Lon: 71.783E

Elev: 113

StdP: 99.97

Time Zone: 5.00 (E05)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	6.1	0.9	4.1	11.0	2.3	4.5	11.1	4.4	16.5	3.7	17.1	0.1	N/A	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.9	43.0	24.7	41.7	25.1	40.6	25.5	29.5	37.2	29.1	36.8	28.7	36.3	1.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	24.0	33.9	27.2	23.3	33.8	26.8	22.7	33.7	98.8	37.9	96.5	37.1	94.5	36.3	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	5.4	4.2	DB	2.5	45.1	1.1	0.9	1.7	45.8	1.0	46.3	0.4	46.9	-0.5	47.5	(4)
(5)			WB	2.2	30.6	1.6	0.4	1.0	30.9	0.1	31.2	-0.9	31.4	-2.0	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	13.0	16.7	22.3	29.3	33.6	34.7	34.2	32.6	30.9	27.2	21.0	15.1	(6)	
	DBStd	8.01	2.47	2.83	3.76	3.13	2.40	2.30	1.82	1.50	1.66	2.42	2.33	2.72	(7)	
	HDD10.0	8	6	1	0	0	0	0	0	0	0	0	0	2	(8)	
	HDD18.3	341	164	61	9	0	0	0	0	0	0	0	3	104	(9)	
	CDD10.0	5822	99	188	381	579	732	740	751	702	628	532	328	161	(10)	
	CDD18.3	3115	0	15	132	329	474	490	493	444	378	273	82	4	(11)	
	CDH23.3	45048	8	143	1322	4418	7459	7991	7943	6710	5252	3017	719	65	(12)	
(13)	CDH26.7	28536	0	21	587	2708	5089	5618	5473	4244	3011	1580	202	3	(13)	
(14)	Wind	WSAvg	1.1	0.5	0.7	0.8	1.2	1.3	2.1	1.9	1.8	1.4	0.7	0.3	0.3	(14)
(15) Precipitation	PrecAvg	130	5	11	9	4	7	8	54	18	15	0	1	3	(15)	
	PrecMax	356	24	78	43	18	48	37	258	82	66	8	16	42	(16)	
	PrecMin	11	0	0	0	0	0	0	1	0	0	0	0	0	(17)	
	PrecStd	86	8	20	14	6	13	14	65	22	22	2	4	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	29.0	36.9	43.0	44.8	44.6	42.1	39.6	38.9	37.2	32.1	27.1	(19)	
		MCWB	15.9	17.9	22.3	22.0	24.5	25.9	27.8	28.2	27.1	24.8	20.1	18.2	(20)	
	2%	DB	22.5	26.8	34.6	41.1	43.2	42.9	40.7	38.5	37.8	36.1	30.5	25.1	(21)	
		MCWB	14.9	18.4	21.9	21.7	24.2	26.0	28.1	27.8	27.1	24.2	20.3	16.7	(22)	
	5%	DB	21.0	25.0	32.2	39.4	41.9	41.5	39.8	37.7	36.8	35.0	28.9	23.6	(23)	
		MCWB	13.8	17.5	21.0	21.7	24.1	26.4	28.1	27.8	26.7	23.4	19.6	15.6	(24)	
	10%	DB	19.5	23.3	30.0	37.3	40.6	40.2	38.8	36.9	35.9	33.8	27.5	22.0	(25)	
		MCWB	13.2	16.3	20.4	21.4	24.1	26.8	28.1	27.9	26.4	23.0	18.9	14.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.0	21.1	24.1	24.7	28.4	29.7	30.2	29.7	29.5	27.1	22.6	18.8	(27)	
		MCDB	23.0	26.1	34.5	37.1	39.1	39.7	38.0	36.2	36.4	35.2	29.1	25.6	(28)	
	2%	WB	15.7	19.7	22.8	23.8	27.1	29.0	29.5	29.3	28.7	26.2	21.5	17.6	(29)	
		MCDB	21.3	25.1	31.9	36.7	39.1	38.8	37.4	35.8	35.5	33.8	28.4	24.0	(30)	
	5%	WB	14.7	18.3	21.7	23.1	26.3	28.5	29.1	28.9	28.1	25.1	20.5	16.4	(31)	
		MCDB	19.8	23.7	30.6	35.5	38.0	38.2	37.1	35.4	34.6	32.3	27.4	22.4	(32)	
	10%	WB	13.7	17.1	20.7	22.3	25.4	27.9	28.7	28.5	27.5	24.2	19.6	15.3	(33)	
		MCDB	18.3	22.1	29.0	34.6	37.3	37.6	36.7	34.9	33.8	31.3	26.0	20.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	12.2	12.6	14.4	13.6	10.9	9.0	8.4	9.9	13.0	13.4	13.1	(35)	
		MCDBR	14.5	14.3	15.3	16.7	15.0	12.7	9.9	9.3	11.0	13.3	14.5	15.0	(36)	
	5% WB	MCWBR	7.9	7.2	6.0	5.1	4.8	3.8	2.9	3.0	3.6	4.6	6.5	7.7	(37)	
		MCWBR	13.3	12.7	14.3	15.0	12.9	10.5	9.3	8.7	9.3	11.7	13.2	13.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.494	0.489	0.518	0.597	0.667	0.763	0.810	0.711	0.606	0.605	0.591	0.542	(40)	
		taud	1.824	1.888	1.844	1.705	1.601	1.489	1.445	1.606	1.756	1.666	1.653	1.734	(41)	
	Ebn at Noon		705	764	774	728	681	615	585	640	692	649	607	631	(42)	
		Edh at Noon	178	182	202	240	268	298	310	262	218	224	211	188	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.28	4.36	5.62	6.56	6.99	6.69	6.14	5.93	5.77	4.97	3.78	3.23	(44)	
	RadStd		0.28	0.28	0.25	0.21	0.18	0.27	0.30	0.25	0.27	0.21	0.23	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page