

NOK KUNDI, Pakistan

WMO: 417100

Lat: 28.817N

Lon: 62.750E

Elev: 2241

StdP: 13.54

Time Zone: 5.00 (E05)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	37.0	3.2	7.0	45.6	5.7	8.0	45.7	28.8	54.9	22.8	58.4	4.3	310	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	113.2	67.2	111.4	66.6	109.6	66.1	72.1	99.9	69.4	104.2	67.6	105.7	8.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.1	90.6	92.5	56.7	74.5	85.6	52.3	63.3	84.3	37.4	99.3	34.9	104.0	33.3	106.3	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.8	26.3	22.1	DB	27.3	116.4	4.6	1.9	23.9	117.8	21.2	118.9	18.6	119.9	15.3	121.2	(4)
(5)			WB	21.1	71.5	3.7	3.4	18.5	73.9	16.3	75.9	14.2	77.8	11.5	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.7	54.9	60.6	71.8	82.3	91.9	96.4	98.7	94.9	88.4	80.1	66.7	56.3		
	DBStd	16.60	7.21	9.50	7.20	7.09	5.07	4.41	3.30	3.45	4.54	5.84	7.13	6.73		
	HDD50	83	36	24	0	0	0	0	0	0	0	0	1	22		
	HDD65	862	317	175	24	3	0	0	0	0	0	0	66	277		
	CDD50	10547	189	320	677	968	1297	1393	1510	1391	1152	933	501	216		
	CDD65	5852	5	51	236	521	832	943	1045	926	702	468	116	7		
	CDH74	91586	55	444	2507	7067	13641	16548	18485	15489	10446	5677	1137	90		
	CDH80	61979	2	104	1027	4055	9385	12252	14022	11045	6664	3059	355	9		
(14) Wind	WSAvg	6.5	4.0	5.5	4.8	5.5	6.1	10.0	11.5	11.1	7.3	4.5	3.5	3.6		
(15) Precipitation	PrecAvg	1.4	0.5	0.2	0.2	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1		
	PrecMax	4.6	3.6	1.4	1.3	0.9	0.2	0.0	1.3	1.0	0.0	0.3	0.1	0.6		
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.1	0.9	0.4	0.4	0.2	0.0	0.0	0.3	0.2	0.0	0.1	0.0	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	87.1	96.9	105.3	112.4	116.0	115.2	113.0	107.5	102.9	91.1	80.1		
		MCWB	53.0	57.9	62.4	65.8	67.0	68.3	67.9	67.4	65.1	63.8	57.9	52.7		
	2%	DB	75.0	83.1	92.5	102.2	110.1	113.3	113.3	110.0	105.3	100.0	87.2	76.2		
		MCWB	51.1	55.6	60.4	64.7	66.9	67.4	67.2	66.3	64.5	63.1	56.4	51.0		
	5%	DB	71.8	79.3	89.2	99.2	107.1	111.2	111.6	107.6	103.3	97.0	84.5	73.1		
		MCWB	49.3	54.8	58.7	63.9	65.7	66.5	66.5	65.3	63.8	61.6	55.6	49.4		
	10%	DB	68.6	75.5	86.0	96.2	104.4	108.9	109.8	105.5	101.3	93.6	80.9	69.7		
		MCWB	47.9	52.6	57.0	62.8	64.9	65.8	66.1	64.6	63.1	59.7	54.3	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.8	63.6	65.8	73.2	69.2	76.9	74.4	73.5	69.7	70.2	61.9	54.7		
		MCDB	72.8	76.9	88.3	96.0	107.7	84.7	99.7	98.3	101.0	96.7	80.9	77.2		
	2%	WB	53.5	58.7	62.9	68.8	67.8	71.4	71.3	69.3	66.3	64.0	58.8	52.0		
		MCDB	69.0	75.8	85.4	94.6	107.3	100.9	105.8	102.9	101.8	95.8	81.2	73.5		
	5%	WB	51.2	56.4	60.6	66.1	66.4	68.1	68.5	66.8	64.3	62.1	57.0	50.2		
		MCDB	67.2	75.1	84.1	95.1	105.5	109.0	108.0	104.8	102.1	95.6	81.5	70.0		
	10%	WB	49.1	54.2	58.6	63.9	65.1	66.5	66.9	65.3	63.1	60.3	55.1	48.4		
		MCDB	65.8	72.8	82.6	93.4	103.2	107.6	107.4	104.3	100.2	92.2	79.5	68.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.2	22.8	23.1	22.2	22.1	22.2	21.6	21.6	24.1	24.7	24.3	24.9		
		MCDBR	26.6	25.4	26.2	25.1	24.5	25.1	23.4	22.8	26.3	26.3	26.9	27.0		
	5% WB	MCWBR	14.1	12.2	11.6	10.3	8.6	8.8	8.0	8.3	10.8	11.5	13.0	13.7		
		MCWBR	23.8	22.5	23.8	23.2	23.7	23.5	22.9	22.0	26.1	25.6	25.2	26.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.356	0.412	0.460	0.520	0.540	0.529	0.558	0.503	0.434	0.415	0.368	0.340		
		taud	2.262	2.085	1.934	1.829	1.790	1.810	1.763	1.869	2.009	2.061	2.224	2.309		
	Ebn at Noon	Ebn at Noon	276	268	262	251	246	247	239	252	266	263	269	276		
		Edh at Noon	36	47	59	67	70	69	72	64	54	48	37	33		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1243	1459	1824	2152	2372	2486	2348	2290	2101	1746	1390	1194		
	RadStd	RadStd	74	95	92	87	58	97	91	73	43	40	43	60		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page