

KHUZDAR, Pakistan

WMO: 417440

Lat: 27.833N

Lon: 66.633E

Elev: 4042

StdP: 12.67

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.3	38.8	4.5	8.0	61.3	9.7	10.5	61.8	13.3	59.0	9.8	58.8	0.8	N/A	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	20.7	103.4	66.7	101.5	66.0	99.6	65.5	76.4	93.5	74.3	91.2	72.8	89.2	2.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	137.1	86.8	69.7	127.2	83.8	68.0	119.9	83.6	43.3	92.0	41.0	91.7	39.5	88.6	94.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	9.5	7.5	DB	32.5	107.2	3.3	3.0	30.1	109.3	28.2	111.1	26.3	112.7	24.0	114.9	
			WB	26.1	80.4	5.8	9.1	21.9	86.9	18.5	92.3	15.3	97.4	11.1	104.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.0	52.7	55.8	65.6	76.2	85.2	89.4	88.5	85.5	82.6	74.7	63.6	55.8
	DBStd	14.03	4.83	6.61	6.86	6.15	5.22	3.76	3.59	3.72	3.26	4.81	4.89	5.28
	HDD50	59	29	19	1	0	0	0	0	0	0	0	0	10
	HDD65	1100	382	263	79	4	0	0	0	0	0	0	82	290
	CDD50	8469	112	182	485	785	1090	1181	1193	1101	977	766	407	190
	CDD65	4036	0	6	98	340	625	731	728	636	527	301	39	5
	CDH74	53837	5	111	938	3737	8959	11125	10284	8423	6513	3229	450	63
	CDH80	29467	0	9	234	1663	5247	7046	6119	4585	3271	1237	49	7
(14) Wind	WSAvg	1.7	1.4	2.1	1.9	2.3	2.4	2.0	1.9	1.5	1.2	1.4	1.0	1.1
(15) Precipitation	PrecAvg	10.4	0.7	1.6	1.1	0.7	0.5	0.6	2.0	1.7	0.4	0.3	0.1	0.6
	PrecMax	23.1	5.8	5.4	3.3	2.8	2.6	5.3	14.0	5.6	2.1	3.5	1.4	4.3
	PrecMin	2.5	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.0	1.1	1.4	1.0	0.8	0.7	1.1	2.8	1.3	0.6	0.7	0.3	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	81.4	89.5	98.7	104.2	106.8	104.2	102.3	98.5	94.5	84.5	80.0
		MCWB	51.5	54.4	59.3	67.1	70.1	67.1	68.9	64.8	63.5	62.7	55.7	56.9
	2%	DB	70.6	77.6	85.7	94.8	101.4	104.1	102.2	99.4	96.2	91.6	81.2	74.9
		MCWB	49.8	53.8	57.1	64.8	66.3	65.4	67.2	64.4	63.8	63.2	55.4	53.9
	5%	DB	67.9	74.1	82.4	91.5	99.2	102.2	100.3	97.4	94.5	89.4	78.9	71.2
		MCWB	48.3	52.3	55.9	62.5	64.2	65.3	66.7	64.5	63.7	61.4	54.6	51.0
	10%	DB	65.0	70.2	79.4	88.6	97.0	100.0	98.4	95.5	92.5	86.7	76.6	68.3
		MCWB	47.3	50.6	54.4	60.3	63.9	65.5	66.8	64.6	62.9	60.0	53.5	49.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.5	57.5	63.0	71.5	78.1	77.7	84.8	75.8	72.0	70.9	60.4	61.7
		MCDB	69.5	71.6	80.3	96.3	101.0	99.3	92.9	91.1	88.3	88.8	77.6	77.3
	2%	WB	52.1	55.5	60.3	68.6	71.9	75.5	77.2	73.7	70.5	67.9	58.2	56.5
		MCDB	65.8	72.9	78.7	90.7	95.6	95.9	90.8	88.4	86.9	84.2	76.7	71.0
	5%	WB	50.0	54.1	58.4	65.9	69.0	73.6	74.7	72.3	69.0	65.2	56.6	52.7
		MCDB	63.7	71.2	76.3	85.8	92.9	92.2	90.1	86.3	85.7	83.1	75.4	67.8
	10%	WB	48.4	52.2	56.2	63.0	66.6	71.9	73.1	71.1	67.4	62.7	54.9	50.2
		MCDB	63.2	67.8	75.3	83.3	91.1	90.0	88.4	84.9	84.8	83.0	73.3	66.3
(35) Mean Daily Temperature Range	5% DB	MDBR	22.7	23.4	21.0	20.4	20.9	20.7	19.6	18.6	20.0	22.8	23.2	23.8
		MCDBR	26.7	28.4	24.6	24.2	22.1	23.2	21.7	21.3	22.1	23.9	26.0	27.1
		MCWBR	13.6	12.8	9.7	10.0	7.8	7.5	7.0	7.3	7.5	9.1	10.5	13.9
	5% WB	MCDBR	24.9	25.4	23.3	25.0	25.0	22.6	20.2	19.1	20.8	24.7	25.1	25.8
		MCWBR	14.6	13.0	10.2	12.1	11.6	10.0	9.3	7.4	8.5	12.3	12.0	15.2
(40) Clear-Sky Solar Irradiance	taub		0.333	0.370	0.416	0.476	0.497	0.562	0.682	0.603	0.472	0.398	0.377	0.333
	taud		2.310	2.209	2.053	1.917	1.873	1.757	1.582	1.720	1.962	2.098	2.142	2.297
	Ebn at Noon		287	284	277	263	257	239	211	228	256	270	267	281
	Edh at Noon		35	42	52	62	65	72	86	75	56	46	41	34
(44) All-Sky Solar Radiation	RadAvg		1292	1535	1918	2166	2357	2369	2151	2083	2026	1821	1455	1249
	RadStd		73	114	104	114	77	106	124	112	86	54	62	63

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page