

PADIDAN, Pakistan

WMO: 417460

Lat: 26.850N

Lon: 68.133E

Elev: 154

StdP: 14.61

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.7	45.2	34.3	29.2	56.6	37.4	33.0	57.1	8.3	62.2	7.2	62.1	0.5	0	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	23.4	113.1	78.4	110.5	78.2	107.8	78.8	87.0	101.4	86.0	100.2	85.3	99.2	3.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.5	176.3	97.2	82.7	171.4	96.2	81.8	166.6	95.3	52.4	102.8	51.1	100.9	50.2	99.6	90.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	7.4	5.7	39.5	118.5	3.6	2.0	36.9	119.9	34.8	121.1	32.8	122.2	30.2	123.7		
			37.8	89.2	3.7	1.0	35.2	90.0	33.0	90.6	30.9	91.1	28.3	91.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.5	58.8	64.1	75.0	87.7	95.0	95.3	93.1	90.1	88.3	83.5	72.3	62.0
	DBStd	13.47	3.70	5.23	6.40	4.91	3.61	2.96	2.36	2.26	2.38	3.97	4.76	4.56
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	385	192	71	5	0	0	0	0	0	0	0	1	116
	CDD50	11136	275	395	776	1130	1394	1360	1335	1242	1150	1039	668	372
	CDD65	6047	1	46	316	680	929	910	870	777	700	574	220	24
	CDH74	87531	57	541	3570	9557	15098	14845	13629	11320	9676	6876	2138	224
	CDH80	55969	1	142	1827	6197	10735	10541	9169	6885	5647	3983	816	26
Wind	WSAvg	2.2	1.6	2.0	2.2	2.7	2.9	3.6	3.0	2.4	2.0	1.4	1.2	1.3
Precipitation	PrecAvg	4.6	0.0	0.2	0.2	0.1	0.1	0.2	1.8	1.1	0.6	0.0	0.0	0.2
	PrecMax	13.1	0.4	0.6	1.7	0.7	0.5	2.0	6.9	6.2	5.4	0.2	0.4	1.8
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.0	0.1	0.2	0.4	0.2	0.2	0.5	2.2	1.6	1.3	0.0	0.1	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	88.1	103.8	112.6	117.2	116.6	108.0	103.5	103.9	103.2	94.8	83.5
		MCWB	63.2	68.4	73.7	77.5	77.6	80.7	84.8	85.9	82.9	78.7	72.0	66.9
	2%	DB	75.4	84.7	98.7	109.1	114.2	112.6	105.4	101.4	101.2	100.4	91.2	79.4
		MCWB	60.7	67.6	71.6	74.9	78.0	80.3	85.1	85.4	83.3	78.8	70.7	64.7
	5%	DB	72.8	80.2	94.2	105.8	111.5	109.4	103.8	99.8	99.4	98.1	88.1	76.4
		MCWB	59.8	65.0	70.9	74.2	77.4	80.8	85.1	85.1	82.9	77.6	70.9	62.7
	10%	DB	70.1	76.8	90.2	102.6	108.9	106.7	102.0	98.2	97.8	95.7	85.1	73.6
		MCWB	58.5	62.8	70.2	72.9	77.5	81.8	84.8	84.6	82.2	76.6	69.0	61.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.0	72.0	76.3	82.2	85.4	87.7	88.5	87.6	86.8	83.6	76.1	68.5
		MCDB	75.8	85.0	95.7	107.7	106.8	105.3	102.8	100.6	99.4	98.3	88.5	80.4
	2%	WB	62.7	69.2	74.3	78.9	83.4	86.0	87.1	86.4	85.3	81.8	73.6	66.5
		MCDB	73.1	80.9	92.8	102.3	104.7	103.5	101.7	98.8	97.6	96.4	87.0	76.6
	5%	WB	60.8	66.8	72.7	76.6	81.6	85.0	86.2	85.5	84.2	80.2	71.9	64.4
		MCDB	70.9	78.4	90.6	98.5	102.9	102.4	100.6	97.5	96.3	94.1	85.6	73.9
	10%	WB	59.2	64.2	70.9	75.0	80.2	84.0	85.3	84.9	83.2	78.4	70.1	62.3
		MCDB	69.0	74.6	87.7	96.3	101.8	101.2	99.5	96.7	95.2	91.3	82.9	71.8
Mean Daily Temperature Range	5% DB	MDBR	23.4	25.6	27.0	28.9	28.7	23.4	18.7	17.1	19.9	25.1	24.7	23.0
		MCDBR	27.0	29.4	32.0	33.1	31.7	28.7	21.1	19.4	22.5	26.9	27.3	25.1
		MCWBR	14.8	15.0	12.0	8.8	7.7	7.5	7.6	8.3	9.1	10.4	11.5	13.0
	5% WB	MCDBR	24.7	27.0	29.0	30.9	29.0	22.2	19.4	18.1	20.5	23.7	25.1	23.0
	MCWBR	14.6	15.5	13.1	10.4	9.9	8.3	7.9	8.3	9.2	10.3	11.9	13.3	
Clear-Sky Solar Irradiance	taub	0.480	0.482	0.536	0.604	0.641	0.713	0.792	0.722	0.607	0.557	0.568	0.530	
	taud	1.898	1.931	1.818	1.709	1.668	1.577	1.493	1.603	1.773	1.783	1.722	1.785	
	Ebn at Noon	235	249	243	231	222	206	189	202	222	223	206	211	
	Edh at Noon	54	56	67	76	80	87	94	84	69	64	64	58	
All-Sky Solar Radiation	RadAvg	1244	1531	1876	2124	2270	2166	1958	1918	1886	1697	1339	1184	
	RadStd	64	84	78	59	40	61	107	92	92	66	60	57	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page