

PADIDAN, Pakistan

WMO: 417460

Lat: 26.850N

Lon: 68.133E

Elev: 47

StdP: 100.76

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.0	7.4	1.3	4.2	13.7	3.0	4.7	13.9	3.7	16.8	3.2	16.7	0.2	0	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.0	45.0	25.8	43.6	25.7	42.1	26.0	30.5	38.6	30.0	37.9	29.6	37.4	1.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.6	25.2	36.2	28.2	24.5	35.7	27.7	23.8	35.2	103.9	39.3	101.0	38.3	98.9	37.6	32.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.2	3.3	2.6	4.2	48.0	2.0	1.1	2.7	48.8	1.6	49.5	0.5	50.1	-1.0	50.9		
			3.2	31.8	2.0	0.6	1.8	32.2	0.6	32.5	-0.6	32.9	-2.1	33.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	14.9	17.8	23.9	30.9	35.0	35.2	33.9	32.3	31.3	28.6	22.4	16.7
	DBStd	7.48	2.06	2.91	3.56	2.73	2.00	1.64	1.31	1.25	1.32	2.21	2.65	2.53
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	214	107	39	3	0	0	0	0	0	0	0	1	64
	CDD10.0	6187	153	219	431	628	774	756	742	690	639	577	371	207
	CDD18.3	3359	1	26	176	378	516	506	483	432	389	319	122	13
	CDH23.3	48628	32	301	1983	5309	8388	8247	7572	6289	5376	3820	1188	124
	CDH26.7	31094	1	79	1015	3443	5964	5856	5094	3825	3137	2213	453	14
(14) Wind	WSAvg	1.0	0.7	0.9	1.0	1.2	1.3	1.6	1.3	1.1	0.9	0.6	0.5	0.6
(15) Precipitation	PrecAvg	118	1	5	6	3	2	4	46	27	15	0	1	5
	PrecMax	334	10	15	43	18	13	52	176	158	136	4	9	46
	PrecMin	3	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	101	3	6	11	5	4	12	57	40	32	1	3	11
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	31.2	39.9	44.8	47.3	47.0	42.2	39.7	39.9	39.6	34.9	28.6
		MCWB	17.3	20.2	23.2	25.3	25.4	27.0	29.3	29.9	28.3	25.9	22.2	19.4
	2%	DB	24.1	29.3	37.1	42.8	45.6	44.8	40.8	38.5	38.4	38.0	32.9	26.3
		MCWB	15.9	19.8	22.0	23.8	25.5	26.9	29.5	29.7	28.5	26.0	21.5	18.2
	5%	DB	22.7	26.8	34.6	41.0	44.2	43.0	39.9	37.7	37.5	36.7	31.2	24.7
		MCWB	15.4	18.3	21.6	23.4	25.2	27.1	29.5	29.5	28.3	25.4	21.6	17.1
	10%	DB	21.2	24.9	32.3	39.2	42.7	41.5	38.9	36.8	36.5	35.4	29.5	23.1
		MCWB	14.7	17.1	21.2	22.7	25.3	27.7	29.3	29.2	27.9	24.8	20.5	16.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	22.2	24.6	27.9	29.7	30.9	31.4	30.9	30.5	28.6	24.5	20.3
		MCDB	24.3	29.5	35.4	42.1	41.6	40.7	39.3	38.1	37.4	36.8	31.4	26.9
	2%	WB	17.1	20.6	23.5	26.1	28.6	30.0	30.6	30.2	29.6	27.7	23.1	19.2
		MCDB	22.8	27.2	33.8	39.1	40.4	39.7	38.7	37.1	36.5	35.8	30.6	24.8
	5%	WB	16.0	19.3	22.6	24.8	27.5	29.4	30.1	29.7	29.0	26.8	22.2	18.0
		MCDB	21.6	25.8	32.6	37.0	39.4	39.1	38.1	36.4	35.7	34.5	29.8	23.3
	10%	WB	15.1	17.9	21.6	23.9	26.8	28.9	29.6	29.4	28.4	25.8	21.2	16.8
		MCDB	20.5	23.7	30.9	35.7	38.8	38.4	37.5	35.9	35.1	32.9	28.3	22.1
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	14.2	15.0	16.0	15.9	13.0	10.4	9.5	11.1	13.9	13.7	12.8
		MCDBR	15.0	16.4	17.8	18.4	17.6	16.0	11.7	10.8	12.5	14.9	15.2	13.9
		MCWBR	8.2	8.3	6.6	4.9	4.3	4.2	4.2	4.6	5.1	5.8	6.4	7.2
	5% WB	MCDBR	13.7	15.0	16.1	17.2	16.1	12.3	10.8	10.1	11.4	13.2	13.9	12.8
		MCWBR	8.1	8.6	7.3	5.8	5.5	4.6	4.4	4.6	5.1	5.7	6.6	7.4
(40) Clear-Sky Solar Irradiance	taub		0.480	0.482	0.536	0.604	0.641	0.713	0.792	0.722	0.607	0.557	0.568	0.530
	taud		1.898	1.931	1.818	1.709	1.668	1.577	1.493	1.603	1.773	1.783	1.722	1.785
	Ebn at Noon		741	784	766	728	701	648	597	637	700	704	649	666
	Edh at Noon		171	178	210	241	251	273	296	264	217	203	203	184
(44) All-Sky Solar Radiation	RadAvg		3.92	4.83	5.91	6.70	7.16	6.83	6.17	6.04	5.95	5.35	4.22	3.73
	RadStd		0.20	0.27	0.24	0.19	0.12	0.19	0.34	0.29	0.29	0.21	0.19	0.18

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page