

PASNI, Pakistan

WMO: 417590

Lat: 25.290N

Lon: 63.344E

Elev: 4

StdP: 101.28

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	13.0	-6.5	2.2	18.3	-3.3	2.9	19.0	10.5	22.0	9.1	21.0	1.3	0	0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.5	37.3	25.3	35.7	25.4	34.6	26.1	29.9	33.4	29.2	32.7	28.8	32.3	3.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.0	25.6	32.2	28.4	24.7	31.6	28.0	24.1	31.2	99.6	33.5	96.7	33.1	94.4	32.4	35.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.2	8.0	6.4	9.0	42.5	1.4	2.6	7.9	44.4	7.1	45.9	6.3	47.4	5.2	49.3		
			4.6	31.3	1.9	2.0	3.2	32.7	2.1	33.8	1.0	34.9	-0.4	36.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	19.3	20.5	24.2	27.9	30.4	31.2	30.3	29.3	28.8	27.9	24.1	20.6
	DBStd	4.43	1.77	2.29	2.04	1.77	1.67	1.27	0.93	0.78	1.17	1.53	2.10	1.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	23	11	7	0	0	0	0	0	0	0	0	0	5
	CDD10.0	5924	288	294	439	536	634	637	629	598	564	555	422	327
	CDD18.3	2906	41	68	181	286	376	387	371	340	314	297	172	74
	CDH23.3	34149	178	395	1459	3162	5107	5523	5036	4212	3643	3314	1630	490
	CDH26.7	15536	4	56	461	1372	2712	3127	2558	1774	1462	1419	529	61
Wind	WSAvg	2.2	1.8	2.1	2.3	2.5	2.8	2.6	2.4	2.3	2.3	1.8	1.5	1.8
Precipitation	PrecAvg	99	25	12	14	3	2	11	8	2	1	1	3	17
	PrecMax	240	147	57	70	32	17	138	57	24	19	26	21	104
	PrecMin	1	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	67	34	18	20	7	3	35	15	6	4	5	6	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	30.6	34.9	37.2	41.1	40.2	34.8	33.4	37.0	37.0	33.7	30.0
		MCWB	18.7	20.4	20.8	23.5	28.6	25.8	28.0	26.8	21.9	21.6	20.1	18.1
	2%	DB	26.1	28.5	32.3	35.2	37.8	36.4	33.9	32.7	34.2	35.1	31.9	28.1
		MCWB	18.8	19.3	21.3	23.2	26.9	27.8	28.1	27.0	24.8	21.3	20.8	19.0
	5%	DB	25.2	26.9	30.5	33.7	35.6	34.9	33.3	32.2	32.7	33.5	30.7	26.9
		MCWB	18.6	19.0	21.0	23.9	26.6	28.5	27.9	27.0	25.8	22.5	21.0	18.8
	10%	DB	24.3	25.8	29.0	32.3	34.1	34.1	32.7	31.7	31.7	32.2	29.6	25.9
		MCWB	18.1	18.8	21.1	24.2	27.1	28.4	27.7	26.8	25.9	23.9	21.2	18.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	23.9	25.9	28.7	32.0	30.7	29.5	29.1	28.1	27.9	26.4	23.2
		MCDB	25.2	26.9	29.7	31.6	37.1	34.3	33.1	31.8	31.4	30.8	29.1	26.5
	2%	WB	21.3	22.8	24.2	27.4	30.0	30.0	29.0	28.3	27.6	27.2	25.2	22.1
		MCDB	24.5	25.7	28.3	30.9	34.1	33.3	32.3	31.2	30.9	30.4	28.6	25.8
	5%	WB	20.4	21.7	23.5	26.8	29.1	29.5	28.5	27.7	27.1	26.7	24.4	21.0
		MCDB	23.8	25.0	27.5	30.1	32.8	32.9	32.0	30.7	30.5	29.9	28.1	25.1
	10%	WB	19.6	20.7	22.8	26.2	28.5	29.0	28.1	27.3	26.7	26.2	23.6	20.2
		MCDB	23.1	24.3	26.7	29.6	32.1	32.6	31.6	30.3	30.0	29.2	27.5	24.3
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.5	10.4	9.6	8.5	6.5	4.8	5.3	7.1	9.7	11.2	10.8
		MCDBR	11.1	11.9	12.5	11.7	11.1	7.9	5.5	5.8	8.4	12.2	12.3	12.4
		MCWBR	7.0	6.4	5.9	4.7	4.7	2.8	1.8	1.8	2.9	5.2	6.0	6.9
	5% WB	MCDBR	10.2	10.5	10.5	8.8	9.0	7.0	5.4	5.4	7.4	8.5	9.9	10.5
		MCWBR	7.6	6.8	6.3	4.5	4.4	3.1	2.1	2.2	2.7	4.1	6.0	7.1
Clear-Sky Solar Irradiance	taub	0.406	0.449	0.502	0.563	0.626	0.707	0.774	0.698	0.602	0.510	0.431	0.417	
	taud	2.215	2.092	1.937	1.832	1.734	1.616	1.538	1.649	1.784	1.930	2.140	2.164	
	Ebn at Noon	836	826	801	762	712	653	609	655	708	755	801	804	
	Edh at Noon	126	153	188	214	235	263	284	253	216	178	135	128	
All-Sky Solar Radiation	RadAvg	4.34	5.25	6.30	7.11	7.57	7.29	6.17	6.05	6.16	5.69	4.72	4.14	
	RadStd	0.23	0.23	0.24	0.23	0.10	0.33	0.41	0.28	0.22	0.12	0.14	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page