

HYDERABAD, Pakistan

WMO: 417640

Lat: 25.383N

Lon: 68.417E

Elev: 135

StdP: 14.62

Time Zone: 5.00 (E05)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	50.4	53.1	23.1	17.5	72.6	28.0	22.0	71.4	23.1	66.6	20.9	66.9	3.5	0	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	18.8	108.4	75.1	105.8	75.3	103.5	75.7	83.4	96.0	82.6	94.8	81.9	93.8	14.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	161.4	88.3	80.0	156.6	88.0	79.2	152.5	87.7	47.8	96.3	46.9	94.3	46.1	93.9	90.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.1	32.8	29.0	DB	46.6	113.9	3.9	1.4	43.8	114.9	41.5	115.7	39.4	116.5	36.5	117.6	(4)
(5)			WB	40.7	86.3	4.4	2.1	37.6	87.8	35.0	89.0	32.5	90.2	29.3	91.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	64.6	70.3	80.3	88.8	92.9	92.8	90.4	87.9	87.8	85.9	77.4	67.4	(6)	
	DBStd	10.35	3.98	5.72	5.68	3.43	2.57	2.62	2.53	2.22	2.53	3.12	4.17	4.54	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	103	58	17	1	0	0	0	0	0	0	0	0	27	(9)	
	CDD50	11768	452	567	940	1163	1330	1283	1252	1176	1134	1111	822	538	(10)	
	CDD65	6397	45	164	476	713	865	833	787	711	684	646	372	101	(11)	
	CDH74	84303	288	1335	5374	9864	12919	12611	11292	9449	9079	8120	3337	635	(12)	
	CDH80	49034	27	441	2890	6130	8491	8302	6839	5019	4900	4477	1395	123	(13)	
(14) Wind	WSAvg	11.4	6.1	6.8	7.8	10.9	17.2	19.3	19.4	16.9	13.2	7.2	5.8	6.5	(14)	
(15) Precipitation	PrecAvg	6.5	0.1	0.2	0.2	0.2	0.1	0.3	2.0	2.2	0.7	0.1	0.1	0.0	(15)	
	PrecMax	19.2	0.5	0.6	1.9	1.9	1.9	3.0	8.4	11.2	11.3	1.0	1.3	1.1	(16)	
	PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	5.4	0.1	0.2	0.4	0.5	0.3	0.7	2.3	2.6	2.0	0.2	0.3	0.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.8	92.7	104.3	109.6	112.3	111.7	105.6	101.6	102.7	103.7	96.3	86.9	(19)	
		MCWB	62.6	65.6	68.7	70.7	75.5	75.4	80.4	80.1	75.9	70.1	67.4	65.4	(20)	
	2%	DB	79.9	89.3	100.1	106.1	109.2	106.7	101.3	98.3	100.0	100.6	93.0	83.7	(21)	
		MCWB	61.7	64.8	68.3	71.5	75.1	78.9	81.0	80.1	77.3	71.3	67.4	63.8	(22)	
	5%	DB	77.2	85.6	96.6	103.8	106.6	103.5	99.1	96.1	97.6	98.3	90.6	80.6	(23)	
		MCWB	59.9	63.9	67.5	71.0	75.9	80.0	81.0	80.1	77.8	71.3	66.7	62.4	(24)	
	10%	DB	74.5	82.2	93.5	101.3	104.0	101.3	97.3	94.3	95.4	96.0	87.9	77.5	(25)	
		MCWB	58.6	62.4	67.0	71.4	76.4	80.2	80.9	79.8	77.8	71.3	65.6	60.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.4	70.8	75.3	81.4	84.8	84.5	84.3	83.5	83.2	80.1	74.6	68.5	(27)	
		MCDB	78.4	83.4	93.4	99.6	102.2	98.3	96.3	93.0	93.7	93.0	85.7	80.0	(28)	
	2%	WB	64.3	68.8	72.8	78.7	82.4	83.2	83.2	82.5	81.8	78.8	72.5	66.3	(29)	
		MCDB	74.7	81.3	87.2	95.0	98.1	96.7	94.9	92.4	91.9	90.7	83.1	78.5	(30)	
	5%	WB	62.1	67.3	71.4	77.1	81.1	82.4	82.4	81.7	80.7	77.8	70.9	64.5	(31)	
		MCDB	73.6	79.7	85.8	91.3	95.7	95.8	93.9	91.5	91.3	88.7	82.6	76.5	(32)	
	10%	WB	60.2	65.5	70.0	75.9	80.1	81.7	81.0	81.0	79.8	76.7	69.0	62.8	(33)	
		MCDB	71.7	77.6	84.6	89.3	94.0	94.6	92.8	90.7	90.2	86.8	81.9	74.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.2	21.3	23.5	25.7	24.2	18.8	15.0	14.1	16.6	21.1	20.1	19.0	(35)	
		MCDBR	22.9	25.3	27.9	29.1	28.0	22.6	17.6	16.7	19.6	23.9	23.6	22.6	(36)	
	5% WB	MCWBR	9.6	8.4	7.5	7.5	6.5	4.5	3.6	4.1	4.5	6.2	6.9	8.3	(37)	
		MCWBR	21.7	22.2	25.3	26.6	24.7	19.0	15.7	14.4	16.0	20.0	20.0	20.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.459	0.474	0.534	0.594	0.645	0.719	0.780	0.715	0.614	0.559	0.551	0.513	(40)	
		taud	1.953	1.951	1.817	1.727	1.669	1.570	1.510	1.611	1.765	1.788	1.760	1.824	(41)	
	Ebn at Noon		245	253	245	234	222	205	192	204	222	225	214	220	(42)	
		Edh at Noon	52	56	67	75	80	87	93	83	70	65	63	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		1308	1584	1901	2104	2197	2091	1809	1782	1829	1691	1368	1233	(44)	
	RadStd		55	61	61	58	37	86	115	83	93	65	58	55	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	-0.86	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page