

DHAKA HAZRAT SHAHJALAL INTL, Bangladesh

WMO: 419220

Lat: 23.843N

Lon: 90.398E

Elev: 30

StdP: 14.68

Time Zone: 6.00 (E06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.1	57.1	45.0	44.2	75.2	48.2	49.9	72.6	12.3	69.8	11.8	69.6	3.2	300	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.3	97.0	78.8	95.3	79.1	93.7	79.2	83.7	91.6	83.0	90.2	82.4	89.1	9.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.0	166.6	89.0	80.9	160.6	88.0	80.6	159.0	87.8	47.9	92.2	46.8	91.3	46.1	90.4	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.1	14.3	12.7	52.0	101.2	3.6	3.3	49.4	103.5	47.2	105.5	45.2	107.3	42.5	109.6		
			50.3	86.0	3.4	1.7	47.9	87.2	45.9	88.2	43.9	89.2	41.4	90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	67.3	74.1	81.2	85.3	85.3	85.8	85.3	85.4	85.4	83.5	77.9	70.1
	DBStd	7.22	3.81	3.93	4.10	4.45	3.62	2.98	2.44	2.19	2.34	3.10	3.13	3.90
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	30	23	0	0	0	0	0	0	0	0	0	0	7
	CDD50	11160	538	676	966	1059	1095	1075	1093	1098	1061	1039	838	622
	CDD65	5714	95	256	501	609	630	625	628	633	611	574	388	164
	CDH74	65401	417	1822	5320	7776	8000	8063	7904	8060	7648	6581	3052	758
	CDH80	29056	27	516	2376	4104	3982	3859	3499	3641	3401	2680	881	90
Wind	WSAvg	5.8	3.9	4.5	5.4	7.9	7.9	8.1	8.3	7.3	6.0	4.0	2.7	3.0
Precipitation	PrecAvg	81.3	0.2	0.7	2.2	5.7	11.7	14.4	15.5	12.5	11.3	6.3	1.3	0.4
	PrecMax	118.7	1.9	2.6	7.7	12.5	27.8	33.5	27.3	21.7	27.0	16.8	6.8	3.4
	PrecMin	60.6	0.0	0.0	0.0	0.0	3.7	5.2	5.4	2.3	4.3	1.5	0.0	0.0
	PrecStd	11.9	0.4	0.7	2.1	3.6	5.9	6.4	5.7	5.4	4.6	3.5	1.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	91.2	96.7	100.8	98.5	97.0	95.2	95.0	95.2	94.9	90.0	84.4
		MCWB	65.5	70.2	72.7	75.9	80.0	82.2	82.0	81.2	80.9	79.9	73.6	67.9
	2%	DB	80.5	87.8	94.3	98.2	96.6	95.1	93.2	93.1	93.3	92.8	88.1	82.4
		MCWB	65.4	68.7	72.0	77.1	80.1	81.9	81.4	81.6	81.0	78.9	73.3	68.1
	5%	DB	78.6	85.8	91.8	95.3	94.9	93.3	91.5	91.4	91.6	91.2	86.3	80.6
		MCWB	63.9	67.4	71.7	77.5	80.2	81.8	81.0	81.1	80.5	78.2	72.5	67.3
	10%	DB	76.7	83.3	90.0	93.4	93.0	91.5	89.7	89.7	89.8	89.5	84.5	78.6
		MCWB	63.8	66.8	71.4	77.5	80.1	81.3	80.5	80.5	80.2	77.3	71.4	66.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	75.1	79.5	83.5	84.6	85.1	84.2	84.0	83.7	82.7	77.8	72.1
		MCDB	77.1	82.6	89.7	92.4	94.0	93.5	91.6	91.1	91.0	89.5	84.0	78.0
	2%	WB	67.5	73.1	77.7	81.7	83.1	83.7	82.8	82.8	82.7	81.4	76.4	70.2
		MCDB	75.4	80.8	87.2	91.1	92.1	91.6	89.0	89.2	89.4	87.8	83.1	77.4
	5%	WB	66.2	71.7	76.5	80.6	82.0	82.8	82.0	82.0	81.7	80.3	75.2	69.1
		MCDB	74.7	79.8	85.7	90.4	90.4	89.8	87.9	88.0	88.0	86.6	82.4	76.8
	10%	WB	64.8	69.7	75.3	79.9	81.1	82.0	81.4	81.3	81.0	79.7	74.2	67.9
		MCDB	73.5	79.6	84.9	89.6	89.3	88.6	87.1	87.1	86.9	85.8	81.2	75.8
Mean Daily Temperature Range	5% DB	MDBR	18.4	19.1	18.4	16.2	13.9	10.3	8.6	8.9	9.5	11.6	14.6	16.2
		MCDBR	20.3	20.1	19.5	17.4	15.6	12.8	10.8	10.7	11.4	13.0	15.1	17.3
		MCWBR	8.8	7.3	7.7	7.0	7.1	5.6	4.6	4.6	4.9	5.3	6.0	7.4
	5% WB	MCDBR	18.2	16.9	17.0	16.0	14.3	11.2	9.4	9.2	10.0	11.1	13.5	15.9
		MCWBR	9.4	7.9	8.4	7.8	7.6	6.1	4.8	4.8	5.0	5.2	6.4	8.0
Clear-Sky Solar Irradiance	taub	0.604	0.576	0.600	0.658	0.691	0.644	0.539	0.518	0.534	0.547	0.576	0.594	
	taud	1.703	1.795	1.785	1.735	1.709	1.824	2.106	2.182	2.111	2.018	1.840	1.773	
	Ebn at Noon	205	227	230	220	212	220	245	251	244	232	212	202	
	Edh at Noon	68	66	70	75	76	68	51	47	50	52	59	62	
All-Sky Solar Radiation	RadAvg	1137	1467	1690	1741	1629	1375	1364	1424	1366	1369	1304	1104	
	RadStd	75	89	126	127	153	113	130	116	88	79	75	108	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page