

SRINAGAR, India

WMO: 420270

Lat: 34.0508N

Lon: 74.8045E

Elev: 5207

StdP: 12.13

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.0	27.5	21.6	19.6	34.1	23.1	21.1	32.4	6.9	36.4	5.2	36.8	0.8	140	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	89.1	70.3	87.3	69.6	85.4	68.8	72.7	85.2	71.7	83.8	70.7	81.9	2.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	130.9	79.4	68.3	126.4	78.4	67.4	122.5	77.5	40.4	85.8	39.4	84.3	38.4	82.0	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	4.9	3.5	DB	23.0	91.9	1.5	1.2	21.9	92.8	21.0	93.5	20.2	94.2	19.1	95.1	(4)
(5)			WB	22.1	76.6	1.7	2.9	20.9	78.7	20.0	80.3	19.0	82.0	17.8	84.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.4	37.1	42.5	51.1	58.0	64.5	70.6	75.6	74.4	68.8	58.3	47.2	39.3	(6)	
	DBStd	13.92	3.39	4.18	5.89	5.11	4.90	5.18	3.70	3.87	4.22	5.06	4.32	3.09	(7)	
	HDD50	1110	399	212	58	5	0	0	0	0	0	2	104	330	(8)	
	HDD65	3782	864	630	432	214	70	13	1	1	13	215	534	795	(9)	
	CDD50	3801	0	2	91	245	449	619	794	757	563	260	21	0	(10)	
	CDD65	996	0	0	0	4	54	182	329	293	126	8	0	0	(11)	
	CDH74	8137	0	0	8	91	515	1510	2684	2189	1021	119	0	0	(12)	
	CDH80	2402	0	0	0	4	93	465	918	688	226	8	0	0	(13)	
	WSAvg	1.1	0.9	1.2	1.3	1.4	1.4	1.4	1.3	1.1	1.0	0.8	0.8	0.7	(14)	
	PrecAvg	27.9	2.1	3.0	4.5	3.6	2.6	1.7	2.3	2.5	1.3	1.2	0.9	1.5	(15)	
(16) Precipitation	PrecMax	45.4	6.4	8.3	14.4	7.9	7.5	5.6	7.2	6.7	7.2	5.4	3.8	8.3	(16)	
	PrecMin	16.7	0.0	0.2	0.2	0.0	0.4	0.3	0.3	0.1	0.0	0.0	0.0	0.0	(17)	
	PrecStd	6.2	1.4	1.8	3.0	1.9	1.6	1.1	1.6	1.5	1.4	1.3	1.0	1.8	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	62.3	74.6	80.5	85.8	91.0	90.8	90.4	87.5	81.0	67.3	54.6	(19)	
		MCWB	41.7	46.9	53.7	57.8	63.0	68.8	71.6	71.6	68.1	63.2	51.7	44.1	(20)	
	2%	DB	50.4	57.4	69.9	76.7	82.5	88.1	89.1	88.2	84.9	77.3	63.8	51.5	(21)	
		MCWB	40.8	44.5	51.8	57.0	62.6	68.3	70.9	70.4	66.7	60.1	50.6	42.9	(22)	
	5%	DB	47.4	54.4	66.3	73.2	79.4	85.3	87.4	86.3	82.6	74.1	60.8	49.2	(23)	
		MCWB	39.4	43.7	50.8	55.6	61.6	67.3	70.5	70.1	65.5	58.2	49.1	41.6	(24)	
	10%	DB	44.6	51.3	62.6	69.9	76.3	82.5	85.4	84.2	80.2	70.7	57.6	46.9	(25)	
		MCWB	38.3	42.6	49.3	54.8	60.6	65.8	69.8	69.3	64.3	56.4	47.7	40.2	(26)	
	0.4%	WB	43.5	48.5	56.1	60.3	68.7	72.8	74.5	74.2	70.7	65.1	54.2	45.4	(27)	
		MCDB	49.5	57.6	70.4	74.5	78.9	86.5	87.4	85.8	84.3	77.4	63.3	51.9	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.7	46.2	53.2	58.3	64.6	70.8	72.9	72.6	68.6	61.8	51.7	43.8	(29)	
		MCDB	48.4	54.3	66.1	72.2	78.4	83.5	85.5	84.7	81.0	73.9	62.0	50.1	(30)	
	5%	WB	40.2	44.7	51.5	57.0	62.9	69.1	71.9	71.6	67.3	59.5	49.8	42.2	(31)	
		MCDB	46.2	52.1	63.5	70.1	76.6	81.1	84.2	83.2	78.9	71.5	59.6	48.1	(32)	
	10%	WB	38.7	43.3	50.0	55.6	61.2	67.4	70.9	70.7	65.9	57.5	47.9	40.8	(33)	
		MCDB	43.9	50.0	60.9	67.4	73.9	78.9	82.5	81.2	76.8	68.5	56.5	46.0	(34)	
	5% DB	MDBR	13.6	14.7	17.8	19.2	21.0	19.9	17.6	17.6	22.1	24.4	21.4	16.7	(35)	
		MCDBR	20.3	21.5	24.5	26.5	25.9	23.9	20.7	20.5	24.4	28.1	26.4	20.8	(36)	
		MCWBR	12.2	10.8	10.2	10.3	10.4	8.6	6.9	7.0	9.1	12.4	14.2	12.6	(37)	
		MCDBR	18.2	17.9	21.5	22.5	23.5	21.0	18.1	17.6	21.2	25.9	24.8	18.8	(38)	
(42) Clear-Sky Solar Irradiance	taub		0.331	0.384	0.414	0.442	0.452	0.486	0.499	0.478	0.404	0.374	0.352	0.333	(40)	
		taud	2.196	2.036	2.040	2.045	2.063	2.015	2.041	2.118	2.288	2.260	2.231	2.255	(41)	
	Ebn at Noon		273	268	271	269	267	256	252	256	271	270	263	265	(42)	
		Edh at Noon	36	47	51	53	53	56	54	49	39	37	35	32	(43)	
(44) All-Sky Solar Radiation	RadAvg		863	1030	1448	1735	2029	2061	1836	1704	1654	1467	1066	838	(44)	
	RadStd		132	166	155	144	162	119	138	138	116	100	102	88	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+1.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page