

SRINAGAR, India

WMO: 420270

Lat: 34.0508N

Lon: 74.8045E

Elev: 1587

StdP: 83.66

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.3	-2.5	-5.8	2.8	1.2	-4.9	3.0	0.2	3.1	2.4	2.3	2.7	0.4	140	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	31.7	21.3	30.7	20.9	29.7	20.4	22.6	29.5	22.1	28.8	21.5	27.7	1.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	18.7	26.3	20.1	18.1	25.8	19.7	17.5	25.3	76.2	29.9	73.8	29.1	71.4	27.8	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 2.7	2.2	1.6	-5.0	33.3	0.8	0.7	-5.6	33.8	-6.1	34.2	-6.6	34.5	-7.2	35.0		
(5)			-5.5	24.8	0.9	1.6	-6.2	25.9	-6.7	26.9	-7.2	27.8	-7.9	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	2.9	5.8	10.6	14.4	18.0	21.5	24.2	23.6	20.4	14.6	8.4	4.1	(6)
(7)		DBStd	7.73	1.88	2.32	3.27	2.84	2.72	2.88	2.05	2.15	2.34	2.81	2.40	1.72	(7)
(8)		HDD10.0	617	222	118	32	3	0	0	0	0	0	1	58	183	(8)
(9)		HDD18.3	2101	480	350	240	119	39	7	1	1	7	119	297	442	(9)
(10)		CDD10.0	2112	0	1	51	136	249	344	441	421	313	144	12	0	(10)
(11)		CDD18.3	553	0	0	0	2	30	101	183	163	70	4	0	0	(11)
(12)		CDH23.3	4521	0	0	4	51	286	839	1491	1216	567	66	0	0	(12)
(13)		CDH26.7	1334	0	0	0	2	52	258	510	382	126	4	0	0	(13)
(14)	Wind	WSAvg	0.5	0.4	0.5	0.6	0.6	0.6	0.6	0.5	0.4	0.4	0.3	0.3	(14)	
(15)	Precipitation	PrecAvg	709	54	77	115	91	67	42	59	63	34	30	23	37	(15)
(16)		PrecMax	1154	162	212	365	200	191	142	183	171	184	136	97	210	(16)
(17)		PrecMin	423	1	6	4	1	10	8	8	3	0	0	0	0	(17)
(18)		PrecStd	157	36	46	76	48	41	28	40	38	36	32	25	45	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	16.8	23.6	26.9	29.9	32.8	32.7	32.4	30.8	27.2	19.6	12.6	(19)
(20)			MCWB	5.4	8.3	12.1	14.3	17.2	20.4	22.0	22.0	20.0	17.3	10.9	6.7	(20)
(21)		2%	DB	10.2	14.1	21.0	24.8	28.0	31.2	31.7	31.2	29.4	25.1	17.7	10.8	(21)
(22)			MCWB	4.9	7.0	11.0	13.9	17.0	20.2	21.6	21.4	19.3	15.6	10.3	6.0	(22)
(23)		5%	DB	8.5	12.5	19.1	22.9	26.3	29.6	30.8	30.2	28.1	23.4	16.0	9.5	(23)
(24)			MCWB	4.1	6.5	10.4	13.1	16.5	19.6	21.4	21.2	18.6	14.6	9.5	5.3	(24)
(25)		10%	DB	7.0	10.7	17.0	21.0	24.6	28.0	29.7	29.0	26.8	21.5	14.2	8.3	(25)
(26)			MCWB	3.5	5.9	9.6	12.7	15.9	18.8	21.0	20.7	17.9	13.6	8.7	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	9.2	13.4	15.7	20.4	22.7	23.6	23.4	21.5	18.4	12.3	7.5	(27)
(28)			MCDWB	9.7	14.2	21.3	23.6	26.1	30.3	30.8	29.9	29.1	25.2	17.4	11.0	(28)
(29)		2%	WB	5.4	7.9	11.8	14.6	18.1	21.6	22.7	22.6	20.3	16.6	10.9	6.6	(29)
(30)			MCDWB	9.1	12.4	18.9	22.3	25.8	28.6	29.7	29.3	27.2	23.3	16.7	10.0	(30)
(31)		5%	WB	4.6	7.1	10.8	13.9	17.1	20.6	22.2	22.0	19.6	15.3	9.9	5.7	(31)
(32)			MCDWB	7.9	11.2	17.5	21.2	24.8	27.3	29.0	28.5	26.1	21.9	15.3	8.9	(32)
(33)		10%	WB	3.7	6.3	10.0	13.1	16.2	19.7	21.6	21.5	18.8	14.2	8.9	4.9	(33)
(34)			MCDWB	6.6	10.0	16.0	19.6	23.3	26.0	28.0	27.3	24.9	20.3	13.6	7.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	8.2	9.9	10.7	11.6	11.1	9.8	9.8	12.3	13.5	11.9	9.3	(35)
(36)			MCDBR	11.3	11.9	13.6	14.7	14.4	13.3	11.5	11.4	13.6	15.6	14.7	11.6	(36)
(37)			MCWBR	6.8	6.0	5.7	5.7	5.8	4.8	3.8	3.9	5.0	6.9	7.9	7.0	(37)
(38)		5% WB	MCDWR	10.1	9.9	11.9	12.5	13.0	11.7	10.1	9.8	11.8	14.4	13.8	10.4	(38)
(39)			MCWBR	6.3	5.2	5.2	5.4	5.9	4.8	3.8	3.9	4.9	6.8	7.7	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.384	0.414	0.442	0.452	0.486	0.499	0.478	0.404	0.374	0.352	0.333	(40)	
(41)		taud	2.196	2.036	2.040	2.045	2.063	2.015	2.041	2.118	2.288	2.260	2.231	2.255	(41)	
(42)		Ebn at Noon	862	845	853	847	841	808	795	806	855	851	830	836	(42)	
(43)		Edh at Noon	113	149	161	168	167	175	170	154	124	117	109	101	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.72	3.25	4.56	5.47	6.40	6.50	5.79	5.37	5.21	4.62	3.36	2.64	(44)	
(45)		RadStd	0.41	0.52	0.49	0.45	0.51	0.38	0.43	0.43	0.37	0.32	0.32	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page