

AMRITSAR, India

WMO: 420710

Lat: 31.710N

Lon: 74.797E

Elev: 756

StdP: 14.30

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.3	38.9	33.4	28.8	45.4	35.4	31.2	47.5	13.6	59.1	11.8	60.7	0.5	270	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	22.9	108.0	73.4	105.6	73.5	102.5	73.2	86.0	89.9	84.6	90.4	83.8	90.4	7.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
85.7	194.1	87.4	83.9	182.9	86.9	82.3	173.4	87.2	51.9	87.5	50.0	90.4	48.9	92.0	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.2	(b) 12.3	(c) 10.4	(e) 32.8	(f) 113.1	(g) 2.0	(h) 2.0	(i) 31.4	(j) 114.6	(k) 30.2	(l) 115.8	(m) 29.1	(n) 116.9	(o) 27.6	(p) 118.4		
(a) 32.4	(b) 87.2	(c) 2.2	(e) 1.9	(f) 30.9	(g) 88.5	(h) 29.6	(i) 89.6	(j) 28.4	(k) 90.7	(l) 26.8	(m) 92.1	(n) 26.8	(o) 92.1	(p) 92.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	51.9	58.3	67.3	78.8	87.9	89.6	86.6	85.5	82.8	76.4	65.2	55.0
	DBStd	13.80	4.09	4.46	5.44	5.88	4.68	5.10	3.63	3.07	2.97	4.31	4.02	4.24
	HDD50	37	27	2	0	0	0	0	0	0	0	0	0	8
	HDD65	988	405	191	38	0	0	0	0	0	0	0	45	309
	CDD50	8747	87	234	537	863	1176	1189	1134	1102	985	818	457	165
	CDD65	4223	0	4	110	413	711	739	669	637	535	353	52	0
	CDH74	57157	2	66	1280	5341	10783	11419	9309	8392	6279	3562	704	20
	CDH80	31930	0	2	417	3093	7074	7448	5068	4214	2944	1556	114	0
(14) Wind	WSAvg	3.1	2.2	3.2	3.6	4.5	4.9	4.9	3.4	2.5	2.3	1.8	1.6	1.6
(15) Precipitation	PrecAvg	26.5	1.0	1.5	1.2	0.6	0.7	2.8	7.6	7.1	3.5	0.4	0.2	0.4
	PrecMax	40.3	3.1	4.7	4.5	2.3	2.5	9.1	18.0	18.0	16.4	2.4	1.9	1.8
	PrecMin	16.1	0.0	0.0	0.0	0.0	0.0	0.0	2.3	0.4	0.1	0.0	0.0	0.0
	PrecStd	7.2	0.9	1.5	1.2	0.7	0.7	2.0	3.9	4.5	3.3	0.7	0.4	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.4	79.1	91.8	106.8	111.5	111.5	103.8	97.7	96.8	93.6	86.0	76.8
		MCWB	57.4	63.9	69.7	69.2	71.6	74.4	80.0	82.9	79.2	75.5	68.2	59.3
	2%	DB	68.3	75.6	88.0	102.6	108.0	109.2	100.1	95.7	94.9	91.8	83.1	73.4
		MCWB	56.7	62.1	69.0	69.7	72.5	74.3	81.2	82.5	79.4	75.0	66.4	59.2
	5%	DB	66.1	73.3	84.4	99.0	105.7	105.9	97.0	94.7	93.2	90.1	80.9	70.5
		MCWB	55.9	60.9	67.5	68.8	72.1	75.4	82.0	82.4	80.0	73.9	65.3	58.1
	10%	DB	63.6	70.0	81.0	95.1	102.6	103.0	94.9	93.0	91.5	88.1	78.7	68.0
		MCWB	54.8	59.1	66.1	68.2	71.7	75.3	81.9	82.3	79.4	73.1	63.7	56.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.9	67.1	74.7	75.5	81.2	85.3	88.2	88.0	85.0	82.8	71.7	63.9
		MCDB	66.3	73.5	83.5	94.4	100.9	92.2	90.5	89.3	88.9	87.7	81.4	70.0
	2%	WB	59.3	64.7	71.5	72.9	78.4	83.6	86.2	85.9	83.5	79.3	69.4	61.3
		MCDB	64.0	72.2	83.3	91.9	98.0	93.8	90.0	89.8	89.1	86.4	80.4	69.6
	5%	WB	57.3	62.7	69.4	71.4	76.5	82.1	84.9	84.6	82.4	77.4	67.3	59.7
		MCDB	63.0	69.9	81.3	89.9	96.4	93.4	90.5	89.9	88.7	85.9	77.8	67.7
	10%	WB	55.7	60.8	67.4	70.0	74.8	80.7	83.8	83.7	81.2	75.4	65.3	57.8
		MCDB	61.5	68.0	78.7	88.6	94.8	93.1	90.6	89.6	88.0	84.6	75.5	65.7
(35) Mean Daily Temperature Range	5% DB	MDBR	22.4	23.5	25.4	29.1	28.1	22.9	14.1	13.4	17.1	23.7	27.5	25.2
		MCDBR	27.0	26.9	29.2	34.2	31.5	28.6	17.6	15.4	19.0	24.2	29.3	29.5
		MCWBR	16.5	14.8	13.2	10.0	9.6	8.3	7.2	6.7	8.5	10.0	14.6	16.9
	5% WB	MCDBR	23.2	23.1	26.5	30.0	28.4	20.2	14.0	13.4	15.8	20.1	26.9	26.5
		MCWBR	16.2	14.7	13.2	11.0	11.8	9.6	7.6	7.4	8.5	10.1	15.5	17.5
(40) Clear-Sky Solar Irradiance	taub		0.483	0.494	0.510	0.566	0.646	0.737	0.776	0.686	0.596	0.639	0.597	0.527
	taud		1.863	1.888	1.883	1.801	1.665	1.543	1.518	1.677	1.811	1.629	1.657	1.776
	Ebn at Noon		222	237	245	237	220	200	191	207	220	193	185	198
	Edh at Noon		53	56	61	69	79	89	91	77	65	72	65	55
(44) All-Sky Solar Radiation	RadAvg		912	1238	1662	1992	2212	2064	1719	1651	1650	1483	1144	942
	RadStd		102	136	110	94	78	128	127	129	89	78	59	60

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page