

LILABARI, India

WMO: 423090

Lat: 27.295N

Lon: 94.098E

Elev: 330

StdP: 14.52

Time Zone: 5.50 (IND)

Period: 91-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 48.0	(c) 49.8	(d) 46.4	(e) 47.2	(f) 49.2	(g) 48.0	(h) 50.2	(i) 51.1	(j) 9.5	(k) 69.6	(l) 7.7	(m) 69.5	(n) 0.3	(o) 50	(p) 0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.0	(c) 95.8	(d) 84.2	(e) 94.3	(f) 83.6	(g) 92.6	(h) 82.7	(i) 85.5	(j) 92.5	(k) 84.9	(l) 91.8	(m) 84.2	(n) 90.8	(o) 4.1	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.8	179.3	90.0	83.1	175.1	89.5	82.5	171.3	89.0	50.6	93.1	49.9	92.7	49.0	90.9	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.7	9.0	7.4	43.7	99.0	4.9	2.1	40.2	100.5	37.4	101.7	34.6	102.9	31.1	104.5
			44.4	86.4	1.6	1.1	43.3	87.2	42.4	87.8	41.5	88.4	40.4	89.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.1	62.7	66.7	71.4	74.5	79.3	82.0	83.3	83.7	82.5	79.2	70.7	64.5
	DBStd	8.14	2.86	3.47	3.85	3.81	4.08	3.62	2.94	3.31	3.22	3.88	3.49	2.87
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	153	82	22	4	0	0	0	0	0	0	0	2	43
	CDD50	9148	392	467	662	734	908	961	1032	1043	975	904	620	450
	CDD65	3827	9	68	201	284	443	511	567	578	525	439	173	29
	CDH74	37890	237	559	1444	1842	3967	5363	6553	6795	5641	3905	1252	332
	CDH80	13805	11	92	469	634	1542	1918	2485	2760	2099	1473	308	14
(14) Wind	WSAvg	2.1	1.5	1.9	2.5	2.5	2.5	2.6	2.7	2.4	2.0	1.6	1.4	1.3
(15) Precipitation	PrecAvg	142.8	1.2	2.5	3.9	8.3	16.4	28.9	26.2	24.1	20.8	7.1	1.2	0.7
	PrecMax	171.9	4.4	5.2	8.7	15.3	29.4	43.1	41.2	42.0	32.3	19.0	2.8	2.1
	PrecMin	101.8	0.1	0.3	1.3	1.7	7.8	16.8	17.5	12.5	11.5	1.7	0.3	0.1
	PrecStd	15.8	1.0	1.3	2.3	3.1	5.5	6.9	5.6	6.7	6.6	4.0	0.8	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	86.0	91.2	93.5	95.4	97.5	96.6	97.9	96.5	95.0	88.7	81.9
		MCWB	66.3	68.9	72.7	75.2	81.6	84.1	84.4	85.9	84.9	84.2	75.5	69.8
	2%	DB	79.2	82.6	87.8	89.9	93.0	94.4	94.6	95.3	94.2	91.9	85.8	79.7
		MCWB	65.7	67.2	71.3	75.4	81.0	83.8	84.4	84.8	84.0	82.0	73.6	67.6
	5%	DB	76.8	80.2	85.1	87.2	90.6	91.6	92.3	93.4	92.1	89.9	83.5	78.0
		MCWB	64.8	66.7	70.1	75.1	80.0	83.2	83.8	84.4	83.1	80.3	72.1	66.5
	10%	DB	74.0	77.6	82.1	84.0	88.3	88.9	90.0	91.0	89.8	87.5	81.2	75.8
		MCWB	63.7	65.8	69.2	74.1	79.3	82.4	83.4	83.6	82.5	78.5	70.7	65.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.0	71.3	75.4	79.1	84.0	85.4	86.1	86.4	85.9	85.4	77.1	71.1
		MCDB	77.6	80.3	86.6	87.5	92.6	92.5	93.0	94.3	93.2	92.9	85.8	79.0
	2%	WB	66.7	69.4	73.3	77.3	82.0	84.6	85.3	85.4	84.8	83.2	74.9	69.2
		MCDB	76.3	79.2	84.6	86.2	89.9	91.7	91.9	92.6	91.9	90.1	83.6	77.5
	5%	WB	65.5	67.9	71.8	76.0	81.0	83.7	84.5	84.9	83.9	81.5	73.4	67.7
		MCDB	74.8	77.1	81.7	84.3	88.8	90.3	90.6	91.7	90.4	88.0	81.5	75.7
	10%	WB	64.2	66.5	70.2	74.6	79.8	82.7	83.5	84.0	82.9	80.0	72.0	66.4
		MCDB	72.9	75.1	79.2	81.8	86.8	88.5	88.9	90.0	88.5	85.8	79.2	73.9
(35) Mean Daily Temperature Range	5% DB	MDBR	25.1	22.1	19.6	14.4	13.2	10.5	10.3	11.0	11.6	16.2	22.5	24.5
		MCDBR	29.6	27.5	26.7	22.8	18.6	15.6	15.1	16.0	16.7	18.9	24.5	26.5
		MCWBR	17.1	13.9	12.3	10.4	9.0	7.2	6.7	7.4	8.2	9.5	13.2	15.4
	5% WB	MCDBR	27.6	25.3	23.8	18.8	17.0	13.7	13.2	14.2	14.8	17.1	22.3	24.1
		MCWBR	16.9	13.9	12.2	9.9	8.9	7.1	6.9	7.2	7.9	9.3	13.0	15.1
(40) Clear-Sky Solar Irradiance	taub		0.565	0.629	0.712	0.688	0.576	0.520	0.457	0.469	0.469	0.438	0.458	0.482
	taud		1.786	1.682	1.561	1.672	1.961	2.168	2.361	2.314	2.293	2.334	2.175	2.055
	Ebn at Noon		209	207	200	212	237	249	265	262	259	260	242	228
	Edh at Noon		61	73	86	79	59	48	39	41	41	37	41	45
(44) All-Sky Solar Radiation	RadAvg		1079	1149	1241	1248	1356	1262	1307	1333	1262	1304	1209	1094
	RadStd		113	126	128	117	166	128	133	154	128	110	104	75

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page