

DIBRUGARH, India

WMO: 423140

Lat: 27.484N

Lon: 95.017E

Elev: 362

StdP: 14.50

Time Zone: 5.50 (IND)

Period: 95-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.9	51.7	46.7	47.8	59.2	48.0	50.2	59.4	10.1	64.6	9.4	66.2	0.3	50	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	95.2	82.0	93.6	81.5	92.2	80.9	84.1	92.0	83.3	90.7	82.5	89.5	5.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.0	169.0	89.1	81.3	165.0	88.1	80.7	161.4	87.2	48.8	92.4	47.8	91.0	47.0	89.6	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.0	9.0	46.1	98.6	2.9	2.0	44.0	100.0	42.3	101.1	40.7	102.3	38.6	103.7		
(5)			45.1	85.2	2.5	0.9	43.3	85.9	41.9	86.5	40.5	87.0	38.6	87.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.1	62.9	66.6	72.1	74.3	79.2	82.1	83.3	83.1	82.5	78.9	71.0	64.9
	DBStd	8.03	2.87	3.62	3.51	4.25	4.30	3.79	3.22	3.36	3.77	3.53	3.28	2.89
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	141	78	22	2	0	0	0	0	0	0	0	2	37
	CDD50	9172	399	464	685	730	907	962	1034	1027	976	896	630	462
	CDD65	3837	11	66	222	280	442	512	569	562	526	431	182	34
	CDH74	38162	134	439	1442	1851	4121	5649	6806	6634	5898	3857	1093	238
	CDH80	14147	2	63	421	635	1552	2133	2731	2644	2369	1357	223	17
Wind	WSAvg	3.0	1.7	2.6	3.6	4.6	3.8	4.0	3.7	3.2	3.1	2.0	1.6	1.4
Precipitation	PrecAvg	99.8	1.1	2.2	4.3	9.3	11.6	15.7	20.2	16.8	12.5	4.6	0.9	0.6
	PrecMax	126.1	3.4	5.8	9.9	22.2	29.2	36.0	30.2	30.5	26.3	14.1	5.4	2.4
	PrecMin	74.1	0.0	0.2	0.7	1.5	3.4	5.9	9.8	5.5	2.1	0.3	0.0	0.0
	PrecStd	14.4	0.9	1.4	2.5	3.9	5.4	5.6	4.2	5.7	5.2	3.0	1.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.8	85.1	90.1	92.9	95.5	96.9	96.5	96.2	96.2	93.3	86.7	82.2
		MCWB	63.7	65.7	69.6	73.2	79.4	83.4	82.6	82.7	82.7	80.2	71.8	68.3
	2%	DB	77.3	81.6	87.4	89.9	92.8	93.3	94.5	94.1	94.0	91.0	84.5	78.7
		MCWB	62.7	64.7	68.8	73.2	78.6	82.0	82.5	82.9	81.9	79.3	70.1	64.9
	5%	DB	75.1	79.1	84.6	86.9	90.4	91.4	92.6	92.2	92.3	88.8	82.7	76.5
		MCWB	61.6	64.0	67.9	72.9	77.8	81.5	82.2	82.3	81.4	77.4	69.2	63.8
	10%	DB	72.6	76.4	82.0	83.7	87.9	89.3	90.1	90.2	90.1	86.7	80.6	74.5
		MCWB	61.0	63.3	67.1	71.8	77.4	80.9	81.7	81.7	80.8	76.0	68.4	62.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	69.2	73.7	76.9	82.3	84.6	84.8	85.1	84.4	82.5	73.9	69.2
		MCDB	75.7	78.6	82.7	85.7	91.0	93.5	92.9	93.0	93.6	90.6	83.6	79.6
	2%	WB	64.3	67.0	71.5	75.4	80.6	83.3	83.7	84.0	83.2	80.6	72.0	67.0
		MCDB	73.8	76.4	80.9	84.8	89.1	91.0	91.3	91.3	91.4	88.2	80.7	76.1
	5%	WB	62.8	65.6	70.0	74.2	79.3	82.3	82.8	83.1	82.3	79.2	70.7	65.3
		MCDB	71.8	74.4	80.1	83.1	87.2	89.3	89.8	89.8	89.8	86.2	79.0	73.6
	10%	WB	61.6	64.4	68.8	72.9	78.2	81.4	82.0	82.2	81.4	77.9	69.6	63.9
		MCDB	70.2	73.3	78.1	81.1	85.4	87.7	88.3	88.4	88.1	84.1	77.8	71.7
Mean Daily Temperature Range	5% DB	MDBR	21.0	19.5	17.9	13.4	12.0	9.8	9.7	9.6	11.4	14.9	19.2	21.5
		MCDBR	25.6	25.1	24.3	20.6	17.3	14.0	14.2	13.9	15.4	17.4	22.4	23.6
		MCWBR	12.1	10.2	9.1	7.9	7.0	5.9	5.7	5.8	6.4	7.5	9.8	11.1
	5% WB	MCDBR	22.4	20.6	19.7	16.9	14.6	12.5	12.2	12.5	13.8	15.0	19.0	20.8
		MCWBR	11.6	9.6	8.9	7.7	6.8	6.1	5.6	5.8	6.3	7.2	9.1	10.7
Clear-Sky Solar Irradiance	taub	0.540	0.608	0.706	0.667	0.558	0.507	0.448	0.462	0.459	0.422	0.425	0.452	
	taud	1.834	1.714	1.561	1.703	2.000	2.201	2.382	2.328	2.312	2.364	2.276	2.133	
	Ebn at Noon	216	213	201	216	242	252	268	264	262	265	253	239	
	Edh at Noon	58	70	86	77	57	46	39	41	40	36	37	41	
All-Sky Solar Radiation	RadAvg	1105	1189	1290	1285	1412	1327	1335	1374	1315	1348	1233	1119	
	RadStd	108	128	146	130	173	145	134	158	133	115	95	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page