

JAIPUR, India

WMO: 423480

Lat: 26.8212N

Lon: 75.8175E

Elev: 1263

StdP: 14.04

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.0	47.6	20.8	16.3	77.3	24.7	19.7	77.5	12.9	62.7	11.6	63.0	1.2	90	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	21.4	108.9	69.7	106.2	70.0	104.0	70.1	81.9	87.5	81.0	86.9	80.3	86.5	9.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	167.7	83.8	79.8	162.0	83.5	79.0	157.6	83.3	47.3	88.3	46.2	86.9	45.5	87.3	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.6	14.0	12.1	DB	39.9	112.6	2.6	2.1	38.0	114.2	36.5	115.4	35.0	116.6	33.1	118.2
			WB	37.4	84.5	1.9	2.0	36.1	85.9	35.0	87.1	33.9	88.2	32.6	89.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.2	60.2	66.9	77.3	87.7	93.6	92.6	86.7	83.8	84.5	81.3	72.2	63.4
	DBStd	11.65	4.44	5.29	5.82	5.04	4.62	5.22	4.33	2.76	3.19	4.02	4.19	4.45
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	285	160	37	1	0	0	0	0	0	0	0	3	84
	CDD50	10667	317	473	845	1131	1351	1279	1137	1047	1034	971	665	417
	CDD65	5474	12	89	380	681	886	829	672	582	584	506	217	36
	CDH74	74054	118	805	4358	10203	14529	13148	8960	6770	7118	5783	1917	345
	CDH80	42360	8	217	2132	6442	10185	8936	4724	2743	3419	2899	620	35
Wind	WSAvg	4.9	3.3	4.3	4.8	5.5	6.8	7.2	6.4	5.9	4.9	3.6	2.8	2.9
Precipitation	PrecAvg	22.1	0.2	0.5	0.2	0.2	0.7	1.9	6.9	8.2	2.6	0.8	0.2	0.2
	PrecMax	38.8	1.1	3.0	1.4	1.3	3.5	12.6	15.3	20.0	10.9	5.5	1.0	1.4
	PrecMin	9.4	0.0	0.0	0.0	0.0	0.0	0.0	1.7	2.2	0.0	0.0	0.0	0.0
	PrecStd	7.3	0.3	0.7	0.3	0.3	0.9	2.4	3.5	4.5	2.6	1.4	0.3	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.8	89.8	101.4	107.6	111.4	111.5	104.2	97.1	100.2	98.8	91.2	83.2
		MCWB	59.4	61.9	63.2	66.3	70.0	70.0	75.4	76.6	71.6	66.9	64.2	61.0
	2%	DB	77.1	85.9	96.9	104.9	109.4	108.5	100.5	93.6	97.1	96.6	88.0	80.6
		MCWB	57.7	60.9	63.2	66.6	69.2	71.5	76.7	77.9	72.7	67.5	63.3	59.3
	5%	DB	74.4	82.3	93.5	102.5	107.4	105.8	97.3	91.7	95.1	94.3	86.0	78.2
		MCWB	56.2	59.7	62.6	66.0	69.1	72.9	77.2	78.4	73.5	67.8	62.3	58.3
	10%	DB	71.5	78.8	90.5	100.3	105.1	102.8	95.0	89.8	93.0	92.1	83.9	75.2
		MCWB	54.8	58.4	61.8	65.5	69.2	73.6	77.4	78.4	73.9	66.9	61.7	56.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.4	66.0	68.7	74.4	77.9	81.8	83.5	82.8	82.5	77.9	71.6	64.9
		MCDB	74.7	82.0	87.8	99.9	97.9	90.7	89.1	87.3	86.7	87.3	79.3	78.2
	2%	WB	60.9	63.9	66.8	71.0	75.9	80.3	82.1	81.7	80.7	75.7	68.1	62.5
		MCDB	69.6	77.6	86.3	95.2	96.4	90.1	87.8	86.8	86.0	85.0	79.4	73.7
	5%	WB	59.0	62.2	65.4	69.2	74.4	79.1	81.1	80.9	79.3	74.0	65.8	60.5
		MCDB	69.1	75.1	85.1	94.2	96.1	90.2	87.2	86.0	85.4	83.5	80.5	72.8
	10%	WB	57.2	60.7	63.9	67.6	73.0	78.2	80.4	80.2	78.2	72.0	63.9	58.6
		MCDB	67.1	73.7	84.0	93.4	96.0	90.6	86.8	85.2	84.9	83.4	78.9	71.2
Mean Daily Temperature Range	5% DB	MDBR	21.8	21.9	23.1	23.0	21.4	18.0	13.1	11.6	15.6	21.2	23.0	22.9
		MCDBR	24.3	25.4	26.1	24.3	22.6	20.3	16.6	14.7	18.9	22.6	24.5	25.6
		MCWBR	9.6	8.8	7.9	7.5	7.2	6.5	4.6	4.7	5.7	7.0	8.5	9.9
	5% WB	MCDBR	19.7	20.5	22.7	22.8	21.1	16.6	12.8	11.3	13.3	17.0	19.8	21.7
		MCWBR	9.5	8.3	7.9	8.6	7.8	5.9	5.2	4.9	5.7	6.4	8.6	9.6
Clear-Sky Solar Irradiance	taub		0.435	0.424	0.459	0.528	0.602	0.674	0.683	0.605	0.532	0.531	0.514	0.474
	taud		1.995	2.083	2.006	1.866	1.743	1.649	1.667	1.846	1.981	1.863	1.833	1.895
	Ebn at Noon		250	267	265	250	231	214	212	228	241	231	222	229
	Edh at Noon		49	48	55	65	74	81	79	66	56	60	57	52
All-Sky Solar Radiation	RadAvg		1214	1560	1934	2199	2256	1997	1613	1547	1718	1642	1307	1165
	RadStd		83	78	81	58	59	110	143	148	138	74	100	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	+0.31	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	+0.31	N/A	N/A	N/A	N/A

Nomenclature: See separate page