

JAIPUR, India

WMO: 423480

Lat: 26.8212N

Lon: 75.8175E

Elev: 385

StdP: 96.78

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 7.2	(c) 8.7	(d) -6.2	(e) 2.3	(f) 25.2	(g) -4.0	(h) 2.8	(i) 25.3	(j) 5.8	(k) 17.1	(l) 5.2	(m) 17.2	(n) 0.5	(o) 90	(p) 0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 11.9	(c) 42.7	(d) 20.9	(e) 41.2	(f) 21.1	(g) 40.0	(h) 21.1	(i) 27.7	(j) 30.8	(k) 27.2	(l) 30.5	(m) 26.9	(n) 30.3	(o) 4.3	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	24.0	28.8	26.5	23.1	28.6	26.1	22.5	28.5	92.1	31.3	89.6	30.5	87.9	30.7	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.4	(b) 6.2	(c) 5.4	(e) 4.4	(f) 44.8	(g) 1.5	(h) 1.2	(i) 3.4	(j) 45.6	(k) 2.5	(l) 46.3	(m) 1.7	(n) 47.0	(o) 0.6	(p) 47.9		
(a) 7.4	(b) 6.2	(c) 5.4	(e) 3.0	(f) 29.2	(g) 1.0	(h) 1.1	(i) 2.3	(j) 30.0	(k) 1.6	(l) 30.6	(m) 1.1	(n) 31.2	(o) 0.3	(p) 32.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	15.7	19.4	25.1	30.9	34.2	33.7	30.4	28.8	29.2	27.4	22.3	17.5
	DBStd	6.47	2.47	2.94	3.24	2.80	2.56	2.90	2.41	1.54	1.77	2.23	2.33	2.47
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	158	89	21	1	0	0	0	0	0	0	0	2	47
	CDD10.0	5926	176	263	469	628	751	711	632	582	574	539	369	232
	CDD18.3	3041	7	49	211	378	492	461	373	323	324	281	121	20
	CDH23.3	41141	66	447	2421	5668	8072	7304	4978	3761	3954	3213	1065	192
	CDH26.7	23533	4	121	1184	3579	5658	4964	2624	1524	1899	1611	344	19
(14) Wind	WSAvg	2.2	1.5	1.9	2.2	2.5	3.0	3.2	2.9	2.6	2.2	1.6	1.2	1.3
(15) Precipitation	PrecAvg	562	5	12	4	5	17	49	176	208	65	21	4	4
	PrecMax	985	28	77	35	32	90	319	388	508	277	140	26	36
	PrecMin	239	0	0	0	0	0	1	44	57	0	0	0	0
	PrecStd	186	8	18	7	8	24	60	89	114	65	36	7	8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.1	32.1	38.5	42.0	44.1	44.1	40.1	36.2	37.9	37.1	32.9	28.4
		MCWB	15.2	16.6	17.3	19.0	21.1	21.1	24.1	24.8	22.0	19.4	17.9	16.1
	2%	DB	25.1	29.9	36.1	40.5	43.0	42.5	38.0	34.2	36.2	35.9	31.1	27.0
		MCWB	14.3	16.0	17.3	19.2	20.7	21.9	24.9	25.5	22.6	19.7	17.4	15.2
	5%	DB	23.6	27.9	34.2	39.2	41.9	41.0	36.3	33.2	35.1	34.6	30.0	25.7
		MCWB	13.5	15.4	17.0	18.9	20.6	22.7	25.1	25.8	23.1	19.9	16.8	14.6
	10%	DB	22.0	26.0	32.5	38.0	40.6	39.3	35.0	32.1	33.9	33.4	28.8	24.0
		MCWB	12.7	14.6	16.6	18.6	20.6	23.1	25.2	25.8	23.3	19.4	16.5	13.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.9	20.4	23.6	25.5	27.7	28.6	28.2	28.0	25.5	22.0	18.3
		MCDB	23.7	27.8	31.0	37.7	36.6	32.6	31.7	30.7	30.4	30.7	26.3	25.7
	2%	WB	16.1	17.7	19.3	21.7	24.4	26.8	27.8	27.6	27.1	24.3	20.0	16.9
		MCDB	20.9	25.3	30.2	35.1	35.8	32.3	31.0	30.4	30.0	29.4	26.3	23.2
	5%	WB	15.0	16.8	18.5	20.6	23.6	26.2	27.3	27.1	26.3	23.3	18.8	15.8
		MCDB	20.6	23.9	29.5	34.6	35.6	32.3	30.7	30.0	29.7	28.6	26.9	22.6
	10%	WB	14.0	15.9	17.7	19.8	22.8	25.7	26.9	26.8	25.7	22.2	17.7	14.8
		MCDB	19.5	23.2	28.9	34.1	35.6	32.5	30.5	29.6	29.4	28.6	26.1	21.8
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.1	12.8	12.8	11.9	10.0	7.3	6.4	8.7	11.8	12.8	12.7
		MCDBR	13.5	14.1	14.5	13.5	12.6	11.3	9.2	8.1	10.5	12.5	13.6	14.2
		MCWBR	5.3	4.9	4.4	4.1	4.0	3.6	2.5	2.6	3.2	3.9	4.7	5.5
	5% WB	MCDBR	11.0	11.4	12.6	12.7	11.7	9.2	7.1	6.3	7.4	9.5	11.0	12.0
		MCWBR	5.3	4.6	4.4	4.8	4.3	3.3	2.9	2.7	3.2	3.6	4.8	5.3
(40) Clear-Sky Solar Irradiance	taub		0.435	0.424	0.459	0.528	0.602	0.674	0.683	0.605	0.532	0.531	0.514	0.474
	taud		1.995	2.083	2.006	1.866	1.743	1.649	1.667	1.846	1.981	1.863	1.833	1.895
	Ebn at Noon		788	842	835	787	729	674	667	718	761	728	700	723
	Edh at Noon		154	152	174	206	233	254	249	207	176	188	181	164
(44) All-Sky Solar Radiation	RadAvg		3.83	4.92	6.10	6.93	7.11	6.30	5.08	4.88	5.42	5.17	4.12	3.67
	RadStd		0.26	0.25	0.26	0.18	0.19	0.35	0.45	0.47	0.44	0.23	0.31	0.16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	+0.17	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	+0.17	N/A	N/A	N/A

Nomenclature: See separate page