

GUWAHATI INTL, India

WMO: 424100

Lat: 26.106N

Lon: 91.586E

Elev: 49

StdP: 100.73

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	11.9	8.4	6.9	20.2	9.8	7.5	18.0	5.0	23.6	4.4	23.2	0.1	180	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	35.2	27.8	34.4	27.6	33.6	27.4	29.5	33.3	29.1	32.8	28.7	32.1	3.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.8	25.4	31.6	28.2	24.5	31.1	27.9	24.1	30.8	98.2	33.4	95.9	32.8	94.0	32.4	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.6	4.1	9.1	37.4	1.0	1.1	8.3	38.1	7.7	38.7	7.1	39.3	6.4	40.1
			8.8	30.2	1.0	0.7	8.1	30.7	7.5	31.2	7.0	31.6	6.2	32.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.1	17.8	20.3	23.8	25.8	27.5	28.9	29.5	29.7	28.9	26.9	23.1	19.3	(6)
(7)		DBStd	4.39	1.69	1.97	1.97	2.12	1.77	1.58	1.37	1.35	1.43	1.70	1.84	1.58	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	43	31	5	0	0	0	0	0	0	0	0	0	8	(9)
(10)		CDD10.0	5522	241	287	427	474	544	568	604	609	566	523	392	288	(10)
(11)		CDD18.3	2524	13	59	169	224	286	318	346	351	316	264	142	37	(11)
(12)		CDH23.3	26749	99	445	1495	2020	3016	3828	4316	4393	3647	2469	838	183	(12)
(13)	CDH26.7	10578	3	84	581	825	1173	1581	1886	1963	1429	863	182	9	(13)	
(14)	Wind	WSAvg	1.1	0.7	0.9	1.4	1.7	1.5	1.2	1.2	1.0	1.0	0.8	0.7	(14)	
(15)	Precipitation	PrecAvg	1692	10	18	52	164	235	313	326	256	181	97	17	6	(15)
(16)		PrecMax	2446	76	96	152	547	570	573	647	595	372	354	89	48	(16)
(17)		PrecMin	1097	0	0	4	16	62	95	132	65	25	3	0	0	(17)
(18)		PrecStd	253	13	18	37	101	108	112	112	103	82	75	21	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	30.6	34.3	36.4	35.5	36.1	35.8	36.1	35.2	34.2	31.1	27.8	(19)
(20)			MCWB	19.1	20.1	21.0	23.5	26.8	29.1	28.7	29.4	28.7	28.2	24.4	21.2	(20)
(21)		2%	DB	25.7	28.9	32.7	34.1	34.0	34.4	34.4	34.8	34.1	32.8	29.8	26.5	(21)
(22)			MCWB	18.4	19.6	21.0	23.7	26.6	28.4	28.7	29.0	28.2	27.1	23.6	20.3	(22)
(23)		5%	DB	24.2	27.6	31.2	32.6	32.9	33.2	33.3	33.8	33.1	31.8	28.7	25.3	(23)
(24)			MCWB	17.7	19.1	20.6	23.7	26.4	27.9	28.4	28.6	27.8	26.3	23.0	19.5	(24)
(25)		10%	DB	23.0	26.2	30.0	31.1	31.8	32.2	32.3	32.8	32.1	30.7	27.7	24.2	(25)
(26)			MCWB	17.3	18.4	20.2	23.7	26.0	27.7	28.1	28.2	27.6	25.8	22.4	18.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.6	22.4	24.7	26.7	28.7	29.7	30.0	30.1	29.7	28.7	25.4	22.2	(27)
(28)			MCDWB	24.9	27.7	30.0	31.4	32.9	33.8	33.6	34.2	33.2	32.9	29.4	26.0	(28)
(29)		2%	WB	19.3	20.8	23.2	25.7	27.8	29.1	29.3	29.5	29.1	27.8	24.3	21.1	(29)
(30)			MCDWB	23.8	26.3	29.1	30.5	31.6	32.9	32.8	33.4	32.7	31.3	28.3	25.2	(30)
(31)		5%	WB	18.4	19.8	22.4	25.1	27.1	28.6	28.8	29.0	28.5	27.1	23.7	20.3	(31)
(32)			MCDWB	22.9	25.5	28.1	29.9	30.9	32.0	32.1	32.8	31.8	30.4	27.4	24.2	(32)
(33)		10%	WB	17.7	19.2	21.6	24.5	26.5	28.1	28.4	28.5	28.0	26.4	23.1	19.5	(33)
(34)			MCDWB	22.0	24.7	27.1	29.1	30.2	31.2	31.4	31.9	30.9	29.5	26.5	23.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.3	12.3	12.4	9.1	7.6	6.0	5.5	6.1	6.2	7.7	9.6	10.8	(35)
(36)			MCDBR	13.0	14.0	14.4	12.4	9.5	7.7	7.1	7.7	8.0	8.7	10.2	11.9	(36)
(37)			MCWBR	6.4	5.8	5.0	4.5	3.8	3.3	2.9	3.1	3.4	3.8	4.7	6.1	(37)
(38)		5% WB	MCDBR	12.1	12.7	11.7	9.7	8.3	7.1	6.4	7.1	7.3	7.9	9.2	10.9	(38)
(39)			MCWBR	6.7	6.1	5.2	4.5	3.8	3.4	3.0	3.2	3.5	3.9	4.7	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.557	0.581	0.631	0.658	0.634	0.579	0.494	0.499	0.514	0.487	0.519	0.522	(40)
(41)		taud		1.799	1.773	1.703	1.720	1.808	1.973	2.237	2.220	2.151	2.174	1.975	1.941	(41)
(42)		Ebn at Noon		673	700	694	690	706	741	806	803	780	777	708	688	(42)
(43)		Edh at Noon		191	210	237	239	218	184	141	143	149	139	159	160	(43)
(44)	All-Sky Solar Radiation	RadAvg		3.73	4.42	5.02	5.01	4.86	4.21	4.24	4.38	4.14	4.32	4.13	3.68	(44)
(45)		RadStd		0.26	0.31	0.40	0.51	0.39	0.37	0.39	0.41	0.25	0.33	0.24	0.17	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (1 neighbor)	+0.55	N/A	+0.83	+0.80	+0.77	+0.78	N/A	N/A	N/A	N/A
		+0.55	N/A	+0.83	+0.80	+0.77	+0.78	N/A	N/A	N/A	N/A

Nomenclature: See separate page