

DALTONGANJ, India

WMO: 425870

Lat: 24.050N

Lon: 84.067E

Elev: 725

StdP: 14.31

Time Zone: 5.50 (IND)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.0	48.2	39.6	36.7	65.9	41.6	39.7	61.6	6.2	68.8	5.4	69.8	0.0	N/A	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	23.6	110.4	76.3	108.2	76.5	105.9	76.3	84.1	98.2	82.9	93.9	82.1	91.5	3.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.7	169.5	87.5	80.8	164.1	86.6	80.1	160.3	85.9	49.2	100.2	47.8	93.7	46.9	91.9	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.2	4.5	42.8	113.2	1.8	2.1	41.6	114.7	40.5	115.9	39.5	117.1	38.2	118.6		
(5)			41.5	85.4	1.7	1.5	40.3	86.5	39.4	87.4	38.4	88.2	37.2	89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.7	63.0	69.9	79.2	89.3	94.0	92.0	84.6	83.8	83.6	79.4	72.4	64.9
	DBStd	10.57	3.96	4.58	5.07	4.23	3.61	5.69	3.05	2.27	2.21	3.42	3.74	3.97
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	146	86	9	0	0	0	0	0	0	0	0	0	51
	CDD50	10840	403	557	904	1179	1364	1259	1073	1048	1008	912	672	461
	CDD65	5511	24	146	439	729	899	809	608	583	558	447	222	47
	CDH74	72589	318	1542	5190	11003	14846	12665	7495	6890	6516	4141	1592	391
CDH80	40293	45	561	2959	7261	10439	8418	3241	2651	2598	1609	464	47	
Wind	WSAvg	0.8	0.4	0.6	0.8	1.2	1.3	1.4	1.0	0.8	0.8	0.4	0.2	0.3
Precipitation	PrecAvg	41.1	0.6	0.8	0.6	0.4	0.7	5.7	12.0	11.2	7.3	1.9	0.4	0.2
	PrecMax	72.6	5.0	5.0	2.7	2.2	4.1	18.5	24.5	21.2	24.2	11.2	3.5	1.5
	PrecMin	21.1	0.0	0.0	0.0	0.0	0.0	0.3	2.2	3.5	0.6	0.0	0.0	0.0
	PrecStd	12.1	0.9	1.2	0.7	0.5	0.9	4.6	5.1	4.4	5.0	2.1	0.7	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.6	93.6	104.8	111.5	112.7	113.0	98.1	94.5	94.7	93.6	89.4	84.7
		MCWB	66.7	69.2	74.5	73.0	76.7	77.6	80.7	81.2	79.8	75.8	71.0	66.4
	2%	DB	80.5	89.8	100.1	108.8	110.5	110.2	94.8	92.1	92.8	91.8	87.1	80.8
		MCWB	63.1	67.6	71.9	75.9	76.0	78.3	81.0	81.2	79.7	75.9	70.5	65.0
	5%	DB	77.5	86.6	97.3	106.4	108.6	107.2	92.7	90.6	91.6	90.1	85.1	78.3
		MCWB	61.9	66.4	71.1	75.9	75.9	78.0	80.9	81.1	79.8	75.4	69.6	63.9
	10%	DB	74.6	83.5	94.3	104.1	106.2	103.9	90.8	89.1	90.1	88.0	82.8	75.8
		MCWB	60.6	65.3	69.9	73.8	76.0	78.5	80.9	80.8	79.7	74.4	68.4	62.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.1	73.5	76.5	84.1	84.5	85.5	85.9	83.6	83.0	81.5	75.6	70.1
		MCDB	77.3	87.2	99.2	107.4	105.9	100.6	91.2	89.1	90.6	88.9	84.5	77.4
	2%	WB	66.4	70.4	74.9	81.4	82.8	84.1	83.5	82.7	81.9	79.9	73.4	67.5
		MCDB	75.2	85.6	95.8	104.5	103.0	99.6	88.8	88.8	89.1	87.2	81.5	76.4
	5%	WB	64.3	68.2	73.3	79.0	81.5	82.7	82.3	81.9	81.3	78.7	71.8	65.8
		MCDB	73.6	82.9	92.5	100.9	100.7	95.5	88.7	87.9	88.2	85.2	80.1	75.6
	10%	WB	62.6	66.4	71.7	76.8	80.0	81.6	81.6	81.4	80.7	77.6	70.2	64.0
		MCDB	71.1	80.2	89.2	97.0	98.4	93.4	87.7	87.0	87.2	83.1	79.2	73.1
Mean Daily Temperature Range	5% DB	MDBR	24.5	26.7	28.2	28.2	23.6	17.2	10.3	9.6	11.6	17.0	23.4	25.1
		MCDBR	29.1	30.0	31.7	30.6	26.7	22.2	13.5	11.9	14.3	19.0	24.2	27.3
		MCWBR	13.7	12.3	11.0	10.1	7.8	5.8	4.1	4.6	4.9	6.4	9.4	12.4
	5% WB	MCDBR	23.3	28.0	28.5	28.8	23.4	17.0	11.3	10.6	12.0	13.0	19.3	23.7
		MCWBR	12.3	13.2	11.6	11.9	9.5	6.0	5.1	4.9	5.1	5.6	8.9	11.6
Clear-Sky Solar Irradiance	taub	0.500	0.483	0.514	0.567	0.647	0.688	0.608	0.581	0.568	0.562	0.576	0.545	
	taud	1.892	1.987	1.933	1.845	1.714	1.678	1.859	1.947	1.959	1.896	1.768	1.811	
	Ebn at Noon	235	253	252	241	221	211	228	235	234	227	211	214	
	Edh at Noon	56	55	60	67	76	78	65	60	58	59	63	59	
All-Sky Solar Radiation	RadAvg	1243	1555	1886	2104	2059	1688	1347	1377	1431	1483	1307	1172	
	RadStd	91	96	80	121	95	155	126	71	115	131	69	60	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page