

DALTONGANJ, India

WMO: 425870

Lat: 24.050N

Lon: 84.067E

Elev: 221

StdP: 98.70

Time Zone: 5.50 (IND)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	9.0	4.2	5.2	18.9	5.3	5.7	16.5	2.8	20.4	2.4	21.0	0.0	N/A	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.1	43.5	24.6	42.4	24.7	41.0	24.6	29.0	36.8	28.3	34.4	27.8	33.0	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	24.2	30.8	27.1	23.4	30.3	26.7	22.9	29.9	96.6	37.9	93.4	34.3	91.2	33.3	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
2.6	2.3	2.0	6.0	45.1	1.0	1.1	5.3	45.9	4.7	46.6	4.2	47.3	3.5	48.1		
			5.3	29.7	0.9	0.8	4.6	30.3	4.1	30.8	3.6	31.2	2.9	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	17.2	21.1	26.2	31.8	34.4	33.3	29.2	28.8	28.7	26.3	22.4	18.3	(6)	
(7)		DBStd	5.87	2.20	2.54	2.82	2.35	2.00	3.16	1.69	1.26	1.23	1.90	2.08	2.21	(7)	
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
(9)		HDD18.3	81	48	5	0	0	0	0	0	0	0	0	0	28	(9)	
(10)		CDD10.0	6022	224	309	502	655	758	699	596	582	560	507	373	256	(10)	
(11)		CDD18.3	3062	13	81	244	405	499	449	338	324	310	248	123	26	(11)	
(12)		CDH23.3	40327	177	857	2883	6113	8248	7036	4164	3828	3620	2301	884	217	(12)	
(13)		CDH26.7	22385	25	312	1644	4034	5799	4677	1801	1473	1443	894	258	26	(13)	
(14)	Wind	WSAvg	0.3	0.2	0.3	0.4	0.5	0.6	0.6	0.4	0.4	0.3	0.2	0.1	0.1	(14)	
(15)	Precipitation	PrecAvg	1044	14	21	14	10	19	144	304	284	185	48	10	4	(15)	
(16)		PrecMax	1843	126	126	69	55	105	471	622	539	614	285	88	37	(16)	
(17)		PrecMin	536	0	0	0	0	0	8	55	90	14	0	0	0	(17)	
(18)		PrecStd	307	22	30	18	13	24	117	129	113	126	53	19	9	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	34.2	40.5	44.1	44.8	45.0	36.7	34.7	34.9	34.2	31.9	29.3	(19)	
(20)			MCWB	19.3	20.7	23.6	22.8	24.8	25.3	27.0	27.4	26.5	24.4	21.7	19.1	(20)	
(21)		2%	DB	26.9	32.1	37.8	42.7	43.6	43.4	34.9	33.4	33.8	33.2	30.6	27.1	(21)	
(22)			MCWB	17.3	19.8	22.2	24.4	24.4	25.7	27.2	27.4	26.5	24.4	21.4	18.3	(22)	
(23)		5%	DB	25.3	30.3	36.3	41.3	42.5	41.8	33.7	32.6	33.1	32.3	29.5	25.7	(23)	
(24)			MCWB	16.6	19.1	21.7	24.4	24.4	25.6	27.2	27.3	26.5	24.1	20.9	17.7	(24)	
(25)		10%	DB	23.7	28.6	34.6	40.1	41.2	40.0	32.6	31.7	32.3	31.1	28.2	24.4	(25)	
(26)			MCWB	15.9	18.5	21.1	23.2	24.4	25.8	27.2	27.1	26.5	23.6	20.2	17.0	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.6	23.0	24.7	29.0	29.2	29.7	29.9	28.7	28.3	27.5	24.2	21.2	(27)
(28)				MCDWB	25.2	30.6	37.3	41.9	41.1	38.1	32.9	31.7	32.6	31.6	29.1	25.2	(28)
(29)	2%		WB	19.1	21.3	23.8	27.4	28.2	29.0	28.6	28.1	27.7	26.6	23.0	19.7	(29)	
(30)			MCDWB	24.0	29.8	35.4	40.3	39.5	37.6	31.5	31.5	31.7	30.7	27.5	24.7	(30)	
(31)	5%		WB	18.0	20.1	23.0	26.1	27.5	28.2	28.0	27.7	27.4	25.9	22.1	18.8	(31)	
(32)			MCDWB	23.1	28.3	33.6	38.3	38.2	35.3	31.5	31.1	31.2	29.6	26.7	24.2	(32)	
(33)	10%		WB	17.0	19.1	22.0	24.9	26.7	27.6	27.5	27.4	27.0	25.3	21.2	17.8	(33)	
(34)			MCDWB	21.7	26.8	31.8	36.1	36.9	34.1	30.9	30.6	30.7	28.4	26.2	22.8	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	13.6	14.8	15.7	15.7	13.1	9.5	5.7	5.3	6.5	9.4	13.0	13.9	(35)
(36)				MCDBR	16.2	16.7	17.6	17.0	14.8	12.3	7.5	6.6	7.9	10.5	13.5	15.2	(36)
(37)		MCWBR		7.6	6.8	6.1	5.6	4.3	3.2	2.3	2.5	2.7	3.6	5.2	6.9	(37)	
(38)		5% WB	MCDWB	13.0	15.5	15.8	16.0	13.0	9.5	6.3	5.9	6.6	7.2	10.7	13.1	(38)	
(39)			MCWBR	6.8	7.4	6.5	6.6	5.3	3.3	2.8	2.7	2.8	3.1	4.9	6.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.500	0.483	0.514	0.567	0.647	0.688	0.608	0.581	0.568	0.562	0.576	0.545	(40)		
(41)		taud	1.892	1.987	1.933	1.845	1.714	1.678	1.859	1.947	1.959	1.896	1.768	1.811	(41)		
(42)		Ebn at Noon	741	797	794	760	698	665	720	740	739	716	664	676	(42)		
(43)		Edh at Noon	177	172	190	211	240	247	206	188	183	186	199	186	(43)		
(44)	All-Sky Solar Radiation	RadAvg	3.92	4.90	5.95	6.63	6.49	5.32	4.25	4.34	4.51	4.67	4.12	3.69	(44)		
(45)		RadStd	0.29	0.30	0.25	0.38	0.30	0.49	0.40	0.23	0.36	0.41	0.22	0.19	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page