

GAYA, India

WMO: 425910

Lat: 24.744N

Lon: 84.951E

Elev: 380

StdP: 14.50

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.8	47.2	35.6	30.9	80.7	38.8	35.2	73.1	17.1	70.6	15.2	70.9	2.1	140	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	23.9	109.4	73.1	107.1	73.4	104.4	73.8	83.6	92.4	82.8	91.2	82.3	90.4	11.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.7	167.4	86.8	81.0	163.3	86.1	80.6	161.2	85.7	48.2	92.8	47.4	91.5	46.7	90.6	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	14.9	12.7	DB	41.1	112.2	3.0	1.9	38.9	113.5	37.1	114.6	35.4	115.7	33.2	117.0	
			WB	40.0	85.5	2.5	0.9	38.2	86.2	36.7	86.7	35.3	87.3	33.5	87.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	60.3	67.8	77.3	87.9	91.6	91.1	85.7	84.9	84.4	79.3	71.3	63.2	(6)
	DBStd	11.07	4.68	4.56	5.19	4.03	4.15	5.01	2.88	2.21	2.38	3.48	3.75	4.25	(7)
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	259	155	20	0	0	0	0	0	0	0	0	1	83	(9)
	CDD50	10512	322	499	847	1138	1289	1234	1106	1083	1033	910	640	411	(10)
	CDD65	5294	11	99	382	688	824	784	641	618	583	445	191	28	(11)
	CDH74	70337	120	1006	4574	10336	13175	12055	8253	7669	7038	4273	1571	267	(12)
	CDH80	38514	7	278	2460	6710	8906	7800	3903	3319	3031	1676	404	20	(13)
(14) Wind	WSAvg	4.0	2.9	3.5	4.4	5.2	5.8	5.8	5.1	4.5	4.1	2.4	1.8	2.4	(14)
(15) Precipitation	PrecAvg	40.8	0.7	0.7	0.4	0.3	1.1	5.9	10.8	12.2	6.5	2.2	0.3	0.2	(15)
	PrecMax	54.3	3.6	2.2	1.5	1.9	4.1	15.6	21.3	20.7	16.4	7.3	2.5	1.6	(16)
	PrecMin	22.2	0.1	0.1	0.0	0.0	0.0	0.2	4.5	6.4	1.7	0.1	0.0	0.0	(17)
	PrecStd	8.1	0.8	0.6	0.4	0.5	1.1	4.3	4.6	3.5	3.6	2.0	0.7	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.9	91.0	102.4	109.7	111.5	112.3	98.8	95.4	95.4	93.4	88.2	82.4	(19)
		MCWB	63.4	67.2	68.7	71.8	73.0	74.5	81.0	82.4	81.2	78.3	70.9	66.0	(20)
	2%	DB	77.2	86.3	98.1	107.4	109.4	109.6	96.1	93.6	93.8	91.5	86.2	79.1	(21)
		MCWB	61.0	66.5	68.6	70.4	72.6	74.8	81.4	82.0	81.0	77.4	69.6	63.6	(22)
	5%	DB	74.6	83.3	95.0	105.0	107.3	106.2	93.9	92.2	92.4	89.8	84.4	77.0	(23)
		MCWB	59.8	65.4	68.1	70.4	73.5	76.6	81.6	81.8	80.9	76.8	68.8	62.5	(24)
	10%	DB	71.9	80.5	92.2	102.5	104.9	102.6	92.1	90.7	90.9	88.0	82.5	74.8	(25)
		MCWB	58.8	63.9	67.6	70.8	74.2	78.0	81.5	81.5	80.6	75.7	67.9	61.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.4	71.8	74.9	81.1	83.5	84.2	84.5	84.3	83.6	81.7	75.4	69.7	(27)
		MCDB	74.3	83.1	91.4	99.1	99.5	96.5	92.3	91.6	91.3	89.2	83.2	78.1	(28)
	2%	WB	64.7	69.1	72.6	78.5	82.0	82.8	83.4	83.4	82.7	80.4	73.3	66.9	(29)
		MCDB	71.6	81.1	89.9	95.0	97.9	94.4	90.9	90.2	89.8	87.6	81.5	75.5	(30)
	5%	WB	63.0	67.2	70.8	76.6	80.8	82.1	82.6	82.6	81.9	79.4	71.6	64.9	(31)
		MCDB	69.6	78.9	88.4	93.3	95.8	93.2	90.0	89.0	88.7	85.8	79.8	73.5	(32)
	10%	WB	61.1	65.6	69.3	75.1	79.6	81.4	81.9	82.0	81.5	78.3	70.0	63.0	(33)
		MCDB	68.3	77.3	87.0	92.5	94.5	92.1	88.9	88.0	88.0	84.2	78.7	71.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.9	24.4	27.3	27.7	23.9	17.8	11.2	10.8	12.2	17.3	23.8	23.3	(35)
		MCDBR	26.2	27.8	30.2	30.8	28.0	23.8	14.4	13.2	14.7	18.7	23.4	25.3	(36)
	5% WB	MCWBR	12.1	11.3	9.8	10.0	8.2	6.7	4.3	4.4	4.6	6.8	9.1	11.3	(37)
		MCWBR	19.9	24.4	27.4	25.9	22.2	17.3	12.4	11.7	12.7	14.7	20.7	21.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.557	0.516	0.526	0.591	0.678	0.703	0.612	0.585	0.582	0.592	0.643	0.626	(40)
		taud	1.744	1.886	1.892	1.794	1.660	1.647	1.852	1.939	1.925	1.824	1.639	1.645	(41)
	Ebn at Noon		216	242	248	235	215	208	227	233	231	218	191	190	(42)
		Edh at Noon	65	60	62	70	80	81	66	60	60	63	72	69	(43)
(44) All-Sky Solar Radiation	RadAvg		1131	1485	1842	2078	2045	1723	1403	1453	1455	1445	1254	1075	(44)
	RadStd		94	94	68	104	93	130	122	64	103	119	61	74	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page