

AGARTALA, India

WMO: 427240

Lat: 23.887N

Lon: 91.240E

Elev: 46

StdP: 14.67

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.4	51.5	45.1	44.3	64.5	47.6	48.9	60.3	7.7	72.5	6.9	73.2	0.0	50	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.6	95.2	80.5	93.9	80.6	92.9	80.5	84.2	91.6	83.4	90.5	82.6	89.5	4.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.3	168.8	88.8	81.4	163.5	87.6	80.8	160.2	86.8	48.5	91.4	47.6	91.0	46.8	90.0	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	8.4	7.2	DB	45.7	97.8	2.4	1.6	44.0	99.0	42.6	100.0	41.2	100.9	39.5	102.0	(4)
(5)			WB	44.9	85.2	2.5	0.9	43.1	85.8	41.6	86.3	40.2	86.8	38.4	87.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	64.2	70.4	78.0	82.6	83.3	83.7	83.6	83.8	83.5	81.0	74.3	67.3	(6)
(7)		DBStd	7.66	3.69	4.61	4.48	3.96	3.56	2.86	2.32	2.12	2.28	3.09	3.35	3.64	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	82	57	6	0	0	0	0	0	0	0	0	0	19	(9)
(10)		CDD50	10228	441	572	869	978	1032	1012	1041	1049	1006	962	729	537	(10)
(11)		CDD65	4835	33	158	404	528	567	562	576	584	556	497	279	91	(11)
(12)		CDH74	52036	353	1383	4066	6090	6528	6531	6588	6751	6184	4893	2045	624	(12)
(13)		CDH80	20533	24	380	1776	2922	3014	2644	2441	2553	2309	1820	578	72	(13)
(14)	Wind	WSAvg	2.0	0.9	1.5	2.1	3.2	2.8	2.9	3.3	2.6	2.0	1.3	1.0	0.8	(14)
(15)	Precipitation	PrecAvg	80.3	0.4	1.1	2.6	6.1	12.4	16.0	13.6	10.7	8.6	6.3	1.3	0.4	(15)
(16)		PrecMax	112.8	2.0	7.2	7.9	15.0	24.0	26.3	30.0	16.3	20.8	13.9	5.8	4.7	(16)
(17)		PrecMin	58.0	0.2	0.1	0.0	0.2	3.5	6.1	4.3	6.0	3.8	2.5	0.2	0.0	(17)
(18)		PrecStd	14.9	0.4	1.4	2.4	3.7	5.2	5.6	7.0	2.9	3.9	3.3	1.8	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	89.8	95.2	97.4	96.8	95.3	94.3	94.8	94.8	93.5	89.6	84.3	(19)
(20)			MCWB	66.5	71.7	73.4	78.2	81.4	83.8	83.7	83.7	82.9	81.9	76.8	69.1	(20)
(21)		2%	DB	80.1	86.5	92.9	95.2	94.9	93.5	92.0	92.7	92.5	91.6	87.3	82.1	(21)
(22)			MCWB	65.3	69.7	73.8	78.4	81.3	82.9	82.1	82.8	82.3	80.7	75.0	68.6	(22)
(23)		5%	DB	77.9	84.4	91.0	93.4	93.4	91.9	90.5	91.1	90.9	89.9	85.5	80.2	(23)
(24)			MCWB	64.1	68.3	73.8	78.5	81.3	82.3	81.5	82.0	81.6	79.6	73.9	67.5	(24)
(25)		10%	DB	75.6	82.2	89.0	91.6	91.6	90.0	88.9	89.5	89.3	88.2	83.7	77.9	(25)
(26)			MCWB	63.2	67.5	73.4	78.5	80.7	81.7	81.0	81.4	81.0	79.0	72.9	66.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	75.6	79.3	82.8	84.6	85.1	84.8	84.8	84.5	83.5	79.3	73.3	(27)
(28)			MCD B	76.6	83.8	88.4	92.8	93.4	93.2	91.9	91.9	91.6	90.9	86.7	79.3	(28)
(29)		2%	WB	68.1	74.1	77.9	81.7	83.3	83.7	83.2	83.5	83.3	81.9	77.3	70.8	(29)
(30)			MCD B	76.0	81.2	86.8	90.9	91.6	91.0	89.5	90.3	89.9	88.7	83.7	77.6	(30)
(31)		5%	WB	66.1	72.5	76.9	80.7	82.4	82.9	82.2	82.6	82.3	81.0	76.1	69.3	(31)
(32)			MCD B	74.5	79.3	85.6	89.1	90.4	89.7	88.0	88.9	88.7	87.3	82.2	76.6	(32)
(33)		10%	WB	64.6	70.4	76.1	79.8	81.5	82.1	81.5	81.8	81.5	80.1	74.8	68.0	(33)
(34)			MCD B	73.1	78.1	84.2	87.8	89.0	88.4	87.0	87.6	87.4	85.9	80.9	75.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.6	24.1	21.7	17.9	15.2	11.2	10.1	10.6	11.4	13.8	19.5	21.8	(35)
(36)			MCDBR	26.4	25.4	22.6	19.3	17.4	14.0	12.7	13.3	13.9	15.7	20.1	23.8	(36)
(37)			MCWBR	12.9	10.6	8.2	6.9	7.1	5.7	4.8	5.2	5.5	6.5	9.1	11.5	(37)
(38)		5% WB	MCDBR	23.7	19.9	18.9	17.2	16.1	13.2	11.4	12.1	12.6	14.2	16.8	20.8	(38)
(39)			MCWBR	12.5	9.0	8.1	7.7	7.8	6.0	5.1	5.3	5.6	6.3	8.6	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.566	0.558	0.604	0.651	0.674	0.614	0.512	0.500	0.514	0.514	0.528	0.541	(40)	
(41)		taud	1.774	1.827	1.780	1.748	1.740	1.891	2.192	2.232	2.167	2.108	1.944	1.876	(41)	
(42)		Ebn at Noon	216	232	229	221	216	227	252	255	249	242	226	217	(42)	
(43)		Edh at Noon	63	64	70	74	74	63	47	45	47	48	53	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1248	1541	1706	1725	1595	1384	1419	1465	1408	1405	1379	1197	(44)	
(45)		RadStd	76	81	125	142	159	127	142	115	95	75	82	88	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page