

PENDRA ROAD, India

WMO: 427790

Lat: 22.767N

Lon: 81.900E

Elev: 2051

StdP: 13.64

Time Zone: 5.50 (IND)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.9	51.1	31.2	27.5	68.7	33.8	30.7	67.8	6.5	68.1	5.4	69.3	0.2	0	0.271

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	22.1	105.5	69.4	103.3	69.4	100.9	69.3	78.9	87.3	78.2	86.0	77.6	84.8	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	151.7	82.4	76.3	148.4	81.7	75.7	145.3	81.0	44.4	87.1	43.7	86.5	43.0	85.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.0	5.1	4.2	DB	44.2	108.7	3.4	2.0	41.8	110.2	39.8	111.4	37.9	112.5	35.4	114.0	
			WB	40.0	81.1	2.7	1.6	38.0	82.2	36.5	83.2	34.9	84.1	33.0	85.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	65.0	70.7	78.1	86.6	90.2	86.3	79.7	79.2	79.3	76.7	71.0	65.9
	DBStd	8.65	4.04	4.81	5.10	4.82	4.04	5.51	2.68	2.25	2.21	2.93	3.03	3.43
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	91	50	9	0	0	0	0	0	0	0	0	1	31
	CDD50	10007	466	579	872	1099	1246	1090	921	905	880	827	629	493
	CDD65	4622	51	168	407	649	781	640	456	440	430	362	180	58
	CDH74	49140	404	1412	4219	8872	11543	8220	3733	3292	3237	2684	1135	389
(13)	CDH80	23543	48	458	2139	5394	7354	4505	909	688	902	911	205	30
(14)	Wind	WSAvg	0.9	0.7	0.8	1.0	1.2	1.4	1.5	1.0	0.9	0.7	0.4	0.5
(15) Precipitation	PrecAvg	53.6	1.1	1.1	1.2	1.0	1.5	7.7	13.3	13.7	9.0	2.8	0.6	0.3
	PrecMax	76.5	7.1	3.6	4.0	5.1	7.5	20.7	21.6	20.4	18.4	14.0	5.0	3.5
	PrecMin	35.9	0.1	0.2	0.0	0.0	0.0	1.9	3.3	5.4	1.6	0.0	0.0	0.0
	PrecStd	9.0	1.7	1.0	1.1	1.1	1.7	4.4	3.9	3.3	4.6	3.0	1.3	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.6	91.5	100.3	106.2	108.5	107.8	92.7	89.6	90.8	91.0	86.3	83.1
		MCWB	62.9	64.3	65.9	67.8	69.3	71.5	77.6	77.5	75.0	70.3	65.1	62.8
	2%	DB	81.0	88.0	96.3	103.9	106.2	104.1	89.0	87.3	88.8	88.8	84.2	80.4
		MCWB	61.3	63.4	64.6	67.3	69.4	71.4	77.5	77.4	75.7	70.5	65.1	61.9
	5%	DB	78.6	85.4	93.7	102.0	104.1	100.8	86.9	85.7	87.2	87.1	82.5	78.3
		MCWB	60.3	62.6	64.9	66.9	69.9	72.7	77.3	77.1	75.7	70.3	64.8	61.0
	10%	DB	76.0	82.7	91.2	99.7	101.6	97.1	84.9	84.0	85.4	85.3	80.7	76.1
		MCWB	59.0	62.0	64.2	66.9	70.4	73.6	76.9	76.6	75.7	70.2	63.9	59.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.1	68.8	71.0	73.8	78.9	79.7	79.8	79.2	79.1	77.0	72.7	67.1
		MCDB	76.0	83.0	88.1	95.6	96.2	90.4	87.5	85.9	86.1	85.2	79.1	76.9
	2%	WB	64.3	66.7	69.2	71.8	76.5	78.4	78.8	78.4	78.0	75.7	70.4	65.1
		MCDB	74.6	80.8	86.4	93.6	94.1	89.4	85.9	84.7	84.9	83.0	77.1	75.4
	5%	WB	62.7	65.2	67.7	70.5	74.8	77.6	78.1	77.8	77.3	74.8	68.8	63.6
		MCDB	73.5	79.3	85.3	92.5	92.9	88.0	84.4	83.6	83.9	81.5	76.6	74.0
	10%	WB	61.2	63.8	66.3	69.1	73.6	76.8	77.4	77.1	76.6	73.7	67.1	61.8
		MCDB	72.2	77.9	83.9	91.6	91.9	86.8	83.0	82.4	82.8	80.0	75.9	72.3
(35) Mean Daily Temperature Range	5% DB	MDBR	22.6	22.8	23.6	23.9	22.1	16.2	9.3	9.1	11.6	18.0	21.4	22.8
		MCDBR	25.1	25.5	26.2	25.3	24.0	21.4	13.1	12.1	15.3	20.3	22.3	24.1
		MCWBR	11.2	9.9	9.2	8.7	7.6	6.3	5.0	5.0	5.7	7.6	8.7	10.4
	5% WB	MCDBR	20.3	21.3	22.1	22.9	21.2	15.7	11.1	10.8	12.0	13.8	16.8	20.1
		MCWBR	9.8	9.7	9.3	9.1	8.1	6.0	4.9	5.0	5.2	6.0	7.6	9.9
(40) Clear-Sky Solar Irradiance	taub		0.460	0.466	0.514	0.552	0.614	0.668	0.607	0.562	0.557	0.527	0.508	0.464
	taud		1.985	2.013	1.913	1.862	1.758	1.699	1.842	1.979	1.962	1.959	1.907	1.999
	Ebn at Noon		250	259	253	245	229	215	229	240	239	239	233	243
	Edh at Noon		52	54	62	66	73	77	67	58	58	56	56	49
(44) All-Sky Solar Radiation	RadAvg		1383	1654	1938	2153	2137	1662	1243	1233	1440	1578	1429	1321
	RadStd		95	86	96	104	68	181	148	115	141	128	80	63

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page