

PENDRA ROAD, India

WMO: 427790

Lat: 22.767N

Lon: 81.900E

Elev: 625

StdP: 94.04

Time Zone: 5.50 (IND)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	10.6	-0.4	3.9	20.4	1.0	4.4	19.9	2.9	20.1	2.4	20.7	0.1	0	0.271

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.3	40.8	20.8	39.6	20.8	38.3	20.7	26.1	30.7	25.7	30.0	25.3	29.3	1.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	21.7	28.0	24.6	21.2	27.6	24.3	20.8	27.2	85.4	30.6	83.7	30.3	82.2	29.4	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2.7	2.3	1.9	6.8	42.6	1.9	1.1	5.4	43.4	4.3	44.1	3.3	44.7	1.9	45.5
			4.4	27.3	1.5	0.9	3.4	27.9	2.5	28.4	1.6	28.9	0.5	29.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	18.3	21.5	25.6	30.4	32.3	30.2	26.5	26.2	26.3	24.8	21.6	18.8	(6)
(7)		DBStd	4.81	2.24	2.67	2.84	2.68	2.24	3.06	1.49	1.25	1.23	1.63	1.68	1.90	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	51	28	5	0	0	0	0	0	0	0	0	1	17	(9)
(10)		CDD10.0	5559	259	322	484	611	692	606	512	503	489	459	349	274	(10)
(11)		CDD18.3	2568	28	93	226	361	434	356	253	244	239	201	100	32	(11)
(12)		CDH23.3	27300	224	784	2344	4929	6413	4567	2074	1829	1798	1491	631	216	(12)
(13)		CDH26.7	13079	27	254	1188	2997	4086	2503	505	382	501	506	114	17	(13)
(14)	Wind	WSAvg	0.4	0.3	0.4	0.4	0.5	0.6	0.7	0.4	0.4	0.3	0.2	0.2	0.2	(14)
(15)	Precipitation	PrecAvg	1362	29	27	31	26	38	196	337	349	228	70	15	8	(15)
(16)		PrecMax	1942	181	92	102	129	190	525	549	518	468	355	128	90	(16)
(17)		PrecMin	912	2	6	0	0	0	47	84	137	40	0	0	0	(17)
(18)		PrecStd	229	43	25	28	29	43	111	100	84	116	77	32	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	33.1	38.0	41.2	42.5	42.1	33.7	32.0	32.7	32.8	30.2	28.4	(19)
(20)			MCWB	17.2	18.0	18.8	19.9	20.7	21.9	25.3	25.3	23.9	21.3	18.4	17.1	(20)
(21)		2%	DB	27.2	31.1	35.7	40.0	41.2	40.0	31.7	30.7	31.6	31.6	29.0	26.9	(21)
(22)			MCWB	16.3	17.4	18.1	19.6	20.8	21.9	25.3	25.2	24.3	21.4	18.4	16.6	(22)
(23)		5%	DB	25.9	29.7	34.3	38.9	40.1	38.2	30.5	29.9	30.6	30.6	28.1	25.7	(23)
(24)			MCWB	15.7	17.0	18.3	19.4	21.1	22.6	25.2	25.0	24.3	21.3	18.2	16.1	(24)
(25)		10%	DB	24.4	28.2	32.9	37.6	38.7	36.1	29.4	28.9	29.7	29.6	27.0	24.5	(25)
(26)			MCWB	15.0	16.7	17.9	19.4	21.3	23.1	25.0	24.8	24.3	21.2	17.7	15.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	20.5	21.6	23.2	26.0	26.5	26.5	26.2	26.2	25.0	22.6	19.5	(27)
(28)			MCD B	24.4	28.4	31.2	35.3	35.7	32.4	30.8	29.9	30.0	29.6	26.2	24.9	(28)
(29)		2%	WB	17.9	19.3	20.7	22.1	24.7	25.8	26.0	25.8	25.6	24.3	21.3	18.4	(29)
(30)			MCD B	23.7	27.1	30.2	34.2	34.5	31.9	30.0	29.3	29.4	28.3	25.0	24.1	(30)
(31)		5%	WB	17.1	18.5	19.8	21.4	23.8	25.3	25.6	25.4	25.1	23.8	20.4	17.6	(31)
(32)			MCD B	23.1	26.3	29.6	33.6	33.8	31.1	29.1	28.7	28.8	27.5	24.8	23.3	(32)
(33)		10%	WB	16.2	17.7	19.1	20.6	23.1	24.9	25.2	25.1	24.8	23.2	19.5	16.6	(33)
(34)			MCD B	22.3	25.5	28.8	33.1	33.3	30.5	28.3	28.0	28.2	26.7	24.4	22.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.5	12.7	13.1	13.3	12.3	9.0	5.2	5.1	6.5	10.0	11.9	12.6	(35)
(36)			MCD BR	13.9	14.1	14.6	14.1	13.3	11.9	7.3	6.7	8.5	11.3	12.4	13.4	(36)
(37)			MCWBR	6.2	5.5	5.1	4.9	4.2	3.5	2.8	2.8	3.2	4.2	4.8	5.8	(37)
(38)		5% WB	MCD BR	11.3	11.8	12.3	12.7	11.8	8.7	6.2	6.0	6.6	7.7	9.4	11.2	(38)
(39)			MCWBR	5.4	5.4	5.2	5.1	4.5	3.3	2.7	2.8	2.9	3.3	4.2	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.460	0.466	0.514	0.552	0.614	0.668	0.607	0.562	0.557	0.527	0.508	0.464	(40)	
(41)		taud	1.985	2.013	1.913	1.862	1.758	1.699	1.842	1.979	1.962	1.959	1.907	1.999	(41)	
(42)		Ebn at Noon	789	818	797	773	722	678	721	756	752	752	735	766	(42)	
(43)		Edh at Noon	163	169	195	208	230	242	210	183	183	176	175	156	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.36	5.21	6.11	6.79	6.74	5.24	3.92	3.89	4.54	4.98	4.50	4.17	(44)	
(45)		RadStd	0.30	0.27	0.30	0.33	0.21	0.57	0.47	0.36	0.45	0.40	0.25	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page