

JAGDALPUR, India

WMO: 430410

Lat: 19.083N

Lon: 82.033E

Elev: 1814

StdP: 13.76

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	50.5	52.7	42.1	42.2	73.8	44.5	46.3	67.8	6.9	72.3	5.5	75.0	0.1	180	0.257

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	21.8	102.8	73.2	100.6	73.5	98.3	73.2	79.9	91.3	78.9	88.8	78.1	87.1	3.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	151.6	83.8	76.4	147.6	82.4	75.9	144.8	81.7	45.2	92.0	44.0	89.3	43.2	87.1	93.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.1	5.5	5.1	DB	45.8	106.0	2.2	2.4	44.3	107.8	43.0	109.2	41.8	110.6	40.2	112.3
			WB	44.3	82.9	2.2	3.2	42.7	85.2	41.4	87.1	40.2	88.9	38.5	91.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	68.6	74.0	80.8	85.9	87.6	82.9	78.2	78.0	79.0	77.5	72.5	68.2
	DBStd	6.81	3.28	3.49	3.47	3.61	3.76	5.16	2.80	2.44	2.16	2.55	3.47	3.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	16	7	0	0	0	0	0	0	0	0	0	0	9
	CDD50	10136	576	672	954	1076	1164	988	875	867	871	853	675	565
	CDD65	4678	118	253	489	626	699	538	410	402	421	388	226	108
	CDH74	47855	1290	2674	5788	8320	9593	5930	2840	2629	3104	2953	1691	1043
	CDH80	21357	260	1136	3153	4857	5678	2794	645	532	822	921	400	159
Wind	WSAvg	1.4	0.9	1.1	1.4	1.8	1.9	2.0	1.9	1.7	1.3	1.2	0.9	0.7
Precipitation	PrecAvg	58.0	0.4	0.4	0.7	2.1	3.1	9.8	13.4	14.1	8.9	3.6	0.8	0.3
	PrecMax	89.1	2.5	2.7	5.4	5.6	13.5	21.4	24.2	29.8	19.3	11.8	4.9	4.8
	PrecMin	36.3	0.0	0.0	0.0	0.0	0.1	1.9	0.8	4.6	3.0	0.0	0.0	0.0
	PrecStd	10.1	0.6	0.6	1.0	1.5	2.1	4.5	4.3	4.7	3.7	3.1	1.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	93.8	99.8	103.9	106.3	104.9	90.4	88.2	89.7	89.8	87.5	85.6
		MCWB	67.2	67.9	69.3	71.8	72.8	73.5	77.6	77.5	76.8	73.4	70.9	66.8
	2%	DB	84.6	91.2	97.5	101.6	103.8	100.4	87.6	86.6	87.9	88.0	85.6	83.6
		MCWB	65.2	66.8	69.3	71.8	73.4	75.8	77.4	76.9	76.4	73.4	70.1	66.4
	5%	DB	82.8	89.0	95.7	99.8	101.4	96.3	85.6	85.0	86.4	86.7	84.1	81.8
		MCWB	64.8	66.4	69.4	72.1	74.3	76.6	76.8	76.5	76.3	73.3	69.5	65.8
	10%	DB	80.9	86.9	93.6	97.8	98.7	92.5	83.7	83.2	84.8	85.2	82.5	80.0
		MCWB	64.1	66.1	69.1	72.1	75.0	76.7	76.4	76.1	76.2	73.1	69.0	65.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	72.0	76.5	78.5	81.8	81.1	79.5	79.0	79.1	78.2	76.6	72.4
		MCDB	81.6	84.6	90.1	93.8	96.6	92.8	85.9	85.2	86.1	84.7	83.8	81.8
	2%	WB	69.4	70.5	74.3	77.1	80.1	79.7	78.3	77.9	78.1	77.1	74.7	70.3
		MCDB	79.4	83.7	89.1	92.2	94.2	90.5	84.5	83.7	84.6	83.8	81.9	78.7
	5%	WB	67.5	69.3	72.8	76.0	78.9	78.7	77.5	77.2	77.3	76.2	73.5	68.6
		MCDB	77.4	82.6	87.4	91.1	92.2	88.7	83.2	82.5	83.5	82.6	79.6	77.4
	10%	WB	66.0	68.1	71.5	75.0	77.6	77.8	76.8	76.5	76.7	75.3	72.1	67.0
		MCDB	77.2	81.6	85.9	90.1	90.7	87.0	82.0	81.2	82.5	81.4	78.0	76.4
Mean Daily Temperature Range	5% DB	MDBR	26.9	26.5	25.8	23.9	21.8	14.0	9.0	9.0	11.3	16.2	22.1	25.9
		MCDBR	28.5	29.1	28.1	26.0	25.0	20.8	13.0	12.7	14.2	18.6	23.5	27.6
		MCWBR	11.9	9.9	8.6	7.3	6.5	5.7	4.9	4.7	4.9	6.5	9.5	12.4
	5% WB	MCDBR	23.4	24.0	24.2	23.1	21.0	15.9	11.5	10.9	12.2	13.9	16.0	21.9
		MCWBR	11.1	9.4	8.5	8.0	8.0	6.1	5.1	4.8	5.1	5.7	7.5	11.1
Clear-Sky Solar Irradiance	taub		0.410	0.434	0.539	0.552	0.579	0.619	0.553	0.527	0.526	0.495	0.439	0.396
	taud		2.205	2.141	1.878	1.909	1.859	1.799	1.981	2.066	2.061	2.108	2.191	2.263
	Ebn at Noon		273	273	249	246	237	226	242	249	249	252	262	274
	Edh at Noon		43	48	65	63	66	69	58	54	53	49	43	39
All-Sky Solar Radiation	RadAvg		1519	1773	1934	2091	2069	1480	1112	1122	1368	1550	1500	1421
	RadStd		59	68	102	87	61	175	170	128	119	135	99	88

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page