

HYDERABAD INTL, India

WMO: 431285

Lat: 17.233N

Lon: 78.417E

Elev: 617

StdP: 94.13

Time Zone: 5.50 (IND)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.9	14.8	-1.0	3.8	26.4	1.1	4.4	28.4	6.4	25.9	6.0	25.7	1.7	110	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.5	40.0	21.4	39.0	21.4	37.9	21.2	26.5	31.6	25.7	30.6	25.2	29.8	4.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	22.0	28.1	24.9	21.5	27.5	24.2	20.6	26.6	87.0	29.8	83.6	31.7	81.0	29.7	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.4	DB	9.9	41.5	2.4	1.9	8.2	42.9	6.7	44.0	5.4	45.0	3.6	46.4	(4)
(5)			WB	7.0	27.0	2.2	2.3	5.4	28.6	4.1	30.0	2.8	31.3	1.2	32.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	22.1	24.9	28.3	30.8	32.2	28.7	26.3	25.8	25.8	25.5	23.5	22.0	(6)	
	DBStd	3.52	1.70	1.85	1.83	1.82	2.05	2.12	1.68	1.32	1.16	1.35	1.51	1.94	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	2	1	0	0	0	0	0	0	0	0	0	0	1	(9)	
	CDD10.0	5959	373	418	567	626	687	560	505	491	473	479	407	372	(10)	
	CDD18.3	2919	116	185	309	376	429	310	247	233	223	221	157	114	(11)	
	CDH23.3	30834	1003	1907	3838	5232	6350	3553	1990	1692	1554	1738	1103	874	(12)	
	CDH26.7	14957	276	888	2179	3168	4038	1713	638	469	449	621	307	209	(13)	
(14) Wind	WSAvg	3.4	2.6	2.8	2.7	2.8	3.6	5.1	5.5	4.5	3.5	2.6	2.6	2.5	(14)	
(15) Precipitation	PrecAvg	858	6	7	17	30	30	115	174	191	182	83	20	3	(15)	
	PrecMax	1214	40	60	160	99	139	226	382	427	430	292	89	31	(16)	
	PrecMin	586	0	0	0	5	0	24	62	60	70	0	0	0	(17)	
	PrecStd	172	13	15	33	24	38	55	75	87	74	77	22	8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	36.0	38.2	41.0	42.8	38.8	34.1	32.8	32.9	33.2	31.1	32.0	(19)	
		MCWB	17.5	19.0	20.5	20.1	24.2	23.7	22.9	22.7	24.3	22.0	20.7	19.0	(20)	
	2%	DB	30.2	34.1	37.2	39.2	40.8	36.9	32.7	31.2	31.2	32.0	30.1	30.1	(21)	
		MCWB	17.7	18.0	20.4	20.7	22.2	23.2	23.3	22.9	23.9	21.8	20.3	19.0	(22)	
	5%	DB	29.2	32.9	36.2	38.2	39.4	35.1	31.1	30.2	30.2	31.0	29.2	28.9	(23)	
		MCWB	17.7	17.9	20.1	20.7	21.7	22.9	23.4	23.2	23.7	21.3	19.8	18.6	(24)	
	10%	DB	28.1	31.8	35.1	37.2	38.2	33.8	30.0	29.2	29.2	30.0	28.8	27.9	(25)	
		MCWB	17.3	18.3	19.1	20.5	21.7	22.9	23.3	23.3	23.5	21.5	19.8	18.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.6	24.8	26.8	25.8	28.2	28.2	25.6	25.7	26.6	26.4	24.9	23.1	(27)	
		MCDB	28.1	30.1	33.5	33.7	36.2	34.3	29.7	28.4	29.1	29.1	28.4	27.5	(28)	
	2%	WB	21.6	22.5	24.3	24.8	26.3	25.9	25.1	25.2	25.8	25.5	23.6	22.1	(29)	
		MCDB	25.5	27.9	30.8	32.2	35.1	31.4	28.8	27.9	29.0	28.5	27.4	26.1	(30)	
	5%	WB	20.4	21.2	23.1	23.9	25.3	25.2	24.6	24.8	25.2	24.8	23.0	21.3	(31)	
		MCDB	24.7	26.2	29.3	31.1	34.2	30.6	28.1	27.4	27.9	27.5	26.4	25.2	(32)	
	10%	WB	19.3	20.2	22.1	23.2	24.5	24.6	24.2	24.4	24.6	24.0	22.3	20.4	(33)	
		MCDB	24.0	26.1	29.2	30.8	33.1	29.7	27.3	26.8	27.2	26.4	25.2	24.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	13.3	13.4	13.1	12.5	9.2	6.9	6.8	7.3	9.2	10.4	12.1	(35)	
		MCDBR	13.9	14.6	14.9	14.1	13.4	11.3	8.7	8.3	8.7	10.9	11.4	13.1	(36)	
	5% WB	MCWBR	4.9	4.5	4.5	4.5	4.2	3.2	2.6	2.7	3.2	4.0	4.4	4.7	(37)	
		MCWBR	12.4	13.0	14.1	12.9	12.7	9.1	7.0	6.4	7.4	8.1	9.1	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.441	0.452	0.519	0.559	0.594	0.568	0.528	0.511	0.504	0.522	0.469	0.448	(40)	
		taud	2.101	2.088	1.930	1.879	1.804	1.908	2.034	2.094	2.108	2.014	2.100	2.098	(41)	
	Ebn at Noon		837	850	805	773	736	748	780	801	806	777	804	816	(42)	
		Edh at Noon	152	162	195	206	220	196	173	164	161	172	151	149	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.88	5.72	6.22	6.62	6.54	5.24	4.45	4.46	4.82	4.99	4.82	4.63	(44)	
	RadStd		0.22	0.22	0.30	0.24	0.22	0.47	0.39	0.26	0.33	0.27	0.34	0.25	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.23	N/A	N/A	+0.73	N/A	N/A	N/A	+140	+139

Nomenclature: See separate page