

VIJAYAWADA INTL, India

WMO: 431810

Lat: 16.530N

Lon: 80.797E

Elev: 25

StdP: 101.03

Time Zone: 5.50 (IND)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.5	(c) 19.4	(d) 13.1	(e) 9.4	(f) 25.3	(g) 14.4	(h) 10.3	(i) 25.4	(j) 4.5	(k) 29.1	(l) 4.3	(m) 29.0	(n) 0.1	(o) 10	(p) 0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.1	41.1	26.8	39.8	26.9	38.2	26.8	29.0	35.2	28.5	34.2	28.2	33.3	2.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.8	31.1	27.2	23.1	30.8	27.0	22.8	30.6	94.6	35.3	92.6	34.1	91.0	33.6	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.1	4.4	16.1	44.4	1.1	1.5	15.3	45.5	14.7	46.3	14.1	47.1	13.3	48.2		
			14.4	29.7	0.8	0.7	13.8	30.2	13.4	30.6	13.0	31.0	12.4	31.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	24.9	26.6	29.5	32.3	34.0	31.9	29.5	29.2	29.1	28.7	26.9	25.4
	DBStd	3.15	1.10	1.29	1.35	1.52	2.10	3.00	2.09	1.62	1.27	1.39	1.35	1.31
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6942	463	464	606	669	743	657	606	597	573	579	507	478
	CDD18.3	3900	205	231	347	419	485	407	348	338	323	321	257	220
	CDH23.3	44728	1314	1829	3798	5633	7139	5704	4279	4002	3766	3508	2232	1524
	CDH26.7	22103	386	771	1868	3293	4681	3389	1964	1681	1504	1363	730	473
Wind	WSAvg	1.5	0.9	1.0	1.1	1.5	1.8	2.1	2.2	2.0	1.3	1.1	1.2	1.4
Precipitation	PrecAvg	1236	7	10	12	21	69	152	231	229	208	210	68	20
	PrecMax	1877	38	51	132	109	391	297	350	389	421	395	206	110
	PrecMin	897	0	0	0	2	12	60	138	127	68	24	1	0
	PrecStd	217	9	16	26	20	78	65	55	54	81	107	60	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	35.1	38.0	40.9	44.1	42.2	37.9	36.0	35.2	35.0	33.1	32.1
		MCWB	22.1	23.2	25.4	26.9	25.6	27.0	26.1	26.5	27.3	26.2	24.8	22.8
	2%	DB	30.4	33.8	36.2	39.2	42.0	40.4	36.0	34.8	34.2	34.0	32.1	31.0
		MCWB	22.0	23.2	25.2	27.0	26.3	26.8	26.2	26.6	27.0	26.2	24.5	22.8
	5%	DB	29.9	32.2	35.2	38.1	40.2	38.8	34.7	33.8	33.2	33.1	31.2	30.2
		MCWB	21.9	23.0	25.1	26.8	26.9	26.5	26.3	26.8	27.0	25.9	24.4	22.6
	10%	DB	29.0	31.0	34.1	37.0	38.9	36.9	33.2	32.6	32.2	32.1	30.4	29.3
		MCWB	21.7	22.7	24.9	26.5	27.0	26.6	26.4	26.6	26.9	25.9	24.2	22.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	26.0	27.4	29.0	29.7	29.3	28.4	28.6	28.7	28.2	26.7	25.1
		MCDB	28.6	32.4	34.0	36.3	37.6	36.1	32.7	32.9	32.8	32.2	30.0	29.3
	2%	WB	24.1	25.0	26.9	28.3	29.1	28.7	27.8	28.0	28.1	27.7	26.2	24.5
		MCDB	27.5	30.5	33.1	34.7	35.8	34.7	31.9	32.0	32.0	31.4	29.6	28.5
	5%	WB	23.4	24.3	26.3	27.9	28.7	28.1	27.4	27.6	27.7	27.2	25.7	24.0
		MCDB	27.1	29.2	32.3	33.8	34.8	33.2	31.4	31.3	31.3	30.7	29.0	27.9
	10%	WB	22.7	23.7	25.8	27.5	28.2	27.6	27.0	27.1	27.3	26.8	25.2	23.4
		MCDB	26.8	28.3	31.4	33.3	34.0	32.6	31.0	30.6	30.7	30.1	28.3	27.2
Mean Daily Temperature Range	5% DB	MDBR	9.9	11.0	11.3	11.2	11.1	8.5	6.4	6.4	6.4	7.2	8.0	9.3
		MCDBR	10.2	12.2	11.9	11.9	12.4	11.2	8.6	8.0	7.8	8.5	8.8	9.8
		MCWBR	3.3	3.5	3.1	2.7	3.1	2.8	2.4	2.6	2.7	2.7	3.0	3.2
	5% WB	MCDBR	8.8	10.8	11.0	11.6	11.3	9.3	7.1	7.0	7.0	7.2	7.1	8.4
		MCWBR	3.6	4.0	3.2	3.0	3.3	3.2	2.9	2.9	3.0	2.8	2.8	3.3
Clear-Sky Solar Irradiance	taub		0.521	0.513	0.571	0.587	0.653	0.625	0.575	0.560	0.556	0.567	0.536	0.551
	taud		1.949	1.995	1.879	1.885	1.750	1.822	1.958	2.001	2.006	1.959	1.978	1.902
	Ebn at Noon		764	797	764	751	694	706	744	762	765	741	745	721
	Edh at Noon		179	178	206	205	232	213	187	180	179	183	172	183
All-Sky Solar Radiation	RadAvg		4.70	5.51	6.04	6.52	6.18	4.91	4.38	4.51	4.72	4.69	4.54	4.33
	RadStd		0.19	0.23	0.23	0.24	0.20	0.40	0.50	0.36	0.37	0.39	0.30	0.27

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.30	+0.32	+0.48	N/A	+0.20	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page