

HONNAVAR, India

WMO: 432260

Lat: 14.283N

Lon: 74.450E

Elev: 9

StdP: 101.22

Time Zone: 5.50 (IND)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	20.1	10.3	7.8	26.9	12.0	8.7	26.5	3.5	28.4	3.2	28.4	0.9	90	0.290

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.3	34.1	24.6	33.6	24.9	33.2	25.1	28.0	31.8	27.7	31.3	27.4	30.9	1.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	30.0	26.7	22.3	29.7	26.4	21.9	29.5	89.6	31.9	88.2	31.6	86.9	31.1	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.4	2.9	2.4	DB	16.8	36.5	1.6	1.0	15.7	37.2	14.7	37.7	13.9	38.3	12.7	38.9	(4)
(5)			WB	13.6	29.0	1.2	0.7	12.7	29.6	12.0	30.0	11.4	30.4	10.5	30.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	26.4	26.6	27.9	29.2	29.6	27.1	26.3	26.3	26.6	27.6	27.9	27.5	(6)	
	DBStd	1.58	1.39	1.11	1.20	1.01	1.17	1.46	1.11	1.02	0.88	1.17	1.23	1.37	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6357	509	465	553	576	607	513	506	506	498	545	536	543	(10)	
	CDD18.3	3316	251	232	295	326	348	263	248	247	248	287	286	284	(11)	
	CDH23.3	34781	2413	2318	3386	4253	4633	2599	2128	2048	2212	2926	2998	2867	(12)	
(13)	CDH26.7	13307	1080	1021	1447	2004	2252	739	358	326	483	1060	1284	1252	(13)	
(14)	Wind	WSAvg	0.9	0.8	0.8	0.8	0.9	1.1	1.1	0.8	0.8	0.8	0.8	1.0	(14)	
(15) Precipitation	PrecAvg	3760	1	1	9	19	152	962	1238	725	407	178	54	8	(15)	
	PrecMax	4684	25	18	98	111	589	1445	1773	1188	861	326	227	76	(16)	
	PrecMin	2874	0	0	0	2	15	452	710	252	104	11	1	0	(17)	
	PrecStd	513	5	4	24	24	149	243	349	268	204	90	69	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	34.3	34.1	34.2	34.2	32.7	30.3	30.2	31.1	34.2	34.6	34.5	(19)	
		MCWB	22.1	21.0	23.9	26.7	27.3	27.1	26.9	26.9	26.5	24.9	24.2	22.6	(20)	
	2%	DB	33.4	33.0	33.0	33.6	33.7	31.7	29.7	29.6	30.3	33.1	33.7	33.6	(21)	
		MCWB	22.1	22.5	25.7	27.0	27.1	27.0	26.8	26.7	26.3	25.3	24.0	22.6	(22)	
	5%	DB	32.4	32.2	32.4	33.1	33.2	30.8	29.1	29.1	29.8	32.1	32.9	32.8	(23)	
		MCWB	22.2	23.2	25.7	26.9	27.0	27.0	26.7	26.5	26.1	25.8	24.0	22.8	(24)	
	10%	DB	31.5	31.5	31.8	32.5	32.6	30.0	28.6	28.5	29.2	31.2	32.2	32.1	(25)	
		MCWB	22.3	23.5	25.6	26.7	26.9	26.8	26.4	26.2	25.9	26.0	24.2	23.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.6	27.7	28.2	28.6	28.1	27.6	27.6	27.5	27.7	27.4	26.6	(27)	
		MCDB	30.7	30.9	31.7	32.6	32.7	30.8	29.5	29.4	29.8	31.2	31.4	31.2	(28)	
	2%	WB	25.1	25.8	27.1	27.7	28.1	27.6	27.2	27.1	26.9	27.2	26.7	25.8	(29)	
		MCDB	30.1	30.3	31.5	32.1	32.2	30.3	29.1	29.0	29.2	30.7	30.8	30.5	(30)	
	5%	WB	24.4	25.2	26.7	27.4	27.7	27.2	26.8	26.7	26.5	26.8	26.2	25.2	(31)	
		MCDB	29.7	29.9	31.1	31.7	31.7	29.9	28.7	28.5	28.8	30.3	30.3	29.8	(32)	
	10%	WB	23.7	24.6	26.3	27.1	27.4	27.0	26.5	26.3	26.2	26.4	25.7	24.5	(33)	
		MCDB	29.2	29.4	30.5	31.3	31.3	29.6	28.2	28.0	28.4	29.8	29.8	29.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	10.5	8.5	7.2	6.3	4.6	3.7	3.8	4.8	7.2	9.3	10.1	(35)	
		MCDBR	12.0	11.4	8.9	7.4	6.7	5.7	4.5	4.7	6.0	8.9	10.3	10.6	(36)	
	5% WB	MCWBR	5.7	5.2	3.9	2.9	2.5	2.6	2.7	2.6	2.9	3.8	4.6	5.0	(37)	
		MCWBR	10.7	9.8	7.8	7.0	6.3	5.2	4.3	4.4	5.1	7.3	8.2	9.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.445	0.473	0.552	0.599	0.580	0.577	0.618	0.570	0.507	0.545	0.492	0.453	(40)	
		taud	2.249	2.177	1.993	1.904	1.961	1.985	1.867	1.993	2.189	2.055	2.182	2.245	(41)	
	Ebn at Noon		848	841	783	743	746	739	712	755	808	767	798	828	(42)	
		Edh at Noon	135	150	185	202	187	181	204	182	150	168	143	132	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.62	6.33	6.78	6.88	6.19	3.98	3.69	4.14	5.00	5.19	5.25	5.29	(44)	
	RadStd		0.18	0.16	0.22	0.21	0.41	0.32	0.46	0.34	0.50	0.34	0.31	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.14	N/A	+0.61	+0.34	+0.39	+0.33	N/A	N/A	N/A	N/A

Nomenclature: See separate page