

MO AMINI, India

WMO: 433110

Lat: 11.1178N

Lon: 72.7168E

Elev: 10

StdP: 14.69

Time Zone: 5.50 (IND)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.5	75.5	67.8	102.1	78.7	69.3	107.5	79.8	9.8	85.3	8.9	85.1	0.9	270	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.8	94.1	82.9	93.1	82.3	92.0	81.8	84.9	90.4	84.3	89.7	83.7	88.8	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.5	175.5	87.7	82.9	171.6	87.2	82.4	169.1	86.9	49.2	91.0	48.5	89.8	47.9	89.2	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.8	19.0	16.8	DB	70.5	96.3	3.4	1.7	68.1	97.5	66.1	98.5	64.1	99.5	61.7	100.7	
			WB	67.3	85.5	2.0	0.6	65.8	85.9	64.7	86.3	63.5	86.6	62.0	87.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.0	83.0	84.2	85.7	87.1	87.2	83.8	82.9	82.7	82.6	83.1	83.4	83.0
	DBStd	2.37	1.56	1.48	1.60	1.55	2.48	2.10	1.68	1.56	1.71	1.71	1.63	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12427	1023	957	1106	1114	1152	1013	1020	1014	979	1026	1001	1022
	CDD65	6952	558	537	641	664	687	563	555	549	529	561	551	557
	CDH74	83976	5973	6221	8095	8993	9436	7136	6689	6409	6070	6515	6326	6113
	CDH80	33912	2248	2497	3707	4684	5005	2877	2299	2037	1854	2215	2301	2188
Wind	WSAvg	4.7	2.1	2.4	2.3	2.5	3.9	9.9	12.2	8.8	5.7	3.0	1.3	1.8
Precipitation	PrecAvg	61.6	0.1	0.2	0.0	1.0	6.5	15.6	14.0	9.8	6.3	5.2	4.0	1.8
	PrecMax	94.7	1.0	1.5	0.4	3.5	17.2	33.0	29.3	19.0	17.2	17.0	14.9	6.6
	PrecMin	37.3	0.0	0.0	0.0	0.0	0.0	4.1	3.7	1.3	1.3	1.3	0.1	0.0
	PrecStd	15.3	0.3	0.4	0.1	0.9	5.9	7.1	6.6	5.7	4.4	3.9	3.8	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.7	92.7	94.2	95.1	95.5	90.7	88.0	87.8	89.9	90.9	91.5	91.4
		MCWB	80.4	81.0	82.2	83.2	83.8	82.7	82.8	81.6	83.2	81.9	81.5	80.6
	2%	DB	90.7	91.7	92.7	93.9	94.4	88.8	86.8	86.5	88.0	89.6	90.3	90.3
		MCWB	79.8	80.6	81.5	82.6	83.4	82.7	82.0	81.1	81.6	81.4	81.2	80.0
	5%	DB	89.7	90.8	91.7	92.8	93.3	87.5	86.1	85.8	86.6	88.3	89.4	89.3
		MCWB	79.2	80.3	81.1	82.1	83.0	82.4	81.6	80.9	80.9	80.7	80.8	79.5
	10%	DB	88.7	89.8	90.7	91.7	92.0	86.7	85.4	85.1	85.6	87.1	88.3	88.2
		MCWB	78.7	79.9	80.8	81.8	82.6	82.1	81.3	80.8	80.4	80.3	80.5	79.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.5	84.0	84.6	85.3	85.5	84.9	84.2	83.7	84.5	83.7	83.7	83.4
		MCDB	89.8	90.8	91.6	92.3	91.6	87.5	86.2	86.0	88.5	88.9	89.3	89.4
	2%	WB	81.4	82.6	83.5	84.4	85.1	84.1	83.4	82.8	82.8	82.6	82.8	82.1
		MCDB	88.9	89.7	90.6	91.4	91.1	86.9	85.4	85.1	86.4	87.5	88.5	88.2
	5%	WB	80.6	81.4	82.5	83.6	84.5	83.5	82.7	82.3	81.9	81.8	82.0	81.1
		MCDB	88.1	88.9	89.6	90.4	90.4	86.4	84.8	84.5	85.2	86.4	87.5	87.0
	10%	WB	79.7	80.5	81.5	82.9	83.8	82.8	82.2	81.7	81.2	81.1	81.3	80.2
		MCDB	86.8	88.2	88.4	89.5	89.7	85.8	84.4	84.0	84.3	85.4	86.6	85.8
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.1	11.0	9.7	8.8	5.5	4.2	4.5	5.5	7.7	9.9	11.0
		MCDBR	13.2	12.8	12.1	10.9	10.7	5.9	4.4	5.1	7.0	9.9	11.6	12.2
		MCWBR	5.8	5.2	4.8	4.4	4.3	3.6	3.2	3.0	3.7	4.6	5.4	5.4
	5% WB	MCDBR	12.1	11.9	11.1	9.8	9.1	5.2	4.3	4.7	6.0	8.1	10.0	10.5
MCWBR		5.8	5.8	5.3	4.8	4.5	3.7	3.5	3.4	3.8	4.6	5.2	5.5	
Clear-Sky Solar Irradiance	taub	0.486	0.492	0.549	0.574	0.542	0.571	0.612	0.555	0.486	0.502	0.511	0.492	
	taud	2.177	2.158	2.022	1.986	2.093	2.014	1.892	2.051	2.275	2.211	2.156	2.184	
	Ebn at Noon	260	264	250	242	245	235	226	243	263	258	251	255	
	Edh at Noon	47	49	57	59	52	56	63	55	44	46	48	46	
All-Sky Solar Radiation	RadAvg	1747	1967	2089	2058	1788	1383	1481	1648	1741	1588	1545	1605	
	RadStd	69	59	81	81	167	134	218	205	179	116	98	89	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page