

COIMBATORE INTL, India

WMO: 433210

Lat: 11.031N

Lon: 77.044E

Elev: 404

StdP: 96.57

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.5	19.4	5.4	5.8	32.3	8.0	7.0	30.8	6.3	27.7	5.6	27.5	0.6	20	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.8	36.7	22.2	35.8	22.2	34.9	22.6	25.7	31.3	25.2	30.6	25.0	30.3	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	20.4	27.2	24.1	20.0	27.0	23.8	19.6	26.8	81.6	31.6	80.0	30.5	78.6	30.4	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.4	6.7	16.5	38.0	1.6	1.0	15.3	38.7	14.3	39.3	13.4	39.8	12.2	40.5		
(5)			13.3	27.2	1.1	1.0	12.5	27.9	11.9	28.5	11.3	29.1	10.5	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	25.1	26.8	29.0	30.0	29.1	27.5	26.7	26.8	27.3	26.9	25.7	24.7
	DBStd	1.99	1.12	1.34	1.31	1.31	1.48	1.44	1.14	1.09	0.97	1.23	1.23	1.22
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6249	467	471	588	601	592	524	518	522	519	523	469	455
	CDD18.3	3208	209	237	330	351	333	274	260	264	269	264	219	197
	CDH23.3	29888	1668	2417	3915	4248	3719	2459	2041	2044	2252	2160	1609	1354
	CDH26.7	12429	549	1101	2042	2192	1733	935	692	721	864	784	463	352
Wind	WSAvg	3.0	2.0	2.3	2.4	2.6	3.5	4.8	4.8	4.4	3.9	2.4	1.7	1.8
Precipitation	PrecAvg	648	6	8	13	39	80	30	44	26	59	159	127	56
	PrecMax	1339	54	104	109	94	171	105	146	126	188	396	687	226
	PrecMin	259	0	0	0	0	21	0	4	1	0	13	30	0
	PrecStd	229	13	21	26	24	46	29	36	28	50	98	131	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	35.5	37.2	38.0	36.9	35.0	33.2	33.2	34.0	33.7	32.1	31.5
		MCWB	19.9	19.7	20.4	22.5	24.2	24.4	23.7	24.0	23.5	22.8	22.0	20.5
	2%	DB	31.2	34.0	36.2	37.0	35.7	33.6	32.1	32.2	32.9	32.8	31.1	30.2
		MCWB	19.6	19.9	20.5	22.7	24.5	24.1	23.6	23.7	23.4	22.9	22.2	20.5
	5%	DB	30.4	33.0	35.5	36.0	34.7	32.4	31.1	31.3	32.0	31.8	30.2	29.5
		MCWB	19.5	19.5	20.7	22.7	24.5	23.9	23.4	23.6	23.4	23.0	22.1	20.4
	10%	DB	29.7	32.0	34.5	35.0	33.7	31.2	30.2	30.4	31.1	30.8	29.2	28.7
		MCWB	19.5	19.7	20.9	23.0	24.5	23.6	23.3	23.5	23.3	23.1	22.0	20.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	23.7	25.2	25.9	26.4	25.7	24.8	25.2	25.4	25.0	24.7	23.8
		MCDB	27.6	27.9	30.4	30.8	32.5	31.7	30.5	30.7	30.2	29.3	28.2	27.2
	2%	WB	22.3	23.1	24.5	25.4	25.8	25.1	24.4	24.6	24.7	24.5	24.1	23.1
		MCDB	26.8	28.0	29.5	30.4	31.9	30.8	29.9	29.9	29.6	28.8	27.7	26.4
	5%	WB	21.8	22.6	24.1	25.1	25.4	24.6	24.0	24.2	24.2	24.1	23.7	22.6
		MCDB	26.3	27.7	29.0	30.1	31.2	30.0	29.3	29.3	29.2	28.5	27.1	25.9
	10%	WB	21.4	22.2	23.7	24.8	25.1	24.2	23.7	23.8	23.8	23.8	23.4	22.2
		MCDB	26.1	27.3	28.6	29.8	30.6	29.2	28.4	28.6	28.6	27.9	26.5	25.3
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.1	11.6	10.8	9.7	8.1	7.8	8.0	8.7	8.1	7.4	8.5
		MCDBR	10.7	12.2	12.5	11.6	10.8	9.4	8.9	9.2	9.8	9.6	8.9	9.6
		MCWBR	3.0	3.4	3.9	3.3	2.4	2.3	2.3	2.2	2.1	2.4	2.5	2.7
	5% WB	MCDBR	8.8	10.3	11.5	10.8	9.9	8.6	8.3	8.3	8.6	8.1	7.1	7.3
		MCWBR	2.8	3.1	3.7	3.2	2.9	2.6	2.4	2.4	2.4	2.5	2.4	2.5
Clear-Sky Solar Irradiance	taub		0.446	0.456	0.517	0.552	0.541	0.470	0.491	0.475	0.454	0.508	0.488	0.451
	taud		2.184	2.163	2.011	1.964	2.011	2.256	2.177	2.232	2.295	2.108	2.139	2.209
	Ebn at Noon		857	863	816	780	773	821	807	831	857	806	812	842
	Edh at Noon		146	154	183	190	177	137	149	143	135	161	152	140
All-Sky Solar Radiation	RadAvg		5.38	6.11	6.34	6.11	5.73	4.80	4.56	4.78	5.21	4.77	4.46	4.68
	RadStd		0.23	0.26	0.29	0.23	0.35	0.33	0.35	0.31	0.39	0.26	0.37	0.31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.65	+0.63	N/A	+1.11	+0.33	+0.30	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.45	N/A	N/A	+1.02	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page