

PORT BLAIR, India

WMO: 433330

Lat: 11.667N

Lon: 92.717E

Elev: 259

StdP: 14.56

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	71.2	72.7	62.9	86.5	79.3	64.9	93.2	78.9	20.8	81.8	18.1	81.8	1.0	320	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.2	91.2	79.9	89.9	79.4	88.8	79.1	81.6	87.7	81.0	86.6	80.6	86.0	5.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	157.4	84.4	79.5	154.4	83.8	79.1	152.2	83.4	45.6	88.4	44.9	87.0	44.4	86.2	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.8	15.3	13.4	DB	67.3	93.4	2.5	1.9	65.5	94.8	64.0	95.9	62.6	96.9	60.8	98.3
			WB	64.9	83.2	1.5	1.3	63.8	84.1	63.0	84.9	62.1	85.6	61.0	86.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	79.9	80.5	81.7	83.5	82.5	81.0	80.8	80.6	79.9	80.8	81.6	80.8
	DBStd	2.23	1.96	1.90	1.84	1.93	2.62	2.04	1.87	1.94	2.04	1.79	1.76	2.00
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11366	927	853	983	1006	1007	931	955	947	898	956	949	954
	CDD65	5891	462	433	518	556	542	481	490	482	448	491	499	489
	CDH74	60187	4299	4328	5696	6726	5996	4920	4897	4680	3938	4657	5205	4845
(13)	CDH80	16653	928	1229	2030	2741	2026	1204	1101	969	740	1134	1423	1128
(14)	Wind	WSAvg	4.7	4.2	3.1	2.4	2.4	5.1	7.3	7.2	5.1	3.1	4.0	4.8
(15) Precipitation	PrecAvg	119.2	1.9	0.5	0.7	2.7	15.9	18.1	17.2	16.9	18.7	12.0	9.1	5.8
	PrecMax	163.5	9.6	4.3	5.6	12.0	41.8	35.9	36.2	28.5	39.0	24.4	23.6	28.0
	PrecMin	61.0	0.0	0.0	0.0	0.0	5.1	4.9	1.1	4.2	0.9	4.1	1.5	0.0
	PrecStd	19.8	2.2	0.9	1.2	2.8	7.8	6.0	6.7	5.2	6.7	4.7	5.0	6.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.8	88.3	91.0	93.1	92.7	88.6	87.4	87.5	87.8	88.5	88.8	87.5
		MCWB	77.2	76.3	77.3	79.9	81.6	80.7	79.7	79.9	79.9	80.1	79.6	78.4
	2%	DB	85.9	87.3	89.5	91.5	90.9	86.9	86.1	86.1	86.4	87.3	87.7	86.3
		MCWB	76.7	76.6	77.7	79.9	80.8	80.0	79.4	79.3	79.3	79.7	79.3	77.6
	5%	DB	85.1	86.5	88.3	90.3	89.3	85.8	85.3	85.1	85.3	86.4	86.9	85.6
		MCWB	76.3	76.6	77.5	79.6	80.4	79.5	79.1	79.0	78.8	79.3	78.9	77.2
	10%	DB	84.3	85.7	87.4	89.2	87.5	84.8	84.4	84.1	84.0	85.4	86.0	84.8
		MCWB	75.8	76.4	77.3	79.2	80.1	79.3	78.8	78.7	78.4	78.9	78.4	76.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	79.8	80.6	82.1	82.8	81.9	81.0	80.9	80.9	81.3	81.0	80.4
		MCDB	84.4	85.9	88.0	90.7	89.5	86.5	84.8	85.5	85.6	86.6	86.7	85.8
	2%	WB	78.3	78.8	79.7	81.0	81.7	80.9	80.3	80.1	80.0	80.4	80.2	79.2
		MCDB	83.6	85.3	86.8	89.2	87.9	84.9	84.0	84.2	84.4	85.9	86.0	84.4
	5%	WB	77.7	78.0	79.0	80.4	81.0	80.3	79.9	79.5	79.2	79.8	79.6	78.6
		MCDB	82.9	84.4	86.0	88.2	86.9	84.0	83.5	83.3	83.1	85.0	85.2	83.6
	10%	WB	77.0	77.3	78.3	79.8	80.5	79.8	79.4	79.1	78.8	79.1	79.0	78.0
		MCDB	82.2	83.5	85.0	87.1	86.1	83.4	82.9	82.6	82.5	84.0	84.3	82.8
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	11.1	11.9	11.2	9.0	7.0	6.8	6.7	7.3	8.4	8.2	8.1
		MCDBR	9.3	11.4	12.7	12.6	11.2	8.0	7.5	7.9	8.9	9.7	9.1	8.4
		MCWBR	4.1	4.6	4.5	3.9	4.0	3.4	3.2	3.2	3.8	4.3	4.1	3.8
	5% WB	MCDBR	8.4	9.9	11.2	11.4	9.9	7.6	6.9	7.4	7.9	9.1	8.7	7.8
		MCWBR	4.1	4.6	4.6	4.1	4.4	4.1	3.6	3.6	4.1	4.6	4.3	3.9
(40) Clear-Sky Solar Irradiance	taub		0.459	0.472	0.483	0.463	0.493	0.505	0.503	0.491	0.453	0.451	0.461	0.460
	taud		2.282	2.221	2.233	2.327	2.274	2.236	2.226	2.271	2.401	2.398	2.336	2.302
	Ebn at Noon		268	269	268	270	258	252	253	259	272	272	266	265
	Edh at Noon		42	46	46	42	43	44	45	44	39	38	40	41
(44) All-Sky Solar Radiation	RadAvg		1628	1911	2002	2014	1507	1369	1406	1435	1449	1577	1524	1480
(45)	RadStd		93	66	136	129	121	132	159	153	156	107	105	101

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.24	+0.97	+1.04	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page