

PORT BLAIR, India

WMO: 433330

Lat: 11.667N

Lon: 92.717E

Elev: 79

StdP: 100.38

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	21.8	22.6	17.1	12.4	26.3	18.3	13.3	26.1	9.3	27.7	8.1	27.7	0.5	320	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.2	32.9	26.6	32.2	26.4	31.6	26.2	27.6	30.9	27.2	30.3	27.0	30.0	2.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.5	29.1	26.4	22.1	28.8	26.1	21.7	28.5	88.2	31.3	86.6	30.6	85.4	30.1	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.9	6.0	19.6	34.1	1.4	1.0	18.6	34.9	17.8	35.5	17.0	36.1	16.0	36.8		
(5)			18.3	28.5	0.8	0.7	17.7	29.0	17.2	29.4	16.7	29.8	16.1	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	26.6	26.9	27.6	28.6	28.1	27.2	27.1	27.0	26.6	27.1	27.6	27.1
	DBStd	1.24	1.09	1.05	1.02	1.07	1.46	1.13	1.04	1.08	1.13	1.00	0.98	1.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6314	515	474	546	559	559	517	531	526	499	531	527	530
	CDD18.3	3273	257	241	288	309	301	267	272	268	249	273	277	272
	CDH23.3	33437	2388	2404	3164	3737	3331	2733	2721	2600	2188	2587	2892	2692
	CDH26.7	9252	516	683	1128	1523	1126	669	612	538	411	630	791	627
Wind	WSAvg	2.1	1.9	1.4	1.1	1.1	2.3	3.3	3.3	3.2	2.3	1.4	1.8	2.2
Precipitation	PrecAvg	3027	49	13	18	68	404	459	437	430	475	304	231	147
	PrecMax	4154	244	109	142	305	1061	912	919	723	991	619	599	710
	PrecMin	1550	0	0	0	0	129	125	27	106	22	103	38	0
	PrecStd	503	56	22	31	70	199	153	170	131	171	120	126	164
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.5	31.3	32.8	34.0	33.7	31.4	30.8	30.9	31.0	31.4	31.5	30.8
		MCWB	25.1	24.6	25.2	26.6	27.6	27.1	26.5	26.6	26.6	26.7	26.4	25.8
	2%	DB	29.9	30.7	31.9	33.0	32.7	30.5	30.1	30.1	30.2	30.7	30.9	30.2
		MCWB	24.8	24.8	25.4	26.6	27.1	26.6	26.3	26.3	26.3	26.5	26.3	25.4
	5%	DB	29.5	30.3	31.3	32.4	31.8	29.9	29.6	29.5	29.6	30.2	30.5	29.8
		MCWB	24.6	24.8	25.3	26.4	26.9	26.4	26.2	26.1	26.0	26.3	26.1	25.1
	10%	DB	29.1	29.8	30.8	31.8	30.8	29.4	29.1	29.0	28.9	29.7	30.0	29.3
		MCWB	24.3	24.7	25.2	26.2	26.7	26.3	26.0	25.9	25.8	26.1	25.8	24.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.6	27.0	27.8	28.2	27.7	27.2	27.2	27.2	27.4	27.2	26.9
		MCDB	29.1	29.9	31.1	32.6	32.0	30.3	29.3	29.7	29.8	30.3	30.4	29.9
	2%	WB	25.7	26.0	26.5	27.2	27.6	27.2	26.9	26.7	26.7	26.9	26.8	26.2
		MCDB	28.6	29.6	30.5	31.8	31.0	29.4	28.9	29.0	29.1	30.0	30.0	29.1
	5%	WB	25.4	25.6	26.1	26.9	27.2	26.8	26.6	26.4	26.2	26.5	26.5	25.9
		MCDB	28.3	29.1	30.0	31.2	30.5	28.9	28.6	28.5	28.4	29.4	29.6	28.7
	10%	WB	25.0	25.2	25.7	26.5	26.9	26.6	26.3	26.1	26.0	26.2	26.1	25.5
		MCDB	27.9	28.6	29.5	30.6	30.0	28.6	28.3	28.1	28.1	28.9	29.0	28.2
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.2	6.6	6.2	5.0	3.9	3.8	3.7	4.0	4.7	4.5	4.5
		MCDBR	5.2	6.3	7.1	7.0	6.2	4.4	4.2	4.4	5.0	5.4	5.1	4.6
		MCWBR	2.3	2.5	2.5	2.2	2.2	1.9	1.8	1.8	2.1	2.4	2.3	2.1
	5% WB	MCDBR	4.7	5.5	6.2	6.3	5.5	4.2	3.9	4.1	4.4	5.0	4.8	4.3
		MCWBR	2.3	2.6	2.5	2.3	2.5	2.3	2.0	2.0	2.3	2.5	2.4	2.2
Clear-Sky Solar Irradiance	taub	0.459	0.472	0.483	0.463	0.493	0.505	0.503	0.491	0.453	0.451	0.461	0.460	
	taud	2.282	2.221	2.233	2.327	2.274	2.236	2.226	2.271	2.401	2.398	2.336	2.302	
	Ebn at Noon	844	848	844	852	812	793	797	818	857	857	837	834	
	Edh at Noon	133	145	146	132	137	140	142	138	122	120	125	128	
All-Sky Solar Radiation	RadAvg	5.13	6.02	6.31	6.35	4.75	4.32	4.43	4.52	4.57	4.97	4.80	4.67	
	RadStd	0.29	0.21	0.43	0.41	0.38	0.41	0.50	0.48	0.49	0.34	0.33	0.32	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.69	+0.54	+0.58	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page