

ANURADHAPURA, Sri Lanka

WMO: 434210

Lat: 8.301N

Lon: 80.428E

Elev: 324

StdP: 14.52

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.3	70.8	63.8	89.7	81.9	65.4	95.1	80.2	7.2	79.3	5.5	80.3	0.3	50	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.8	95.2	77.4	94.0	77.7	92.8	77.9	80.9	89.7	80.3	88.9	79.9	88.2	2.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	151.0	84.4	78.2	148.2	83.9	77.7	146.0	83.5	44.9	90.3	44.3	89.3	43.7	88.7	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.5	6.6	66.1	98.2	1.2	1.2	65.2	99.1	64.5	99.8	63.8	100.4	62.9	101.3		
(5)			64.0	82.4	1.6	0.7	62.9	82.9	61.9	83.3	61.0	83.6	59.8	84.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	78.4	80.2	83.8	84.8	84.6	84.1	84.5	84.1	84.0	82.5	80.1	78.8		
	DBStd	3.04	1.94	2.27	2.04	2.15	1.80	1.64	1.49	1.79	1.93	2.33	1.86	2.17		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11858	880	846	1048	1043	1071	1023	1070	1056	1019	1007	904	891		
	CDD65	6383	415	426	583	593	606	573	605	591	569	542	454	426		
	CDH74	66104	3014	3705	6440	6908	7192	6704	6999	6635	6299	5312	3748	3148		
	CDH80	25500	772	1294	2891	3174	3068	2625	2845	2658	2527	1929	995	722		
(14) Wind	WSAvg	2.1	1.3	1.2	1.1	1.1	2.9	4.2	3.6	3.2	3.0	1.6	0.6	1.0		
(15) Precipitation	PrecAvg	51.5	3.1	2.0	2.5	6.0	3.3	0.3	1.2	1.6	2.4	11.0	9.5	8.5		
	PrecMax	76.7	13.7	6.0	7.1	10.9	9.4	2.4	6.5	8.6	5.7	20.5	15.6	19.3		
	PrecMin	33.9	0.0	0.0	0.0	1.2	0.0	0.0	0.0	0.6	2.6	2.9	2.7	2.7		
	PrecStd	11.7	4.1	1.8	1.8	2.2	2.6	0.6	1.7	2.3	1.4	5.0	3.9	4.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.6	91.8	96.8	96.8	94.8	93.4	95.0	94.5	95.0	95.0	90.0	88.7		
		MCWB	76.1	76.8	75.2	77.6	79.8	78.9	77.8	77.3	77.2	76.3	77.7	76.0		
	2%	DB	87.0	89.9	94.8	95.1	93.0	91.8	92.8	92.7	93.2	92.5	88.5	86.9		
		MCWB	75.2	76.4	76.0	78.2	79.7	78.5	77.9	77.2	77.1	76.8	77.4	76.5		
	5%	DB	85.7	88.6	93.0	93.7	91.7	90.5	91.4	91.4	91.7	90.7	87.1	85.7		
		MCWB	74.5	75.9	76.6	78.7	79.6	78.3	77.5	77.0	77.0	77.3	77.3	76.2		
	10%	DB	84.5	87.1	91.3	92.1	90.5	89.3	90.1	90.0	90.1	88.8	85.6	84.2		
		MCWB	74.3	75.4	76.7	78.9	79.4	78.1	77.3	76.9	76.9	77.4	77.2	75.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.3	79.2	80.0	81.4	81.9	80.9	79.9	80.0	79.7	80.0	79.7	79.6		
		MCDB	84.7	87.0	89.4	91.4	90.5	89.7	90.4	89.2	89.5	88.1	86.3	84.6		
	2%	WB	77.3	78.3	79.2	80.8	81.0	79.9	79.0	78.9	78.9	79.2	78.9	78.3		
		MCDB	83.1	86.0	88.4	90.1	89.6	88.2	89.4	88.3	88.2	86.8	85.3	83.1		
	5%	WB	76.5	77.6	78.5	80.1	80.5	79.2	78.3	78.2	78.2	78.7	78.2	77.7		
		MCDB	81.9	84.8	87.5	89.0	88.9	87.1	88.0	87.1	87.0	86.0	84.1	82.2		
	10%	WB	75.8	76.9	78.0	79.7	80.0	78.8	77.8	77.6	77.6	78.1	77.8	77.1		
		MCDB	80.7	83.7	86.5	88.2	87.7	86.3	86.9	86.1	85.9	85.0	83.2	81.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	14.3	16.7	15.7	12.8	11.2	12.9	13.4	13.5	13.2	11.0	10.4		
		MCDBR	14.7	16.3	18.6	17.7	14.7	13.0	14.4	14.8	15.7	16.1	13.7	13.2		
	5% WB	MCWBR	4.7	4.6	4.4	4.6	4.1	2.9	3.0	3.1	3.3	3.9	4.7	4.7		
		MCWBR	11.1	13.9	16.4	16.0	13.3	11.7	13.8	13.6	13.8	13.6	11.6	10.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.435	0.433	0.462	0.475	0.529	0.505	0.518	0.500	0.471	0.473	0.459	0.457		
		taud	2.322	2.305	2.241	2.246	2.076	2.163	2.106	2.169	2.266	2.260	2.299	2.277		
	Ebn at Noon	Ebn at Noon	279	282	274	267	247	250	248	257	268	267	269	269		
		Edh at Noon	41	43	46	45	53	48	50	49	44	44	42	42		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1461	1745	1929	1883	1793	1741	1755	1763	1782	1597	1322	1265		
	RadStd	RadStd	141	116	103	88	117	76	62	80	105	84	112	128		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page